

United Utilities Inspection Notice

This form is to confirm a new connection has been made
to an existing public sewer under Section 106 of the
Water Industry Act 1991



Site details: Details of the site or premise that have been connected to the public sewer		
United Utilities notification reference (EC/NC/SC/WC)	ICS-05343041	
Site address	Victoria Mill, Lower Vickers street, M40 7LH S106	
Development type	New property	

Contractor Details		
Contractor name / Company Name	Thomas contracting	
Contractor Email Address	Joe@thomascontractingltd.com	
Works Supervisor	Richard Hubbard	
Confirm sewer 'log on' & 'log off' procedure followed	Yes ☐	No ☐

Principal Contractor Details (if applicable)		
Company name (if applicable)	Truman	
Name of Contact for Project	David Lockwood	
Email Address	Davidlockwood@trumandab.com	
Number of site inspections conducted by United Utilities	2	

Connection details		
Sewer connection type	Surface Water	
Surface Water sewer pipesize diameter	300mm	
Connecting into:	Existing Sewer Type	Combined
Connecting to asset:	new manhole	
Connection Location	site	

Outcome	
Connection status	Satisfactory

Comments
I can confirm that the Surface Water Sewer connection is SATISFACTORY - 300mm Surface Water Sewer connecting into the Combined connected via new manhole in site

Approved: I confirm the sewer connection detailed above has been
satisfactorily completed and inspected

Developer Services Inspector	Wesley Odell
Date of Inspection	22/04/2024