Will Brown <willbrown@ggpconsult.co.uk>

UU REF 05491936- Spath Road, Didsbury, Manchester

2 messages

seweradoptions@uuplc.co.uk <seweradoptions@uuplc.co.uk> 25 March 2024 at 11:58
To: "willbrown@ggpconsult.co.uk" <willbrown@ggpconsult.co.uk>
Cc: "jeremycollins@ggpconsult.co.uk" <jeremycollins@ggpconsult.co.uk>, "ciaranmcateer@ggpconsult.co.uk" <ciaranmcateer@ggpconsult.co.uk>, "darren.staff@mccarthyandstone.co.uk" <darren.staff@mccarthyandstone.co.uk>

Hi Will,

Thank you for your email, please see below:

UU REF 05491936- Spath Road, Didsbury, Manchester

I can confirm United Utilities have no objections in principal to a combined connection with surface water flow restricted to a maximum of 5 l/s.

Please do contact me on my mobile should you wish to discuss this matter in more detail.

Regards

Anthony

Anthony Laithwaite
Ww Engineer
Developer Services & Metering
Customer Services

M: 07880 298897
unitedutilities.com