A0

EXISTING SQUARE RECESSED IP RATED DOWNLIGHTS INSTALLED WITHIN PORTICO CEILING. CURRENTLY NOT IN OPERATION

PORTICO

ENTRANCE HALL
CG.1

FOUR ARM FITTING
CHAIN SUSPENSION
4 x 60W GLASS

LINEAR FLUORESCENT
T8 LIGHTING

CG.8

BT

3A PSU

FAP

HL

x2

MORNING ROOM
CG.2

CHAIN SUSPENSION
WITH FLUTED MONKS
CAP & DPAL GLASS
SPHERE - 150W

LIGHTING IS PROVIDED USING TRACK LIGHTING/SPOT LIGHTING

EXHIBITION ROOM
EG.1

12 WAY
DP SWITCHES
TRACK LIGHTING
EG

EG.S1

UP

DN

JB

WROUGHT IRON STAND WITH BULLY IN LIGHTING C/W CLEAR GLASS BOWL

INNER HALL
CG.3

CHAIN SUSPENSION
WITH FLUTED MONKS
CAP & DPAL GLASS
SPHERE - 150W

CORRIDOR
EG.C1

4No CEILING GLASS
HALLWOOD COMICAL
LIMINAIRE

WG.7

CG.S2

CG.7

GRAND STAIRCASE
CG.S1

ANTE ROOM
TO LIBRARY
EG.2

MUSIC ROOM
EG.4

CHANDELIER
12 CANDLE LAMPS

BULKHEAD
FITTING

ORGAN

DINING ROOM
CG.6

FIVE ARM CLEAR
GLASS CHANDLER
ON CHAIN SUSPENSION

SALOON
CG.5

CHANDELIER
10 CANDLE LAMPS

BILLIARDS ROOM
CG.4

FOUR ARM CLEAR GLASS/PERSPEX
CHANDELIER ON CHAIN SUSPENSION
WITH CANDLE LAMPS

LOGGIA

LIBRARY
EG.3

FOUR ARM FITTING
CHAIN SUSPENSION
4 CANDLE LAMPS

CEI

FIRE ALARM LEGEND

SYMBOL	DESCRIPTION
S	OPTICAL SMOKE DETECTOR
	MANUAL CALL POINT
	FIRE ALARM BELL
FAP	FIRE ALARM PANEL

LIGHTING CONTROLS LEGEND

SYMBOL	DESCRIPTION
	ONE WAY GRID SWITCH

CONTAINMENT LEGEND

SYMBOL	DESCRIPTION
C	STEEL CONDUIT

LIGHTING LEGEND

SYMBOL	DESCRIPTION
	EXISTING FLOODLIGHT
	TRACK LIGHTING WITH SPOT LIGHTS

CCTV LEGEND

SYMBOL	DESCRIPTION
	CCTV CAMERA 240V SUPPLY

CONTAINMENT LEGEND

SYMBOL	DESCRIPTION
JB	JOINT BOX

SMALL POWER LEGEND

SYMBOL	DESCRIPTION
	13A SINGLE SOCKET(FLOOR)
	13A SINGLE SOCKET
	13A DUAL SOCKET
	13 SPUR UNIT
	13A SINGLE SOCKET(ABOVE 900mm FFL)
	13A DUAL SOCKET(ABOVE 900mm FFL)
S	STARTER FOR ORGAN MOTOR

INTRUDER ALARM LEGEND

SYMBOL	DESCRIPTION
	INTRUDER ALARM DETECTOR
LIM	LIM CARD

GENERAL NOTES

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ECS ELECTRICAL ENGINEERING SPECIFICATIONS.
2. THIS DRAWING IS INDICATIVE AND IS INTENDED TO HIGHLIGHT THE PROPOSED LOCATION FOR ELECTRICAL SERVICES. THE CONTRACTOR SHALL NOTE THESE DRAWINGS SHALL NOT BE USED FOR CONSTRUCTION PURPOSES. THE CONTRACTOR SHALL INCLUDE TO PRODUCE THEIR OWN WORKING DRAWINGS, TAKE DETAILED SITE MEASUREMENTS, INDICATE THE PROVISION OF BUILDERS WORKS AND COORDINATE THE INSTALLATION OF ALL SERVICES.
3. THE CONTRACTOR SHALL NOTE THIS DRAWING HAS BEEN PRODUCED USING LIMITED SITE SURVEY INFORMATION. THE CONTRACTOR SHALL INCLUDE TO CARRY OUT AN INTRUSIVE SURVEY AND TO PRODUCE DRAWINGS THAT REFLECT THE INSTALLATION.
4. ALL EQUIPMENT SHALL BE INSTALLED & LOCATED TO MAINTAIN SPATIAL REQUIREMENTS TO FACILITATE ACCESS & MAINTENANCE IN LINE WITH MANUFACTURERS RECOMMENDATIONS AND GOOD PRACTICE GUIDES.
5. ALL EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS GUIDELINES.
6. DO NOT SCALE FROM THIS DRAWING.
7. ALL DETAILS ARE APPLICABLE TO EVERY DRAWING UNLESS INDICATED OTHERWISE.
8. THE CONTRACTOR SHALL INCLUDE TO IDENTIFY THE COMPLETE EXISTING ELECTRICAL INSTALLATION, EXTEND AND ADAPT TO FACILITATE THE PROPOSED WORKS

ABBREVIATIONS

HL	HIGH LEVEL

DRAWING NOTES

SYMBOL	DESCRIPTION
⚠	CONTRACTOR SHALL INSTALL NEW FIRE ALARM DETECTORS IN THE MAJORITY OF THE EXISTING LOCATIONS WHERE NEW DETECTOR ARE REQUIRED DUE TO THE IMPROVEMENT IN FIRE PROTECTION THEN THE LOCATION WILL BE AS THE DRAWING (HIGHLIGHTED)

CAD original - not to be modified by hand

Rev.	Description	By	Date
T2	TENDER ISSUE.	G.M.	May. 24
T1	TENDER ISSUE.	G.M.	Mar. 24

STATUS

TENDER

CONSULTANTS
Building Services Consulting Engineers
148 Stockport Road
Cheadle, Cheshire, SK8 2DP
Tel. 0161 283 2882 Fax 0161 282 8825
Web Site: www.ecs-ecs.co.uk Email: sales@ecs-ecs.co.uk

JOB NO.	DRAWING NO.	COMPUTER FILE	REVISION
24/100	24/100/E/32	24_100_E_32	T2
DATE	SCALE	DRAWN	CHECKED
Mar. 2024	1:50 @ A0	G.P.	G.M.

JOB TITLE
Heaton Park Hall MCC
Planners Infomation

DRAWING TITLE
Ground Floor
Existing Electrical Layout