

Barney Hospitality Limited

A full clean would be scheduled in line with the recommended cleaning frequencies set out within the Hy5 Cleaning RAMS and covering letter. The first extraction clean (to include the canopy, ductwork and fans) would take place 3 months after the first occupation of Unit 3. Following this, a full clean would be undertaken on a frequency of every 3 to 6 months, the regularity required to be determined based on Hy5's assessment following the first clean. These full cleans would see all systems cleaned to T19 standards as per BESA requirements, and would be carried out by Hy5 as a fully accredited contractor.

This will run alongside the regular site cleaning procedures of canopies. There will be daily visual workplace inspections and any build up of debris or grease will be cleaned with Catering degreaser, adhering to requirements of the relevant COSHH data sheet. A suitable amount of catering degreaser will be applied to supplied rags. Using the rags, kitchen staff will wipe away any grease on any internal/external canopy surface (as required).

The frequency for change for the kitchen filters, including for the ESP, UVO and carbon filters is set out within the SKOF M&E Strategy, and summarised below:

Purified Air ESP Maintenance (every month)

- Ensure systems are isolated and locked off prior to commencing works.
- Replace pre-filter, ioniser, collector and final filter.
- Drain off accumulated grease from filter compartment.
- Clean inside and outside of each product with detergent.
- Check door sealing material, replace as required.
- Check high voltage circuit.
- Check function of indicator lamps.
- All work areas will be kept clean and tidy where possible.
- All tools, equipment and waste will be removed from the site after the job has been completed.

Purified Air UVO Systems Maintenance (every 12 months)

- Ensure systems are isolated and locked off prior to commencing works.
- Clean lamps, check operation.
- Replace filter.
- Replace lamps.
- All work areas will be kept clean and tidy where possible.
- All tools, equipment and waste will be removed from the site after the job has been completed.

Barney Hospitality Limited

Carbon Filters (every 12 months)

- Ensure systems are isolated and locked off prior to commencing works.
- Remove & dispose of filters.
- Install new filters.
- All work areas will be kept clean and tidy where possible.
- All tools, equipment and waste will be removed from the site after the job has been
- completed.