

1. NOTE THAT ALL POWER, DATA, TELEPHONE & FUSED SOCKETS THROUGHOUT PUBLICLY ACCESSIBLE AREAS ARE TO BE FINISHED IN (TBC)
2. SOCKET & OUTLETS TO BACK OF HOUSE AREAS MUST BE WHITE PLASTIC
3. INSTALLATION TO BE INSTALLED IN FULL ACCORDANCE WITH BS7671:2022
4. EARTHING TO BE CARRIED OUT IN FULL ACCORDANCE WITH BS7671:2022 & BS7430:2015

General Notes:

1. This drawing shall be read in conjunction with all general conditions, performance specifications and landlord requirements.
2. This drawing shall be read in conjunction with all associated specialist service drawings, architects, and structural drawings.
3. All equipment selections are indicative, and the contractor shall be responsible for all final calculations and equipment sizing and selection.
4. The project is to be a flush mounted installation throughout except for any plant room which can be surface mounted.
5. This drawing was produced in AutoCAD, DO NOT scale from this drawing. contractor must verify all dimensions on site.
6. All wall and ceiling penetrations for services to be sealed in compliance with fire regulations and building control requirements.

LEGEND

- SINGLE SWITCHED SOCKET OUTLET
- TWIN SWITCHED SOCKET OUTLET
- USB TWIN SWITCHED SOCKET C/W USB
- CLEANERS SOCKETS
- RECESSED FLOOR SOCKET
- ISOLATOR
- COMMANDO SOCKET 16A
- FUSED CONNECTION UNIT WITH SWITCH
- 'DDA' DENOTES DISABLED ALARM

'HD' DENOTES HAND DRYER

'WH' DENOTES WATER HEATER

'DA' DENOTES DOOR ACCESS

'HT' DENOTES HOT TAP

'WP' DENOTES WASTE PUMP

'H' DENOTES PANEL HEATER

'LB' DENOTES LIGHT BOX
- DISTRIBUTION BOARD
- CAT 6 RJ45 DATA OUTLET

DENOTES NUMBER OF OUTLETS

'WIFI' DENOTES WIFI ACCESS POINT
- CAT 6 DATA OUTLET
- DADO TRUNKING (TYPE TBC)
- HAND DRYER
- WATER HEATER
- 'LL' MOUNTED AT LOW LEVEL AT 450mm

'HL' MOUNTED AT HIGH LEVEL AT 1800mm

'AC' MOUNTED AT ABOVE COUNTER
- FLOOR BOC C/W 2No TWIN SOCKETS
- INDUCTION LOOP
- FIRE ALARM PANEL
- CLEAN EARTH CONNECTION
- SHOWER
- FLOOR GROMMET

Revisions

Rev.	Date	Init.	Description

Client

Fourways

Job Title

Fourways

Drawing Title

Small Power & Data Layout

Scale 1 : 100 A1 Drawn by JF

Date 08/04/2024 Checked JM

Status Stage 4

Drg. No.

002-E-01

Rev.

This Drawing Is The Property Of. It Must Not Be Copied Or Lent To Any Third Party Without Written Consent and Must Be Returned Upon Request

