

S106 Part 1 'Application to connect to a public sewer' Approval Notice



United Utilities Reference Number:		04977938				
Applicant details						
Applicant name	MC Construction					
Applicant address (including postcode)	6 Oldfield Road Salford M5 4WB					
Applicant email	mike.purcell@mcconstruction.co.uk					
Site details: The site / property which is proposed for connection to the public sewer						
Site address (including postcode)	Ducie Street Manchester M1 2JN					
<h2>APPROVED</h2> <p>Your application for connection to the public sewer has been approved, to be made via a new connection:</p>						
To a private drain	☐	You may appoint your contractor and advise your appointed building control body (who should inspect the work). United Utilities should be advised when this work is complete.				
Direct to the public sewer	☒	Further action required You may now appoint an appropriately qualified contractor. Your appointed contractor is responsible for obtaining authorisation to work on a public sewer. (The S106 Part 2 application form 'Request for permission to work on a public sewer' is available on our website; unitedutilities.com).				
Mode of connection approved	Connection into existing manhole					
Sewer connection type	Foul	☒	Surface water	☐	Combined	☐
<p>This approval is valid for 12 months from the date below.</p> <p>This approval does not grant access to third party land, permission should be sought if required between applicant and land owner If the new connection renders access unsafe or is otherwise detrimental to the manhole or sewer, a new/upgraded manhole will be requested.</p>						
Comments						
Approval granted for new foul connection into existing manhole in Ducie Street as per drawings submitted.						
Any connection to an existing manhole should be made soffit to soffit, with a swept bend in the direction of flow. The connection must not be made in the landing area. The exact condition, location and depth of the existing manhole and surrounding services should be established as early as possible to avoid site delays. If the existing manhole is in poor condition but otherwise the connection would be acceptable, the applicant should be aware they may have to rebuild/renew the manhole if it deteriorates as a result of your contractor working on or near it.						
Developer Services Inspector	Marcus Jones					
Contact number	07823553970					
Date	08/01/2024					