



Notes Floodlighting Equipment 12 x 5m Masts (C1-C12) 6 x Halliday LED bollards (B1-B6) Each carrying the following Floodlights :- C1-C10 & C121 x SITECO SL21/MINI/LED C112 x SITECO SL21/MINI/LED Illuminance Levels Car park Initial - (100hrs) E.i.ave = 36Lux Maintained - (4000hrs) E.i.ave = 32Lux Uniformity Emin/Eave = 0.25 Stairs Initial - (100hrs) E.i.ave = 26Lux Maintained - (4000hrs) E.i.ave = 23Lux Uniformity Emin/Eave = 0.26 Pathway Initial - (100hrs) E.i.ave = 56Lux Maintained - (4000hrs) E.i.ave = 50Lux Uniformity Emin/Eave = 0.26 Grid values in Lux(initial). Maintenance Factor = 0.90	
HALLIDAY LIGHTING www.halliday-lighting.co.uk	
Project Manchester College - car park	
Drawing Title Aiming-Drawing	
Drawn By (print) DS	Date 20/10/2022
Project No HLS2948	Scale 1:250 @ A3
Drawing No 2948	Status Aiming