

## Emily Booth

---

**From:** Graeme Souter  
**Sent:** 19 January 2023 16:38  
**To:** Emily Booth  
**Subject:** Greggs, Victoria Station 135522/FO/2022

Hiya Emily

Please see recommended conditions and comments below:

FUME\*  
Fume/odours

a) Fumes, vapours and odours shall be extracted and discharged from the premises in accordance with a scheme to be submitted to and approved in writing by the City Council as local planning authority before the use commences.

Mixed use schemes shall ensure provision for internal ducting in risers that terminate at roof level. Schemes that are outside the scope of such developments shall ensure that flues terminate at least 1m above the eave level and/or any openable windows/ventilation intakes of nearby properties.

b) Prior to commencement of the use hereby approved confirmation shall be submitted for the approval of the City Council as local planning authority that the approved scheme has been implemented.

Reason - In the interests of the amenities of occupiers of nearby properties.

\*The applicant will need to consult with a suitably qualified ventilation engineer and submit a kitchen fume extract strategy report for approval. The strategy should include risk assessments for odour and noise and be based on appropriate guidance such as that published by EMAQ titled 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems' dated September 2018. Details should also be provided in relation to replacement air.

The odour assessment provided has been based on different premises in Reading and Bracknell. An updated report for the actual site will be required to determine the risk rating for the odour assessment and details of the fume and odour control system to be installed commensurate with the risk rating for the Victoria Station site need to be provided. The risk rating will need to include any other nearby commercial premises as part of the assessment and scoring.

NSE6

External plant/equipment/servicing

a) Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5dB (LAeq) below the typical background (LA90) level at the nearest noise sensitive location. Prior to commencement of the use hereby approved the scheme shall be submitted to and approved in writing by the City Council as local planning authority in order to secure a reduction in the level of noise emanating from the site. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

b) Prior to the operation of the scheme a verification report shall be submitted to and approved in writing by the City Council as local planning authority to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic report. The report shall also undertake post completion testing to confirm that the noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To minimise the impact of the development and to prevent a general increase in pre-existing background noise levels around the site.

We will require an assessment for the air conditioning unit and the additional extract flue based to demonstrate compliance with the above criteria

Kind regards

Graeme

Graeme Souter  
Environmental Protection Officer  
Environmental Protection  
Environmental Health  
The Neighbourhoods Directorate  
Manchester City Council

Tel: 0161 234 1387  
Call Centre: 0161 234 5004  
email: [Graeme.souter@manchester.gov.uk](mailto:Graeme.souter@manchester.gov.uk)  
website: [www.manchester.gov.uk](http://www.manchester.gov.uk)

\*\*\*\*\*

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.  
If you have received this email in error, please notify the system manager.  
The full text of the Council's email disclaimer is available at: [www.manchester.gov.uk/emaildisclaimer](http://www.manchester.gov.uk/emaildisclaimer).  
Your personal data is very important to us. Please refer to our privacy notice at: [www.manchester.gov.uk/privacy](http://www.manchester.gov.uk/privacy) for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.

\*\*\*\*\*