



To	Head of Planning	FAO: Max Gibson
From	Head of Compliance, Enforcement and Community Safety	
Contact Officer:	Laura Miller	Our Ref: 793967
Date:	5 January 2024	Telephone: 31742

Consultation on Planning Application

Application No: 136986/FO/2023

Description: Creation of cafe (Use Class E(b)) with associated external alterations and outdoor seating area.

Location: 27 Gun Street, Manchester

I write in response to your memorandum of the 13 December 2023 regarding the above application and to inform you that I have considered the application and recommend that the following conditions are attached to any approval.

DEMOLITION/CONSTRUCTION MANAGEMENT PLAN

Prior to the commencement of development, a demolition/construction management plan outlining working practices shall be submitted to and approved in writing by the City Council as Local Planning authority, which for the avoidance of doubt shall include as a minimum:

- Measures to control noise and vibration;
- Dust suppression measures;
- Compound locations where relevant;
- Details of an emergency contact telephone number;
- A community consultation plan; and
- Sheeting of construction vehicles.

The development shall only be carried out in accordance with the approved management plan.

Reason - To safeguard the amenities of nearby residents pursuant to policies SP1, EN19 and DM1 of the Manchester Core Strategy.

**The applicant should refer to our noise from building sites [webpage](#) for further information/guidance and also [IAQM/EPUK Construction Guidance](#) on controlling emissions.*

DEMOLITION/CONSTRUCTION HOURS

Construction/demolition works shall be confined to the following hours unless otherwise agreed in writing by the City Council as local planning authority:

- Monday - Friday: 7.30am - 6pm
- Saturday: 8.30am - 2pm
- Sunday / Bank holidays: No work

Reason - To safeguard the amenities of nearby residents pursuant to policies SP1, EN19 and DM1 of the Manchester Core Strategy.

HOURS1

The premises shall not be open outside the following hours unless otherwise agreed in writing by the City Council as local planning authority:-

<i>As applied for:</i>	<i>Monday to Saturday</i>	<i>07:30 to 22:00</i>
	<i>Sunday/Bank Holiday</i>	<i>10:00 to 22:00</i>

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

HOURS2

Deliveries, servicing and collections, including waste collections shall not take place outside the following hours: 07:30 to 20:00, Monday to Saturday, no deliveries/waste collections on Sundays/Bank Holidays.

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

NSE1

a) The premises shall be acoustically insulated and treated to limit the break out of noise in accordance with a noise study of the premises and a scheme of acoustic treatment that has been submitted to and approved in writing by the City Council as local planning authority. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

Where entertainment noise is proposed the L_{Aeq} (entertainment noise) shall be controlled to 5dB below the L_{A90} (without entertainment noise) in each octave band at the facade of the nearest noise sensitive location, and internal noise levels at structurally adjoined residential properties in the 63Hz and 125Hz octave frequency bands shall be controlled so as not to exceed (in habitable rooms) 47dB and 41dB ($L_{eq,5min}$), respectively.

b) Prior to occupation of the development a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that acceptable criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To safeguard the amenities of the occupiers of the building and occupiers of nearby properties.

We have considered the submitted acoustic report (AEC, May 2023) and agree with the conclusions with regards to the proposed glazing/doors. Part a) of this condition has been complied with and we will await the post completion validation report.

NSE2

Shall only allow use of external areas within the application site in accordance with a schedule of days and hours of operation submitted to and approved in writing by the City Council as local planning authority, and shall not allow for the use of amplified sound or any music in these external areas at any time.

Reason - To safeguard the amenities of the occupiers of nearby properties.

NSE6

a) Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5dB (L_{Aeq}) below the typical background (L_{A90}) level at the nearest noise sensitive location. Prior to commencement of the use hereby approved the scheme shall be submitted to and approved in writing by the City Council as local planning authority in order to secure a reduction in the level of noise emanating from the site. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

b) Prior to the operation of the scheme a verification report shall be submitted to and approved in writing by the City Council as local planning authority to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic report. The report shall also undertake post completion testing to confirm that the noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To minimise the impact of the development and to prevent a general increase in pre-existing background noise levels around the site.

We have considered the submitted acoustic report (AEC, May 2023), limits have been proposed for the external plant. At the time of writing the specific items of plant were not known so an addendum reports needs to be submitted once the plant has been selected to satisfy part a) of the condition.

REF*

a) Before the development commences a scheme for the storage and disposal of refuse shall be submitted to and approved in writing by the City Council as local planning authority.

New developments shall have refuse storage space for segregated waste collection and recycling. Internal and external storage areas are required.

b) The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health.

The submitted waste proforma only covers general and pulpable waste (paper/card board, given the café use there is likely also be food waste and plastic/glass/tins which have not been accounted for in their waste strategy.

Information for Developers guidance documents can be downloaded using the following link:

http://www.manchester.gov.uk/info/500207/planning_and_regeneration/1962/additional_planning_guidance/3

Should you wish to discuss this matter further please contact Laura Miller.

Fiona Sharkey
Head of Compliance, Enforcement and Community Safety