

Quay Street CDN/24/0120 condition 18

Graeme Souter <graeme.souter@manchester.gov.uk>

Tue 05/03/2024 10:17

To: Michael Pearson <Michael.Pearson@manchester.gov.uk>

Hi Michael

I have reviewed the above application and it looks like the only illuminated signs for the scheme are the building identifier sign and the canopy sign on Zone 1 and the canopy sign on zone 2. Is this correct?

We will just need confirmation that the illuminated signs will be selected or controlled so not to exceed an illumination level of 300cd/m2

Kind regards

Graeme

Graeme Souter
Environmental Protection Officer
Environmental Protection
Environmental Health
The Neighbourhoods Directorate
Manchester City Council

email: graeme.souter@manchester.gov.uk

website: www.manchester.gov.uk

Tel: 0161 234 1387

Internal: 31387

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.

If you have received this email in error, please notify the sender, or dpo@manchester.gov.uk, and then permanently delete the email, attachments and all copies.

The full text of the Council's email disclaimer is available at: www.manchester.gov.uk/emaildisclaimer.

Your personal data is very important to us. Please refer to our privacy notice at: www.manchester.gov.uk/privacy for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.
