

Level 6 VRV - System A (Existing)										
REF	Description	Location	Make	Model	Duty [Nominal cooling /		Size [H x W x D] mm	Weight kg	Control	Electrical
AC/06/01A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1/ 6A
AC/06/02A	Ceiling Concealed FCU	6th - Music Room	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1/ 6A
AC/06/03A	Ceiling Concealed FCU	6th - Creative Room	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1/ 6A
AC/06/04A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1/ 6A
AC/06/05A	Ceiling Concealed FCU	6th - Meeting Room R06-03	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1/ 6A
AC/06/06A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1/ 6A
AC/06/07A	Ceiling Concealed FCU	6th - Meeting Room R06-04	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1/ 6A
AC/06/08A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1/ 6A
AC/06/09A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1/ 6A
AC/06/10A	Ceiling Concealed FCU	6th - Meeting Room R06-05	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1/ 6A
AC/06/11A	Ceiling Concealed FCU	6th - Meeting Room R06-05	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1/ 6A
AC/06/12A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ40P7VEB (Exis	4.5	5	200 x 950 x 620	26	BMS / Central Controller Temp Sensor	230v / 1/ 6A
AC/06/13A	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1/ 6A
BS/06/01A-13A	Single BS Box - (Per Unit)	6th - Open Plan Office	Daikin	BSVQ100P8V1B	-	-			-	230v / 1/ 6A
OU/06/01A	External Condenser	Roof Level	Daikin	REMQ16 / REMQ16	100		-	-	BMS / Central Controller	-

Level 6 VRV - System B (Existing)

AC/06/01B	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/02B	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/03B	Ceiling Concealed FCU	6th - Open Plan Office (Minshul St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/04B	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/05B	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/06B	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/07B	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/08B	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/09B	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
BS/06/01B-09B	Single BS Box - (Per Unit)	6th - Open Plan Office	Daikin	BSVQ100P8V1B	-	-			-	230v / 1 / 6A
OU/06/01B	External Condenser	Roof Level	Daikin	REMQ10 / REMQ16		81.5	-	-	BMS / Central Controller	-

Level 6 VRV - System C (Existing)

AC/06/01C	Ceiling Concealed FCU	6th - Coffee Shop	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/02C	Ceiling Concealed FCU	6th - Coffee Shop	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/03C	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/04C	Ceiling Concealed FCU	6th - Open Plan Office (Portland St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/05C	Ceiling Concealed FCU	6th - Meeting Room R06-06	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1 / 6A
AC/06/06C	Ceiling Concealed FCU	6th - Meeting Room R06-07	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1 / 6A
AC/06/07C	Ceiling Concealed FCU	6th - Meeting Room R06-08	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1 / 6A
AC/06/08C	Ceiling Concealed FCU	6th - Meeting Room R06-09	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1 / 6A
BS/06/01C-08C	Single BS Box - (Per Unit)	6th - Open Plan Office	Daikin	BSVQ100P8V1B	-	-			-	230v / 1 / 6A
OU/06/01C	External Condenser	Roof Level	Daikin	REMQ8 / REMQ12		62.5	-	-	BMS / Central Controller	-

Level 6 VRV - System D (Existing)

AC/06/01D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/02D	Ceiling Concealed FCU	6th - Meeting Room R06-10	Daikin	FXDQ50P7VEB (Exis	5.6	6.3	200 x 950 x 620	26	BMS / Central Controller Local Controller	230v / 1 / 6A
AC/06/03D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/04D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/05D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/06D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/07D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/08D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/09D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/10D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
AC/06/11D	Ceiling Concealed FCU	6th - Open Plan Office (Aytoun St)	Daikin	FXDQ63P7VEB (Exis	7.1	8	200 x 1150 x 620	29	BMS / Central Controller Temp Sensor	230v / 1 / 6A
BS/06/01D-11D	Single BS Box - (Per Unit)	6th - Open Plan Office	Daikin	BSVQ100P8V1B	-	-			-	230v / 1 / 6A
OU/06/01D	External Condenser	Roof Level	Daikin	REMQ8 / REMQ10 / REMQ16		103.9	-	-	BMS / Central Controller	-


NOTES:

1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL CONSTRUCTION ISSUED PROJECT INFORMATION - DRAWINGS, REPORTS AND SPECIFICATIONS.
2. ALL WORKS TO BE CARRIED OUT IN LINE WITH THE PROGRAMME.

C2	LEVEL 6 VRV - SYSTEM C AMENDED	GD	22/11/23
C1	CONSTRUCTION ISSUE	GD	30/10/23
P2	UPDATED TO SUIT LATEST ARCHITECTS LAYOUT	GD	4/9/23
P1	FIRST ISSUE	GD	7/8/23

CONSTRUCTION ISSUE

DL PROJECT No	C/23/3639
---------------	-----------





M&E BUILDING SERVICES LTD

DL M&E BUILDING SERVICES LTD

KINGS HOUSE

STOTTS PARK

JAMES STREET

WESTHOUGHTON

BOLTON, BL5 3QR

TEL : 01942 842507

E-MAIL : info@dl-bsl.co.uk



APPROVED CONTRACTOR



UKAS PRODUCT CERTIFICATION

THIS DRAWING IS THE PROPERTY OF DL M&E BUILDING SERVICES LIMITED, AND MUST NOT BE COPIED OR REPRODUCED WITHOUT THE PERMISSION IN WRITING OF DL M&E BUILDING SERVICES LIMITED.

PROJECT ADDRESS Corporate 11 Portland Street Manchester M1 3HU	SCALE A1 - N.T.S
DRAWING DESCRIPTION Mechanical Services Plant Schedule Sheet 2 of 6 Level 6 VRV Systems	DATE Aug 2023
DRAWING NUMBER 50960488-LBG-CP-XX-M2-ML-2702	DRAWN BY GD
	REVISION C2