

Emily Booth

From: Paul Mason
Sent: 03 January 2023 15:51
To: Emily Booth
Subject: 44-46 Princess Street

135667/FO/2022 | Installation of lightning protection system, generator, and ground level plant screen. | Langley Buildings 40-46 Princess Street Manchester M1 6DE

135619/LO/2022 | LISTED BUILDING CONSENT for the installation of a lightning protection system | Langley Buildings 44-46 Princess Street Manchester M1 6DE

Hi Emily,

The proposed lightning strategy is for 'an early streamer emission air terminal which requires significantly less lightning strips to be installed to the building elevations'. Can we please see drawings showing the proposed air streamer in its location rather than product info and a small drawing. Can we see a close up of the full height, dimensions and fixing details etc to make a full assessment and also can we have an idea of how many lightening strips would be needed if a 'streamer terminal' wasn't used as a couple more tapes may cause less harm than a two metre high addition to the roofline.

The proposed takes should be of a colour to match the background and need to be located in discrete areas. The positions on the elevation seem to show them in the corners of reveals which needs confirming that they will be tucking into the corners.

I'm also not clear from the drawings what has been approved for the plant screen under the previous application and what is now proposed. Can the applicants please provide an approved drawing as well as the submitted existing and proposed to enable a full comparison.

Kind regards, Paul

Paul Mason
Heritage & Urban Design Manager
Planning, Building Control & Licensing,
Growth & Development Directorate,
Manchester City Council

email: paul.mason@manchester.gov.uk
tel: 0161 234 4585

Postal address: Planning Service, Manchester City Council, PO Box 532, Town Hall Extension, Manchester, M60 2LA.

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.

If you have received this email in error, please notify the system manager.

The full text of the Council's email disclaimer is available at: www.manchester.gov.uk/emaildisclaimer.

Your personal data is very important to us. Please refer to our privacy notice at: www.manchester.gov.uk/privacy for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.
