



LEVEL 01 (Langley Building)

CEILING TYPES

NOTE:
plasterboard dryings/partitions and ceilings to be in accordance with K10

Submit test certificates, calculations and reports to demonstrate that materials/systems achieve the fire performance requirements. Note that where fire rated partitions, walls, ceilings, existing building (floors and ceilings) and any other location where fire compartmentation is required (and laboratory test data is not available) the Engineer must be provided by the Fire Engineering Consultant to assess the predicted fire performance of the proposed fire compartmentation.

These calculations and build details must satisfy the requirements of The Building Control Officer/ Approved Inspector prior to any work commencing on site.

FINAL CONSTRUCTION ISSUE DRAWING