



To	Head of Planning	FAO: Joshua Lee
From	Head of Compliance, Enforcement and Community Safety	
Contact Officer:	Sharon McAndrew	Our Ref: 792780
Date:	15 December 2023	Telephone: 31374

Consultation on Planning Application

Application No: 138367/FO/2023

Description: Installation of new shop front and installation of an extract flue to the rear

Location: 296-298 Barlow Moor Road, Manchester, M21 8HA

I write in response to your memorandum of the 28 November 2023 regarding the above application and to inform you that I have considered the application and recommend that the following conditions are attached to any approval.

Fume/odours

a) Fumes, vapours and odours shall be extracted and discharged from the premises in accordance with a scheme to be submitted to and approved in writing by the City Council as local planning authority before the use commences.

Mixed use schemes shall ensure provision for internal ducting in risers that terminate at roof level. Schemes that are outside the scope of such developments shall ensure that flues terminate at least 1m above the eave level and/or any openable windows/ventilation intakes of nearby properties.

b) Prior to commencement of the use hereby approved confirmation shall be submitted for the approval of the City Council as local planning authority that the approved scheme has been implemented.

Reason - In the interests of the amenities of occupiers of nearby properties.

**The applicant will need to consult with a suitably qualified ventilation engineer and submit a kitchen fume extract strategy report for approval. The strategy should include risk assessments for odour and noise and be based on appropriate guidance such as that published by EMAQ titled 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems' dated May 2022. Details should also be provided in relation to replacement air.*

Deliveries to commercial premises

Deliveries, servicing and collections, including waste collections shall not take place outside the following hours: 07:30 to 20:00, Monday to Saturday, no deliveries/waste collections on Sundays/Bank Holidays.

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

Noise - Ground Floor Restaurant and Offices

a) The premises shall be acoustically insulated and treated to limit the break out of noise in accordance with a noise study of the premises and a scheme of acoustic treatment that has been submitted to and approved in writing by the City Council as local planning authority. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

Where entertainment noise is proposed the L_{Aeq} (entertainment noise) shall be controlled to 5dB below the L_{A90} (without entertainment noise) in each octave band at the facade of the nearest noise sensitive location, and internal noise levels at structurally adjoined residential properties in the 63HZ and 125Hz octave frequency bands shall be controlled so as not to exceed (in habitable rooms) 47dB and 41dB ($L_{eq,5min}$), respectively.

b) Prior to occupation of the development a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that acceptable criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To safeguard the amenities of the occupiers of the building and occupiers of nearby properties.

Noise - Residential sound insulation AND overheating

a) Before the development commences a scheme for acoustically insulating the proposed residential accommodation against noise from Barlow Moor Road and Mauldeth Road West shall be submitted to and approved in writing by the City Council as local planning authority. There may be other actual or potential sources of noise which require

consideration on or near the site, including any local commercial/industrial premises such as the businesses on the lower floors of the development.

The potential for overheating shall also be assessed and the noise insulation scheme shall take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the dwelling units are occupied.

Noise survey data shall include measurements taken during a rush-hour period and night time to determine the appropriate sound insulation measures necessary. The following noise criteria shall be required to be achieved when providing adequate ventilation as defined by Approved Document F of the Building Regulations (whole dwelling ventilation):

Bedrooms (night time - 23.00 - 07.00)	30 dB L_{Aeq} (individual noise events shall not exceed 45 dB $L_{Amax,F}$ by more than 15 times)
Living Rooms (daytime - 07.00 - 23.00)	35 dB L_{Aeq}
Gardens and terraces (daytime)	55 dB L_{Aeq}

Higher internal noise levels than those specified above may be allowed when higher rates of ventilation are required in relation to the overheating condition.

Due to the proximity of the development to the tram line it shall be necessary for vibration criteria to apply which can be found in BS 6472: 2008 "*Guide to evaluation of human exposure to vibration in buildings*". Groundborne noise/re-radiated noise shall also be factored into the assessment and design.

Additionally, where entertainment noise is a factor in the noise climate the sound insulation scheme shall be designed to achieve internal noise levels in the 63Hz and 125Hz octave centre frequency bands so as not to exceed (in habitable rooms) 47dB and 41dB ($L_{eq,5min}$), respectively.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise criteria.

Reason: To secure a reduction in noise from traffic or other sources in order to protect future residents from noise disturbance and to reduce the potential for overheating.

Noise - External plant/equipment/servicing

a) Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5dB (L_{Aeq}) below the typical background (L_{A90}) level at the nearest noise sensitive location. Prior to commencement of the use hereby approved the scheme shall be submitted to and approved in writing by the City Council as local planning authority in

order to secure a reduction in the level of noise emanating from the site. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

b) Prior to the operation of the scheme a verification report shall be submitted to and approved in writing by the City Council as local planning authority to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic report. The report shall also undertake post completion testing to confirm that the noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To minimise the impact of the development and to prevent a general increase in pre-existing background noise levels around the site.

Waste – Commercial and Residential

a) Before the development commences a scheme for the storage and disposal of refuse shall be submitted to and approved in writing by the City Council as local planning authority.

New developments shall have refuse storage space for segregated waste collection and recycling. Internal and external storage areas are required.

b) The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health.

Air quality

a) Prior to commencement of the development, a scheme for a clean air intake shall be submitted to and approved in writing by the City Council as local planning authority.

b) Prior to occupation of the development any agreed mitigation measures shall be implemented and verified as such in writing by the City Council as local planning authority and shall remain in situ whilst the use or development is in operation.

Reason: To secure a reduction in air pollution from traffic or other sources in order to protect existing and future residents from air pollution, pursuant to policies EN16, SP1 and DM1 of the Core Strategy.

Information for Developers guidance documents can be downloaded using the following link:

http://www.manchester.gov.uk/info/500207/planning_and_regeneration/1962/additional_planning_guidance/3

Should you wish to discuss this matter further please contact Sharon McAndrew on extension 31374.

Fiona Sharkey

Head of Compliance, Enforcement and Community Safety