



Planning

Steven McCoombe
Telephone: 0161 234 4607
steven.mccoombe@manchester.gov.uk

P O Box 532 Town Hall
Manchester M60 2LA

Mr Darren Pomfret
Manchester Building Design Ltd
8 Gas Street
Hollingworth
Hyde
SK14 8JD

Date: 28 November 2023

Dear Sir or Madam,

Class G, Part 3, Schedule 2 of the Town & Country Planning (General Permitted Development) (England) Order 2015 (as amended)

Application No.: 138252/P3GPA/2023

Description: Prior Approval for the conversion of the first and second floors to form 2 x 2 bedroom flats (Class C3) above ground floor retail unit

Location: 3 Bury New Road, Manchester, M8 8FW

1) The City Council is satisfied that the development would have no material, harmful impact as a result of contamination, flooding or noise, and satisfactory arrangements have been made with regard to the management of domestic waste and the provision of natural light to all habitable rooms. The proposal therefore complies with the requirements of policies SP1, EN14, EN18, EN19 and DM1 of the Manchester Core Strategy and saved policy DC26 of the Unitary Development Plan for the City of Manchester, pursuant to Schedule 2, Part 3, Class G of the Town and Country Planning (General Permitted Development) Order 2015 (as amended). Approval is hereby granted in accordance with drawings referenced 55/23-01/A and 55/23/03/A, received by the City Council as Local Planning Authority on 5 October 2023.

2) The development hereby approved shall only be implemented in accordance with the waste management details shown on drawings referenced 55/23-01/A and 55/23/03/A and accompanying waste management pro forma, received by the City Council as Local Planning Authority on 5 October 2023.

Reason - In the interests of amenity and public health, pursuant to policies DM1 and SP1 of the Manchester Core Strategy.

3) a) Notwithstanding details submitted, prior to the flats hereby approved being occupied, a scheme for acoustically insulating the proposed residential accommodation against noise from Bury New Road and surrounding commercial uses, shall be submitted to and approved in writing by the City Council as Local planning authority. The potential for overheating shall also be assessed and the noise insulation scheme should take this into

account. The approved noise insulation and ventilation scheme shall be completed before any of the approved flats are occupied.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise criteria.

Reason - In order to safeguard the amenity of existing and future occupiers of nearby residential accommodation, pursuant to saved policy DC26 of the Unitary Development Plan for the City of Manchester and policies SP1, H1 and DM1 of the Core Strategy.

Informatives

Building Regulations 2010

Please note that this document does not grant any permission under Building Regulations. If you require further information regarding compliance with Building Regulations, please contact Building Control on 0161 234 4490 or by email to building.control@manchester.gov.uk.

Street Naming & Numbering Requirements

Manchester City Council is responsible for allocating street naming and numbering within Manchester for new developments or property conversions. Individuals or businesses are not permitted to allocate their own property numbers, building or street names.

If your development includes the creation of new dwellings (either new build or conversion of existing buildings), creation of new commercial properties or the subdivision of existing properties you must ensure that you request new or changes to addresses through us so they can be officially allocated and registered in accordance with the Public Health Act 1925 Sections 17-19 & Greater Manchester Act 1981 Section 22.

Failure to do this may result in difficulties for the developer/occupier when requiring services such as connections to utilities, phone lines and postal services and may delay your development.

You can apply online at the following address:

http://www.manchester.gov.uk/info/100011/roads_parking_and_transport/1988/naming_and_numbering_of_houses_buildings_streets_and_roads/2

The applicant is encouraged to consider signing up for Environment Agency Flood Warnings - <https://www.gov.uk/sign-up-for-flood-warnings>

The applicant should design and construct drainage system to prevent the increased risk of flooding, to improve and protect water quality and ensure future maintenance of the surface water drainage system.

City Council records highlight an underground culverted ordinary watercourse (River Irwell Tributary) is located within close proximity to the site (approximately 30m south of the site). Whilst the Council's records are frequently updated to ensure the highest level of accuracy, the records cannot guarantee 100% accuracy for all City Council underground assets. Therefore, it is requested that the applicant informs the onsite contractor to remain observant and to take the appropriate safety precautions during any excavation works. If

any major unknown drainage assets are found beneath the site, then further investigation works should take place to identify the asset and the City Council should be contacted immediately.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Julie Roscoe', with a stylized, cursive script.

Julie Roscoe
Director of Planning, Building Control & Licensing