



Technical Submittal External Lighting

Project: New Cross – Bendix St
Project No: MC1161
TSM No: D480-AME-XX-XX-TS-E-005
Revision: 1
Date: 11th December 2021


The following is our proposal for the external lighting on the project. This technical submittal is to be read in conjunction with Ameen Drawing D480-AME-ZZ-00-DR-E-6301 Level 00 lighting

Manufacturer – LDL Lighting

Ameen Limited Unit 9-10 Olympic Court
Boardmans Way
Whitehills Business Park
Blackpool
FY4 5GU

Tel: 01253 760160
Fax: 01253 760150
Email: enquiries@ameon.co.uk





Overview

In ground drive over uplight.
Stainless steel bezel.
IK10
On board PSU

200mm x 235mm
CRI 80+

Options

- 4000K
- 3000K
- 30°
- 45°
- 60°
- Asymetric

Part No.	Lm	W
TAL/10/1000	1000	10
TAL/15/1500	1500	15
TAL/19/2000	2000	20

More outputs available, see www.LDL.lighting

Key Features

- IP67 suitable for external/wet environments
- Impact rating of IK10
- Efficacy of up to 100lm/W
- Nominal life-time of 50,000 h
- Colour stability with 3 step MacAdam