Planning

Janine Renshaw-Livesey
Telephone: 0161 234 4555
janine.renshaw-livesey@manchester.gov.uk

P O Box 532 Town Hall
Manchester M60 2LA

Mr Paul McMullen
Paul McMullen
54 Wyresdale Road
Liverpool
L9 0JS

Date: 31 January 2024

Dear Sir or Madam,

Application No.: 138800/P3MA/2023
Description: Prior Approval for change of use of ground and first floor from offices (Class E - Commercial, Business and Service) to a C3 Dwellinghouse
Location: Rear Of 115 Beech Road, Manchester, M21 9EQ

The City Council is satisfied that this development has minimal impact on the local highway network and transport, that there are no known contamination or flood risks at the site, that the proposal would not lead to an inadequate level of retail facilities in the area and that the proposed external alterations are acceptable. The proposal therefore complies with the requirements of policies SP1, EN18, EN19, T2 and DM1 of the Manchester Core Strategy and the requirements of Schedule 2, Part 3, Class M of the Town and Country Planning (General Permitted Development) Order 2015 (as amended). Approval is hereby granted in accordance with drawing titled, ' Proposed Floor Plans and Elevations 2023-01- 03 Rev A, received electronically on the 30 January 2024 and The Site and Location Plan, stamped as received 11 December 2023.

1) Notwithstanding details submitted, the dwelling house hereby approved shall not be occupied until scheme for the storage (including segregated waste recycling) and disposal of refuse has been submitted to and approved in writing by the City Council as Local Planning Authority. The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health, pursuant to saved policy DC5 of the Unitary Development Plan for the City of Manchester and policies DM1 and SP1 of the Manchester Core Strategy.

2) a) Before the development commences a scheme for acoustically insulating the proposed residential accommodation against noise from the Beech Road shall be submitted to and approved in writing by the City Council as local planning authority. There may be other actual or potential sources of noise which require consideration on or near the site, including any local commercial/industrial premises.
The potential for overheating shall also be assessed and the noise insulation scheme shall take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the dwelling units are occupied.

Noise survey data shall include measurements taken during a rush-hour period and night time to determine the appropriate sound insulation measures necessary. The following noise criteria shall be required to be achieved:

Bedrooms (night time - 23.00 - 07.00) 30 dB LAeq (individual noise events shall not exceed 45 dB LAmax,F by more than 15 times)
Living Rooms (daytime - 07.00 - 23.00) 35 dB LAeq Gardens and terraces (daytime) 55 dB LAeq

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise criteria.

Reason - To protect the amenity of the occupants of the premises once the development hereby approved is occupied, pursuant to policies SP1, H1 and DM1 of the Core Strategy.
3) No part of the development shall be occupied until space and facilities for bicycle parking have been provided in accordance with details to be submitted to and approved in writing by the City Council as local planning authority. The approved space and facilities shall then be retained and permanently reserved for bicycle parking.

Reason - To ensure that adequate provision is made for bicycle parking so that persons occupying or visiting the development have a range of options in relation to mode of transport in order to comply with policies SP1, T1 and DM1 of the Core Strategy.

Informatives

Building Regulations 2010

Please note that this document does not grant any permission under Building Regulations. If you require further information regarding compliance with Building Regulations, please contact Building Control on 0161 234 4490 or by email to building.control@manchester.gov.uk.

Street Naming & Numbering Requirements

Manchester City Council is responsible for allocating street naming and numbering within Manchester for new developments or property conversions. Individuals or businesses are not permitted to allocate their own property numbers, building or street names.

If your development includes the creation of new dwellings (either new build or conversion of existing buildings), creation of new commercial properties or the subdivision of existing properties you must ensure that you request new or changes to addresses through us so they can be officially allocated and registered in accordance with the Public Health Act 1925 Sections 17-19 & Greater Manchester Act 1981 Section 22.

Failure to do this may result in difficulties for the developer/occupier when requiring services such as connections to utilities, phone lines and postal services and may delay your development.

You can apply online at the following address:
http://www.manchester.gov.uk/info/100011/roads_parking_and_transport/1988/naming_and_numbering_of_houses_buildings_streets_and_roads/2

Yours faithfully,

Julie Roscoe
Director of Planning, Building Control & Licensing