

Plan ref: 138103

Lisa Jones <lisa.jones3@manchester.gov.uk>

Tue 10/10/2023 16:05

To: Katie Raw <Katie.Raw@manchester.gov.uk>

Hi Katie,

Please can the following be attached to the above:

GAS01 New applications for extensions

Prior to the commencement of development appropriate and comprehensive construction designs for the installation of a proprietary gas membrane, in order to alleviate any possibility of landfill gas ingress to the building, shall be submitted for approval to the City Council, as Local Planning Authority. The approved details shall then be implemented as part of the development.

Reason - the development site lies within 250 metres of a registered landfill site or in close proximity to a potential historical source of landfill gas pursuant to policy EN18 of the Manchester Core Strategy (2012).

CLAND* (Watching brief condition)

In the event that ground contamination, groundwater contamination and/or ground gas are encountered on the site at any time before the development is occupied during the watching brief, then development shall cease and/or the development shall not be occupied until a report detailing what measures, if any, are required to remediate the land (the Remediation Strategy), is submitted to and approved in writing by the City Council as local planning authority and the development shall be carried out in accordance with the agreed Remediation Strategy and validated. If no contamination is found, then a post-completion report shall be submitted to evidence this prior to occupation of the development.

Reason – To ensure that the presence of or the potential for any contaminated land and/or groundwater is detected and appropriate remedial action is taken in the interests of public safety. Pursuant to [INSERT] of the Unitary Development Plan for the City of Manchester.

**Our records indicate that the proposal site is on or in the vicinity of an infilled pond/potentially contaminative historic land uses.*

Kind regards

Lisa Jones
Environmental Protection Officer
Environmental Protection
Environmental Health
The Neighbourhoods Directorate
Manchester City Council

email: lisa.jones3@manchester.gov.uk

website: www.manchester.gov.uk

Tel: 0161 234 5004

Internal: 31372

We are now on Twitter, for latest news and updates follow us [@EnvHealthMcr](#)

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the system manager.
The full text of the Council's email disclaimer is available at: www.manchester.gov.uk/emaildisclaimer.
Your personal data is very important to us. Please refer to our privacy notice at: www.manchester.gov.uk/privacy for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.
