



e3p

Noise Impact Assessment

Greenfinch Public House, Manchester

Reference: 51-024-R1-2

Date: December 2023



NOISE IMPACT ASSESSMENT

Greenfinch Public House,
Manchester

Prepared for:

Churchill Retirement Living

Report Ref: 51-024-R1-2

Date Issued: 1st December 2023

E3P

Taylor Road
Trafford Park
Urmston
Manchester
M41 7JQ

+ 44 (0) 161 707 9612
<https://e3p.co.uk>

Registered in England
CRN: 807255262

QUALITY ASSURANCE

PROJECT NUMBER	51-024		
VERSION	Version 1	Version 2	
REMARKS	Draft for Comment	Draft for Comment	
DATE	24th October 2023	1st December 2023	
PREPARED BY	Scott Boughton	Scott Boughton	
QUALIFICATIONS	BEng (Hons) MIOA	BEng (Hons) MIOA	
POSITION	Senior Consultant	Senior Consultant	
CHECKED BY	L Faulkner	L Faulkner	
QUALIFICATIONS	BSc (Hons) MEnvSci MIOA	BSc (Hons) MEnvSci MIOA	
POSITION	Associate Director	Associate Director	
AUTHORISED BY	L Faulkner	L Faulkner	
QUALIFICATIONS	BSc (Hons) MEnvSci MIOA	BSc (Hons) MEnvSci MIOA	
POSITION	Associate Director	Associate Director	

EXECUTIVE SUMMARY

BACKGROUND

Site Address	Former Greenfinch Public House, Manchester, M20 3ZA
National Grid Reference	E 384311 N 392073
Proposed Development	Proposed development of retirement living apartment dwellings with associated access, parking and landscaping.
Report Objectives	<p>The objectives of this report are to:</p> <ul style="list-style-type: none">Identify, measure and assess the potential impact of any existing noise sources in the immediate vicinity of the Site upon proposed residential receptors.Identify and assess the potential impact of any proposed noise sources associated with the proposed development upon existing and proposed residential receptors. <p>The report follows current and relevant British Standards in order to provide a robust assessment.</p>

ASSESSMENT

Surveys Completed	Two unattended 24-hour road traffic sound measurements have been undertaken for Lapwing Lane and Palatine Road during a typical weekday period in accordance with Calculation of Road Traffic Noise. The measurement location for Lapwing Road also captured sound levels from the tram line.
Assessments	<p>A 3D noise model has been constructed to assess road and tram traffic sound across the site and incident upon facades.</p> <p>Road and tram traffic sound impact is assessed in accordance with the criterion, for day and night, given in BS 8233:2014+A1:2019.</p>
Mitigation Requirements	<p>The assessment has shown standard thermal double glazing will be sufficient across the development. It is assumed that a whole dwelling ventilation system will be installed as standard in accordance with the guidance within Approved Document F. The opening of windows has been found to be an acceptable method of mitigating overheating.</p> <p>Limits have been set on any proposed fixed plant items to protect the proposed and existing noise sensitive receptors.</p>

CONCLUSIONS

With mitigation measures in place, this assessment has shown that no adverse impact is predicted day or night at the receptors due to road and tram traffic sound.

As such, noise need not be a material consideration in the granting of planning permission if the recommendations of this report are followed and included within the design stage.



TABLE OF CONTENTS

EXECUTIVE SUMMARY	2
Background	2
Assessment.....	2
Conclusions.....	2
1. INTRODUCTION	4
1.1. Background	4
1.2. Proposed Development.....	4
1.3. Limitations	4
2. ASSESSMENT METHODOLOGY	5
2.1. National Planning Policy Framework	5
2.2. National Planning Practice Guidance.....	5
2.3. Manchester City Council – Planning & Noise (May 2022)	7
2.4. Building Regulations: Approved Document F - Volume 1: Dwellings (June 2022)	8
2.5. Building Regulations: Approved Document O – Overheating (June 2022).....	9
2.6. British Standard BS 8233:2014+A1:2019 – Guidance on Sound Insulation and Noise Reduction for Buildings.....	9
2.6.1. Noise Criteria Limits	9
2.7. World Health Organisation (WHO) – Guidelines for Community Noise	10
3. SURVEY RESULTS.....	11
3.1. Road Traffic Sound Measurement – Lapwing Lane.....	11
3.2. Road Traffic Sound Measurement – Palatine Road.....	12
4. NOISE IMPACT ASSESSMENT	14
4.1. External Amenity Area Noise Level Assessment.....	14
4.2. Internal Noise Level Assessment	15
4.2.1. Ventilation Condition	15
4.2.2. Overheating Condition	15
4.3. Proposed Fixed Plant	16
5. CONCLUSION AND RECOMMENDATIONS.....	17
APPENDIX I GLOSSARY OF ACOUSTIC TERMINOLOGY	18
APPENDIX II FIGURES	21



1. INTRODUCTION

1.1. BACKGROUND

E3P were commissioned by Churchill Retirement Living to undertake a Noise Impact Assessment for a proposed retirement living development at the former Greenfinch Public house, Manchester, to be referred to hereafter as '*the Site*'.

This assessment looks to determine the key noise sources in the immediate vicinity of the Site and to assess their impact, if any, upon proposed residential receptors and to specify mitigation measures, where required.

1.2. PROPOSED DEVELOPMENT

The client intends to construct retirement living apartments along with associated parking, access, landscaping, and associated works on vacant land adjacent to Lapwing Lane and Palatine Road.

The key source of sound impacting upon the Site is road traffic associated with Lapwing Lane and Palatine Road.

This assessment has been undertaken in accordance with the following supplied drawings:

-  Proposed Site Plan – Drawing number 50013DB/PL02 dated December 2023.

1.3. LIMITATIONS

Where a noise or vibration survey is required to inform an assessment, E3P will endeavour to ensure that all noise and vibration measurements taken are robust, representative and reliable in order to inform an accurate assessment.

Where mitigation measures are specified in this report, it should be noted that these measures are relative to a specific sound or vibration source, both in terms of the measured sound pressure and vibration level and the character of the sound source. Where either the sound pressure level or the character of the sound varies following completion of the sound survey, E3P cannot be held responsible for any subsequent variations in the proposed mitigation performance.



2. ASSESSMENT METHODOLOGY

2.1. NATIONAL PLANNING POLICY FRAMEWORK

To prevent unacceptable risks from pollution, planning policies and decisions should ensure that new development is appropriate for its location. The effects (including cumulative effects) of pollution on health, the natural environment or general amenity, and the potential sensitivity of the area or proposed development to adverse effects from pollution, should be considered.

The national planning policy framework states that planning policies and decisions should aim to:

- ✿ Avoid noise from giving rise to significant adverse impacts on health and quality of life as a result of new development.
- ✿ Mitigate and reduce to a minimum, other adverse impacts on health and quality of life arising from noise from new development, including through the use of conditions.
- ✿ Recognise that development will often create some noise and existing businesses wanting to develop in continuance of their business should not have unreasonable restrictions put on them because of changes in nearby land uses since they were established.
- ✿ Identify and protect areas of tranquillity which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.

2.2. NATIONAL PLANNING PRACTICE GUIDANCE

Noise needs to be considered when new developments may create additional noise and when new developments would be sensitive to the prevailing acoustic environment. When preparing local or neighbourhood plans, or taking decisions about new development, there may also be opportunities to consider improvements to the acoustic environment.

Local planning authorities' plan-making and decision-making should take account of the acoustic environment and in doing so consider:

- ✿ Whether or not a significant adverse effect is occurring or is likely to occur.
- ✿ Whether or not an adverse effect is occurring or is likely to occur.
- ✿ Whether or not a good standard of amenity can be achieved.

In line with the explanatory note of the NPSE, this would include identifying whether the overall effect of the noise exposure (including the impact during the construction phase, where applicable) is, or would be, above or below the significant observed adverse effect level and the lowest observed adverse effect level for the given situation.



The “observed effect levels” are as follows:

-  **Significant observed adverse effect level:** This is the level of noise exposure above which significant adverse effects on health and quality of life occur.
-  **Lowest observed adverse effect level:** This is the level of noise exposure above which adverse effects on health and quality of life can be detected.
-  **No observed effect level:** This is the level of noise exposure below which no effect at all on health or quality of life can be detected.

Table 2.1 summarises the noise exposure hierarchy, based on the likely average response.

TABLE 2.1 NOISE EXPOSURE HIERARCHY

PERCEPTION	EXAMPLES OF OUTCOMES	INCREASING EFFECT LEVEL	ACTION
Not Noticeable	No effect.	No observed effect	No specific measures required
Noticeable and Not Intrusive	Noise can be heard but does not cause any change in behaviour or attitude. Can slightly affect the acoustic character of the area but not such that there is a perceived change in the quality of life.	No observed adverse effect	No specific measures required
Lowest Observed Adverse Effect Level			
Noticeable and Intrusive	Noise can be heard and causes small changes in behaviour and/or attitude, e.g. turning up volume of television, speaking more loudly, or having to close windows for some of the time because of the noise where there is no alternative ventilation. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life.	Observed adverse effect	Mitigate and reduce to a minimum
Significant Observed Adverse Effect Level			
Noticeable and Disruptive	The noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion, having to keep windows closed most of the time because of the noise where there is no alternative ventilation. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area.	Significant observed effect	Avoid
Noticeable and Very Disruptive	Extensive and regular changes in behaviour and/or an inability to mitigate effect of noise leading to psychological stress or physiological effects, e.g. regular sleep deprivation/awakening, loss of appetite, significant/medically definable harm (auditory and non-auditory).	Unacceptable adverse effect	Prevent



The subjective nature of noise means that there is not a simple relationship between noise levels and the impact on those affected. This will depend on how various factors combine in any situation. These factors include the following:

- ✿ The source and absolute level of the noise together with the time of day it occurs. Some types and level of noise will cause a greater adverse effect at night than if they occurred during the day. The adverse effect can also be greater simply because there is less background noise at night.
- ✿ For non-continuous sources of noise, the number of noise events, and the frequency and pattern of occurrence of the noise can be important.
- ✿ The spectral content of the noise and the general character of the noise. The local topology and topography should also be considered along with the existing and, where appropriate, the planned character of the area.

More specific factors to consider when relevant:

- ✿ Where applicable, the cumulative impacts of more than one source should be considered along with the extent to which the source of noise is intermittent and of limited duration.
- ✿ Consideration should also be given to whether adverse internal effects can be completely removed by closing windows and, in the case of new residential development, if the proposed mitigation relies on windows being kept closed most of the time. In both cases, a suitable alternative means of ventilation is likely to be necessary.
- ✿ If external amenity spaces are an intrinsic part of the overall design, then the acoustic environment of those spaces should be considered so that they can be enjoyed as intended.

2.3. MANCHESTER CITY COUNCIL – PLANNING & NOISE (MAY 2022)

Manchester City Council have produced a guidance note in relation to the assessment of planning and noise.

3.7.7.1 Residential Developments

The Council has adopted the following noise limits for residential properties:

- *Bedrooms (night-time - 23.00 - 07.00) 30 dB L_{Aeq} (individual noise events should not normally exceed 45 dB $L_{Amax,F}$ by more than 10 times)*
- *Living Rooms (daytime - 07.00 - 23.00) 35 dB L_{Aeq}*
- *Gardens and terraces (daytime) 55 dB L_{Aeq}*

These criteria have been adopted for the following reasons:

- *BS 8233: 2014 recognises these levels as a good standard for resting/sleeping conditions.*
- *The WHO document 'Guidelines for Community Noise' recommends an internal L_{Aeq} of 30dB for optimal sleep conditions (and no more than 35dB for internal rooms during daytime).*
- *The performance of acoustic insulation schemes can often be below that specified, according to the quality of installation, materials, noise spectrum and deterioration / wear and tear of building elements. A high design specification introduces a 'safety margin' should building elements not perform as well as expected ('on-site')*



performance).

- Performance specification for glazing does not usually take into account the detrimental effect of vents on the sound insulation. Even 'acoustic' vents will reduce the performance of the facade insulation, as they will inherently contain a free open area for air exchange.
- There is a general increase in urban noise levels, which can in the future be reasonably accommodated by these standards.
- The standards support the Local Authority corporate objective to prevent ill-health and improve local peoples' health and well being.

2.4. BUILDING REGULATIONS: APPROVED DOCUMENT F - VOLUME 1: DWELLINGS (JUNE 2022)

Approved document F Volume 1: Dwellings (ADF) provides guidance set by the Department for Levelling Up, Housing and Communities, that relates to means of ventilation within dwellings. The ventilation strategy specified within the ADF are as follows.

1.9 The ventilation strategy in this approved document relies on a combination of all of the following.

a. Extract ventilation from rooms where water vapour or pollutants are likely to be released (e.g. bathrooms and kitchens), to minimise their spread to the rest of the building. Ventilation fans may be either intermittent operation or continuous operation.

b. Whole dwelling ventilation to provide fresh air to the building and to dilute, disperse and remove water vapour and pollutants not removed by extract ventilation.

c. Purge ventilation to remove high concentrations of pollutants and water vapour. Purge ventilation is used intermittently and required only for pollutants produced by occasional activities (e.g. fumes from painting).

1.10 Ventilation may be delivered through natural ventilation, mechanical ventilation or a combination of both.

1.11 The ventilation systems in this approved document are examples of systems that comply with Part F of the Building Regulations. Other ventilation systems may be acceptable if they can be shown to meet an equal level of performance.

Within the ADF there are three system specific ventilation systems that can be utilised to provide sufficient ventilation. These methods are as follow.

1. **Natural ventilation with background ventilators and intermittent extract fans** (guidance suitable only for less airtight dwellings) - Ventilation provided by thermal, wind or diffusion effects through doors, windows or other intentional openings without the use of mechanically driven equipment. For the purposes of this approved document, natural ventilation refers to a ventilation strategy using background ventilators and intermittent extract ventilation.
2. **Continuous mechanical extract ventilation** - Mechanically driven ventilation that continuously extracts indoor air and discharges it to the outside.



3. **Mechanical ventilation with heat recovery** - A mechanically driven ventilation system that both continuously supplies outdoor air to the inside of the dwelling and continuously extracts indoor air and discharges it to the outside. For the purposes of this approved document, the guidance for mechanical ventilation with heat recovery applies to centralised or decentralised supply and extract systems, with or without heat recovery.

2.5. BUILDING REGULATIONS: APPROVED DOCUMENT O – OVERHEATING (JUNE 2022)

Approved document O - Overheating (ADO) provides guidance set by the Department for Levelling Up, Housing and Communities, that relates to the mitigation of overheating. In relation to noise the ADO provides the following guidance.

3.2 In locations where external noise may be an issue (for example, where the local planning authority considered external noise to be an issue at the planning stage), the overheating mitigation strategy should take account of the likelihood that windows will be closed during sleeping hours (11pm to 7am).

3.3 Windows are likely to be closed during sleeping hours if noise within bedrooms exceeds the following limits.

- a. 40dB $L_{Aeq,T}$, averaged over 8 hours (between 11pm and 7am).
- b. 55dB L_{AFmax} , more than 10 times a night (between 11pm and 7am).

3.4 Where in-situ noise measurements are used as evidence that these limits are not exceeded, measurements should be taken in accordance with the Association of Noise Consultants'

Measurement of Sound Levels in Buildings with the overheating mitigation strategy in use.

NOTE: Guidance on reducing the passage of external noise into buildings can be found in the National Model Design Code: Part 2 – Guidance Notes (MHCLG, 2021) and the Association of Noise Consultants' Acoustics, Ventilation and Overheating: Residential Design Guide (2020)

2.6. BRITISH STANDARD BS 8233:2014+A1:2019 – GUIDANCE ON SOUND INSULATION AND NOISE REDUCTION FOR BUILDINGS

2.6.1. NOISE CRITERIA LIMITS

The scope of this standard is the provision of recommendations for the control of noise in and around buildings including residential dwellings. It suggests appropriate criteria and limits for different situations, which are primarily intended to guide the design of new buildings or refurbished buildings undergoing a change of use, rather than to assess the effect of changes in the external noise climate.

The standard suggests suitable internal noise levels within different types of buildings, including residential dwellings, as shown in Table 2.2.



TABLE 2.2 BS 8233:2014 RECOMMENDED INTERNAL NOISE LEVELS

CRITERION	TYPICAL SITUATION	DESIGN CRITERION, $L_{Aeq,T}$ (dB)
Suitable Resting and Sleeping Conditions	Living Room	35
	Bedroom	30

BS 8233 goes on to recommend noise levels for gardens:

It is desirable that the external noise level does not exceed 50 dB $L_{Aeq,T}$, with an upper guideline value of 55 dB $L_{Aeq,T}$ which would be acceptable in noisier environments. However, it is also recognised that these guideline values are not achievable in all circumstances where development might be desirable. In higher noise areas, such as city centres or urban areas adjoining the strategic transport network, a compromise between elevated noise levels and other factors might be warranted.

BS 8233 goes on to say:

In such a situation, development should be designed to achieve the lowest practicable levels in these external amenity spaces but should not be prohibited.

2.7. WORLD HEALTH ORGANISATION (WHO) – GUIDELINES FOR COMMUNITY NOISE

The WHO gives guidance on desirable levels of environmental noise. The levels presented in the WHO Community Guidelines are those at which adverse effects become measurable. The 1980 WHO document suggested that “general daytime outdoor noise levels of less than 55 dB(A) $L_{eq,16hr}$ are desirable to prevent any significant community annoyance.” This level is an external free-field noise level. The 1980 document also stated in relation to internal levels, “that night-time noise levels of 35 dB(A) $L_{eq,8hr}$ or less will not interfere with the restorative process of sleep”.

A report was submitted to the WHO in 1995 for consideration as a revision to the 1980 document and revised community guidelines were issued in 2000. In the 2000 guidelines, it is considered that the sleep disturbance criteria should be taken as an internal noise level of 30 dB $L_{Aeq,8 hr}$ or an external level of 45 dB $L_{Aeq,8 hr}$. It also recommends that internal L_{Amax} levels of 45 dB and external L_{Amax} levels of 60 dB should be limited where possible.



3. SURVEY RESULTS

3.1. ROAD TRAFFIC SOUND MEASUREMENT – LAPWING LANE

E3P have undertaken a road traffic sound survey in accordance with the methodology given in given in Calculation of Road Traffic Noise (CRTN) during a typical weekday period. The survey was undertaken during the following period:

📅 11:00 Monday 16th October to 11:00 Tuesday 17th October 2023.

The following noise measurement position was chosen for the Road Traffic Noise Survey:

📍 Noise Measurement Position 1 (NMP1): Located near the northern boundary of the site approximately 15 m from the roadside edge. The microphone was under free-field conditions. Sound sources consisted of road traffic along the Lapwing Land and occasional tram pass-bys.

Table 3.1 details the measured sound pressure levels.

TABLE 3.1 MEASURED ROAD TRAFFIC SOUND LEVELS – LAPWING

MEASUREMENT START TIME	MEASURED SOUND PRESSURE LEVELS (dB)			
	$L_{Aeq,T}$	10th Highest $L_{Amax,fast}$	$L_{A90,T}$	$L_{A10,T}$
11:00	55.1	N/A	49.0	58.0
12:00	55.5		48.9	58.2
13:00	54.6		48.2	57.3
14:00	57.4		48.8	60.8
15:00	56.5		49.1	59.2
16:00	55.4		49.5	58.2
17:00	57.1		49.5	58.9
18:00	55.9		49.4	58.3
19:00	56.4		48.6	57.5
20:00	54.3		47.7	56.7
21:00	53.6		46.3	55.7
22:00	54.8		44.7	55.5
23:00	49.5	64.9	41.7	53.0
00:00	47.7		38.4	51.0
01:00	45.1		35.5	49.4
02:00	43.3		36.5	47.0
03:00	42.9		36.8	46.2
04:00	44.3		37.2	48.4
05:00	49.2		39.1	52.8



MEASUREMENT START TIME	MEASURED SOUND PRESSURE LEVELS (dB)			
	L _{Aeq,T}	10th Highest L _{Amax,fast}	L _{A90,T}	L _{A10,T}
06:00	54.7	N/A	46.0	56.3
07:00	56.5		51.2	58.8
08:00	57.4		51.9	59.6
09:00	58.1		50.6	61.3
10:00	58.7		49.6	60.0
Derived Daytime Noise Level, L _{Aeq,16hr}				56.3
Derived Night-time Noise Level, L _{Aeq,8hr}				48.9

3.2. ROAD TRAFFIC SOUND MEASUREMENT – PALATINE ROAD

E3P have undertaken a road traffic sound survey in accordance with the methodology given in given in CRTN during a typical weekday period. The survey was undertaken during the following period:

📍 11:00 Monday 16th October to 11:00 Tuesday 17th October 2023.

The following noise measurement position was chosen for the Road Traffic Noise Survey:

📍 Noise Measurement Position 2 (NMP2): Located near the eastern boundary of the site approximately 7 m from the roadside edge. The microphone was under free-field conditions. Sound sources consisted of road traffic along Palatine Road.

Table 3.2 details the measured sound pressure levels.

TABLE 3.2 MEASURED ROAD TRAFFIC SOUND LEVELS – PALATINE ROAD

MEASUREMENT START TIME	MEASURED SOUND PRESSURE LEVELS (dB)			
	$L_{Aeq,T}$	10th Highest $L_{Amax,fast}$	$L_{A90,T}$	$L_{A10,T}$
11:00	55.1	N/A	49.0	58.0
12:00	55.5		48.9	58.2
13:00	54.6		48.2	57.3
14:00	57.4		48.8	60.8
15:00	56.5		49.1	59.2
16:00	55.4		49.5	58.2
17:00	57.1		49.5	58.9
18:00	55.9		49.4	58.3
19:00	56.4		48.6	57.5
20:00	54.3		47.7	56.7



MEASUREMENT START TIME	MEASURED SOUND PRESSURE LEVELS (dB)				
	L _{Aeq,T}	10th Highest L _{Amax,fast}	L _{A90,T}	L _{A10,T}	
21:00	53.6		46.3	55.7	
22:00	54.8		44.7	55.5	
23:00	49.5		63.6	41.7	53.0
00:00	47.7			38.4	51.0
01:00	45.1	35.5		49.4	
02:00	43.3	36.5		47.0	
03:00	42.9	36.8		46.2	
04:00	44.3	37.2		48.4	
05:00	49.2	39.1		52.8	
06:00	54.7	N/A		46.0	56.3
07:00	56.5		51.2	58.8	
08:00	57.4		51.9	59.6	
09:00	58.1		50.6	61.3	
10:00	58.7		49.6	60.0	
Derived Daytime Noise Level, L _{Aeq,16hr}				56.3	
Derived Night-time Noise Level, L _{Aeq,8hr}				48.9	

During the survey, conditions remained dry and wind speeds rarely exceeded 5 m/s. The equipment outlined in Table 3.3 was used for the noise survey.

TABLE 3.3 NOISE MEASUREMENT EQUIPMENT AND CALIBRATION DATES

MEASUREMENT POSITION	EQUIPMENT DESCRIPTION	MANUFACTURER & TYPE NUMBER	SERIAL NUMBER	CALIBRATION DUE DATE
NMP1	Sound Level Meter	01dB Fusion	12039	30/07/2025
	Pre-amplifier	01dB Pre22	1805124	
	Microphone	GRAS 40CE	330832	
	Calibrator	01dB Cal31	87281	26/01/2024
NMP2	Sound Level Meter	01dB Fusion	14616	29/06/2024
	Pre-amplifier	01dB Pre22	20951	
	Microphone	GRAS 40CD	494264	
	Calibrator	Cirrus CR 515	99206	03/08/2024

The sound level meters were field calibrated on site using the above-mentioned calibrators prior to and after noise measurements were taken. No significant drift was witnessed as noted above. Calibration certificates are available upon request.



4. NOISE IMPACT ASSESSMENT

For the purposes of this assessment, E3P has used noise modelling software, CadnaA 2023 MR2, to determine the impact of noise from road and tram traffic sound.

The following inputs have been included in the model:

- ✳ Proposed Site Plan – Drawing number 50013DB/PL02 dated December 2023.
- ✳ Lapwing Lane and Palatine Road are calibrated using NMP1 and NMP2 respectively. Tram sound is included for within the measurement location NMP1.
- ✳ Site elevations have been taken as existing by way of a 2 m grid Digital Terrain Model (DTM) which contains public sector information licensed under the Open Government License v3.0.
- ✳ Existing buildings are included.
- ✳ A reflection order of 2 has been used in all calculations. All ground has been assumed to be acoustically hard.
- ✳ Noise levels generated using ISO 9613-1 and ISO 9613-2 "Acoustics – Attenuation of sound during propagation outdoors" as incorporated into CadnaA software.

Figures 2 and 3 determine the noise levels across the Site during the daytime and night-time periods, respectively, due to road traffic.

4.1. EXTERNAL AMENITY AREA NOISE LEVEL ASSESSMENT

The noise model has been used to predict noise levels in potential amenity areas to be used for relaxation. The predicted levels range between 42 dB and up to 59 dB. E3P notes that there are exceedances of the 55 dB for external amenity areas closest to Palatine Road. However, E3P is aware that Manchester City Council have previously raised concerns regarding visual impact of barriers along this boundary. As such E3P have provided an explanation for the justification of noise levels above the upper guideline value of 55 dB. BS 8233 states the following:

For traditional external areas that are used for amenity space, such as gardens and patios, it is desirable that the external noise level does not exceed 50 dB $L_{Aeq,T}$ with an upper guideline value of 55 dB $L_{Aeq,T}$ which would be acceptable in noisier environments. However, it is also recognized that these guideline values are not achievable in all circumstances where development might be desirable. In higher noise areas, such as city centres or urban areas adjoining the strategic transport network, a compromise between elevated noise levels and other factors, such as the convenience of living in these locations or making efficient use of land resources to ensure development needs can be met, might be warranted. In such a situation, development should be designed to achieve the lowest practicable levels in these external amenity spaces, but should not be prohibited

In such environments as described above it is often accepted that levels of 58 dB within external amenity areas is acceptable. As shown in Figure 2 levels only reach 59 dB at the very edge of the amenity areas closest to Palatine Road, with large areas being below 58 dB. Accordingly, no mitigation measures are required.



4.2. INTERNAL NOISE LEVEL ASSESSMENT

With regards to internal noise levels, E3P has assumed a standard glazing specification of 4 mm glass/20 mm air space/4 mm glass affords sound insulation performance in the order of 29 dB however this is for a pink noise spectrum. The same unit, weighted for road traffic noise using the '+C_{tr}' correction, has a sound insulation performance value of approximately 25 dB and so this value has been used to calculate internal noise levels. The recently published AVO guide recommends that a partially open window provides approximately 13 dB attenuation.

The model has been used to predict façade noise levels at all floors. In order to determine any requirements for mitigation, E3P has added the reduction provided by the glazing (25 dB) to the relevant criterion for day (35 dB) and for night (30 dB). As such, any facades subject to noise levels higher than 60 dB during the day and/or 55 dB during the night will require higher specification glazing.

As can be seen in Figures 2 and 3, no facades exceed the above criterion in the daytime or night-time period. As such, standard thermal double glazing will be sufficient across the site.

Consideration must also be given to maximum noise levels generated by road traffic on Lapwing Lane and Palatine Road. The 10th highest maximum noise level from Lapwing Lane and Palatine Road when distance corrected to the closest façade would be 56 dB and 58 dB respectively.

Internal maximum noise levels of 45 dB L_{Amax} should also not be exceeded. The sound insulation performance achieved by standard glazing (29 dB) has been added to the 45 dB maximum internal noise level limit. As, such, facades subject to maximum noise levels above 74 dB will require higher specification glazing.

As shown above, no facades are subject to levels higher than 74 dB L_{Amax} . Therefore, standard glazing would be sufficient across the site to mitigate against maximum noise levels generated by road traffic from Lapwing Lane and Palatine Road.

With regards opening windows, there is a requirement to consider the need to open windows for ventilation and the mitigation of overheating. At this stage, the assessment assumes that ventilation would be provided by way of extract fans in kitchens and bathrooms and open windows.

4.2.1. VENTILATION CONDITION

It is assumed that the developer would be installing a whole dwelling ventilation system in accordance with Part F of the Building Regulations as it is assumed Natural Ventilation is not appropriate for these dwellings.

Where background ventilators form part of the system, consideration is required to the sound reduction provided by these when in the open position. Where trickle vents are incorporated within the design of the whole dwelling ventilation system they should achieve the sound insulation of at least that of the glazing unit.

4.2.2. OVERHEATING CONDITION

E3P has considered the potential impact of noise, internally, should windows be opened to mitigate overheating, as per the criteria stipulated in ADO. Any plots/facades that pass this test can open windows for this without resulting in unacceptable internal noise levels. Those that fail the test would be subject to a Part O Overheating Assessment by a suitably qualified consultant.



Part O only applies to bedrooms at night in relation to the average 8-hour noise level and 10th highest maximum noise level.

Given that the site is within a moderate risk location, as per guidance within Approved Document O the external noise limit threshold is 49 dB during the night-time ($L_{Aeq,8hr}$) and 64 dB more than 10 times a night ($L_{A10,max}$).

As can be seen from the figures, no facades experience an exceedance of the above criterion. As such, the opening of windows is an acceptable method of mitigation against overheating.

4.3. PROPOSED FIXED PLANT

It is understood that as part of the development, fixed plant items may be present. At the time of submission, details of the plant are unknown and, as such, it is appropriate to set limits on the noise levels for the plant. Given that the location of the plant is unknown nor are the background sound levels known when the building is in place, it is considered prudent to set limits based on the NR30 curve, as above.

As such, any fixed plant items installed as part of the development, should not exceed the below criterion when measured or predicted outside the closest habitable room window. A correction of 13 dB is applied to all frequencies to allow for the attenuation achieved by the open window.

TABLE 4.1 PROPOSED PLANT LIMITS

FREQUENCY (Hz)	31.5	63	125	250	500	1k	2k	4k	8k
NR30 (dB)	76	59	48	40	34	30	27	25	23
Open Window (dB)	13	13	13	13	13	13	13	13	13
Allowable external noise level due to proposed fixed plant	89	72	61	53	47	43	40	38	36

Where octave band data is not available, as a minimum, the rating level from the plant should be no more than 43 dB at the closest habitable room window so as to achieve 30 dB internally with an open window.



5. CONCLUSION AND RECOMMENDATIONS

E3P were commissioned by Churchill Retirement Living to undertake a Noise Impact Assessment for a proposed residential development at former Greenfinch Public House, Manchester.

Unattended road traffic sound measurements over a 24-hour period have been undertaken for both Lapwing Lane and Palatine Road during a typical weekday period in accordance with calculation of road traffic noise.

No other notable sources of sound impact upon the site.

A 3D noise model has been constructed to assess noise levels across the site due to road traffic sound. The predicted external and internal noise levels have been compared to the criteria given in BS 8233:2014. Consideration has been given to external amenity space and internal habitable rooms.

The assessment has shown that standard thermal double glazing will be sufficient across the development. It is assumed that a whole dwelling ventilation system will be installed as standard in accordance with the guidance within approved document F. The opening of windows has been found to be an acceptable method of mitigating overheating for all façades.

Limits have been set on any proposed fixed plant items to protect the proposed and existing noise sensitive receptors.

The assessment has shown that, with mitigation measures in place, no adverse impact is expected due to existing sound sources. As such, noise need not be a material consideration in the granting of planning permission.

END OF REPORT



APPENDIX I

GLOSSARY OF ACOUSTIC TERMINOLOGY

NOISE

Noise is defined as unwanted sound. Human ears are able to respond to sound in the frequency range 20 Hz (deep bass) to 20,000 Hz (high treble) and over the audible range of 0 dB (the threshold of perception) to 140 dB (the threshold of pain). The ear does not respond equally to different frequencies of the same magnitude but is more responsive to mid-frequencies than to lower or higher frequencies. To quantify noise in a manner that approximates the response of the human ear, a weighting mechanism is used. This reduces the importance of lower and higher frequencies, in a similar manner to the human ear.

Furthermore, the perception of noise may be determined by a number of other factors, which may not necessarily be acoustic. In general, the impact of noise depends upon its level, the margin by which it exceeds the background level, its character and its variation over a given period of time. In some cases, the time of day and other acoustic features such as tonality or impulsiveness may be important, as may the disposition of the affected individual. Any assessment of noise should give due consideration to all of these factors when assessing the significance of a noise source. The most widely used weighting mechanism that best corresponds to the response of the human ear is the "A"-weighting scale. This is widely used for environmental noise measurement, and the levels are denoted as dB(A) or L_{Aeq} , L_{A90} etc., according to the parameter being measured.

The decibel scale is logarithmic rather than linear, and hence a 3 dB increase in sound level represents a doubling of the sound energy present. Judgement of sound is subjective but, as a general guide, a 10 dB(A) increase can be taken to represent a doubling of loudness, whilst an increase in the order of 3 dB(A) is generally regarded as the minimum difference needed to perceive a change under normal listening conditions. An indication of the range of sound levels commonly found in the environment is given in the following table.

TABLE A1 TYPICAL SOUND PRESSURE LEVELS

SOUND PRESSURE LEVEL	LOCATION/EXAMPLE
0	Threshold of hearing
20–30	Quiet bedroom at night
30–40	Living room during the day
40–50	Typical office
50–60	Inside a car
60–70	Typical high street
70–90	Inside a factory
100–110	Burglar alarm at 1 m away
110–130	Jet aircraft on take off
140	Threshold of pain



ACOUSTIC TERMINOLOGY

TABLE A2 TERMINOLOGY

DESCRIPTOR	EXPLANATION
dB (decibel)	The scale on which sound pressure level is expressed. It is defined as 20 times the logarithm of the ratio between the root-mean-square pressure of the sound field and a reference pressure (2E-05 Pa).
dB(A)	A-weighted decibel. This is a measure of the overall level of sound across the audible spectrum with a frequency weighting (i.e. "A" weighting) to compensate for the varying sensitivity of the human ear to sound at different frequencies.
L_{Aeq, T}	L _{Aeq} is defined as the notional steady sound level which, over a stated period of time (T), would contain the same amount of acoustical energy as the A-weighted fluctuating sound measured over that period.
L_{Amax}	L _{Amax} is the maximum A-weighted sound pressure level recorded over the period stated. L _{Amax} is sometimes used in assessing environmental noise where occasional loud noises occur, which may have little effect on the overall L _{eq} noise level but will still affect the noise environment. Unless described otherwise, it is measured using the "fast" sound level meter response.
L₁₀ and L₉₀	If a non-steady noise is to be described, it is necessary to know both its level and the degree of fluctuation. The L _n indices are used for this purpose, and the term refers to the level exceeded for n% of the time. Hence L ₁₀ is the level exceeded for 10% of the time and as such can be regarded as the "average maximum level". Similarly, L ₉₀ is the "average minimum level" and is often used to describe the background noise. It is common practice to use the L ₁₀ index to describe traffic noise.
Free-field Level	A sound field determined at a point away from reflective surfaces other than the ground with no significant contributions due to sound from other reflective surfaces. Generally, as measured outside and away from buildings.
Fast	A time weighting used in the root-mean-square section of a sound level meter with a 125-millisecond time constant.
Slow	A time weighting used in the root-mean-square section of a sound level meter with a 1000-millisecond time constant.



APPENDIX II

FIGURES


Figure 1 - Noise Measurement Positions



Project:
Former Greenfinch
Public House,
Manchester

Project-No:
51-024

Client:
Churchill Retirement Living





Project Engineer: Scott Boughton
Date: 24/10/2023

Figure 2 - Daytime Grid Noise Map - Calculation at 1.5 m above ground level



Project:
 Former Greenfinch
 Public House,
 Manchester

Project-No:
 51-024

Client:
 Churchill Retirement Living

**Daytime Noise Level,
 LAeq, 16hr (dB)**

...	<= 48
48 < ...	<= 50
50 < ...	<= 52
52 < ...	<= 56
56 < ...	<= 58
58 < ...	<= 60
60 < ...	<= 62
62 < ...	<= 65
65 < ...	

Noise Map Objects

	Road
	Railway
	Building
	Barrier
	Bridge
	Receiver
	Building Evaluation
	Calculation Area

Project Engineer: Scott Boughton
 Date: 24/10/2023

Figure 3 - Night-time Grid Noise Map - Calculation at 4.5 m above ground level



Project:
Former Greenfinch
Public House,
Manchester

Project-No:
51-024

Client:
Churchill Retirement Living

**Night-time Noise Level,
LAeq, 8hr (dB)**

...	<= 42
42 < ...	<= 45
45 < ...	<= 47
47 < ...	<= 50
50 < ...	<= 52
52 < ...	<= 55
55 < ...	<= 57
57 < ...	<= 60
60 < ...	

Noise Map Objects

- Road
- Railway
- Building
- Barrier
- Bridge
- Receiver
- Building Evaluation
- Calculation Area

e3p

Project Engineer: Scott Boughton
Date: 24/10/2023