LIGHTING LEGEND

A L.1	LED DOWNLIGHT ONLY, 4091m, 3000K OR EQUAL AND APPROVED.	
B	LED DOWNLIGHT, WHITECROFT LDR 650lms, 4000K OR EQUAL AND APPROVED.	
C	SURFACE MOUNTED IP44 LED, WHITECROFT ACLN 4200lm, 4000K OR EQUAL AND APPROVED.	
L	RECESSED IP2X LED, 1190lm, 4000K. IP4X above showers.	
F	SUFACE FLOOD LIGHT, IP54 LED, xxxlm, 3000K OR EQUAL AND APPROVED.	
G	SURFACE LED READING LIGHT, 4000K OR EQUAL AND APPROVED.	
H	SURFACE LED IP44 BATHROOM LIGHT, 4000K OR EQUAL AND APPROVED.	
M	SURFACE LED IP2X UNDERCUPBOARD STRIP LIGHT, 4000K OR EQUAL AND APPROVED.	
R	SURFACE IP44 LED, WHITCROFT SPECTRE WR ?????lm, 4000K OR EQUAL AND APPROVED.	
N	SUSPENDED DECORATIVE LED LUMINAIRE OR EQUAL AND APPROVED.	
Q		
P	SUSPENDED DECORATIVE LUMINAIRE OR EQUAL AND APPROVED.	
	RECESSED DECORATIVE LED LUMINAIRE / DRIVER OR EQUAL AND APPROVED.	

NOTE

All luminaires to have a minimum lumen / circuit watt of 75.

Local 3m radius PIR to restrict operation

RING OR SIMILAR (WIRED)

DBP1/11

DBP2/9

DBP2/12

DBP3/11

DBP3/12

DBP4/11

DBP4/12

Wall mounted at high level

Wall mounted luminaire to clients requirements, conduit besa box for mounting of luminaire.

Lighting in stairs to be 2-way and intermediate switched.

RING OR SIMILAR

1a

6

SAFETY HEALTH AND ENVIRONMENTAL INFORMATION BOX

Construction Risks

- Enter text here / Delete text where necessary
- Enter text here / Delete text where necessary

Maintenance/Cleaning Risks

- Enter text here / Delete text where necessary
- Enter text here / Delete text where necessary

Demolition/Adaption Risks

- Enter text here / Delete text where necessary
- Enter text here / Delete text where necessary

In addition to the hazards / risks normally associated with the type of work detailed on this drawing - the contractor is to take note of the above & also the hazards identified in the risk assessment document. It is assumed that all works detailed on this drawing will be performed by a competent contractor working, where appropriate, to an approved method statement.

Rev	Date	Description	By	Check	App
P4	30/10/23	Incorporating Architect's comments	JL	RW	SD
P3	10/10/23	Lighting amended to ecologists requirements			
P2	09/10/23	Incorporating Architects Comments	JL	RW	SD
P1	15/09/23	Revision 4	JL	RW	SD

COPYRIGHT. THE COPYRIGHT OF THIS DRAWING IS VESTED IN CLANCY CONSULTING.
IT SHALL NOT BE USED WITHOUT PERMISSION BY ANYONE FOR ANY PURPOSE.
DO NOT SCALE THIS DRAWING ELECTRONICALLY OR MANUALLY.
WORK TO FIGURED DIMENSIONS ONLY.
ALL DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.
THIS DRAWING WAS PRODUCED USING REVIT . IT IS NOT TO BE EXPORTED AND USED IN AUTOCAD . ANY EXPORTED AUTOCAD DRAWINGS PRODUCED FROM THIS SHEET ARE TO BE USED FOR INFORMATION PURPOSES ONLY.

Clancy Project No. 7-8545

Client: VICTOR (M1) Limited

Project: PARADISE MEWS, MANCHESTER

Office: READING

Discipline: ELECTRICAL

Title: Ground floor Lighting Services Layout

Scale @ A1	Status
1:50	Preliminary

clancy consulting
www.clancy.co.uk

Birmingham 0121 200 7800 Leeds 0113 426 3434 Glasgow 0141 222 7720 Liverpool 0151 227 5300 London 020 3077 0970 Manchester 0161 613 6000 Newcastle 0191 221 0702 Norwich 01603 305190 Portsmouth 01329 475375 Reading 0118 947 7888

Project No.	Originator	Zone/Volume	Level
7-8545	CCL	XX	00
Type	**Discipline**	**Drawing No.**	**Revision**
DR	E	6301	P4