

CASSETTE SCHEDULE		
REF.	CAPACITY (kW)	PRODUCT NAME
VRF/A	4.5	DVM 360 CASSETTE
VRF/B	5.6	DVM 360 CASSETTE
VRF/C	7.1	DVM 360 CASSETTE
VRF/D	9.0	DVM 360 CASSETTE

CASSETTE UNIT MOUNTING HEIGHT IN DOUBLE HEIGHT SPACE
MAXIMUM 4000mm AFFL.

GENERAL NOTES

- 1.0 THE DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION & ALL OTHER RELEVANT DOCUMENTS & DRAWINGS PROVIDED BY MEP DESIGN.
- 2.0 THE DRAWING INDICATES THE DESIGN INTENT FOR THE WORKS.
- 3.0 COORDINATION WORKING DRAWINGS, INSTALLATION DRAWINGS & BUILDERS WORK DRAWINGS SHALL BE PREPARED BY THE CONTRACTOR.
- 4.0 DIMENSIONS SHALL NOT BE SCALED FROM THE DRAWING & THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL DIMENSIONS & LEVELS ON SITE FOR THE ACTUAL SETTING OUT OF THE WORKS.

GENERAL LEGEND

- L/L ITEM MOUNTED AT LOW LEVEL.
H/L ITEM MOUNTED AT HIGH LEVEL.
C/V ITEM MOUNTED IN CEILING VOID.
R/V ITEM MOUNTED IN ROOF VOID.
F/V ITEM MOUNTED IN FLOOR VOID.
W/T ITEM MOUNTED AT WORKTOP LEVEL.
WP DENOTES WEATHERPROOF IP65 TYPE SUITABLE FOR EXTERNAL USE.
EX DENOTES EXISTING TO BE RETAINED.
R DENOTES EXISTING TO BE RELOCATED.
R.T.A. RISE TO ABOVE.
R.F.B. RISE FROM BELOW.
D.F.A. DROP FROM ABOVE.
D.T.B. DROP TO BELOW.

LEGEND

- AREA IS TO BE HEATED BY RADIANT PANELS.
AREA IS TO BE UNHEATED.
HEATING DESIGN IS IN ABEYANCE.

- VRF CASSETTE UNIT.
WALL MOUNTED CONTROLLER.
NOTE - FOR THE DOUBLE HEIGHT SPACES THE CONTROLLERS ARE ALREADY SHOWN ON THE GROUND FLOOR DRAWING.

PO2	CLIENTS COMMENTS INCORPORATED	SEP 23
PO1	ISSUED FOR COMMENT	SEP 23
Revision	Description	Date


**MEP
DESIGN**
10 The Hitcock, Harwood, Bolton, BL2 3HP
www.mepdesign.co.uk

Client
ALLIED LONDON

Project
UPPER & LOWER CAMPFIELD - DESIGN

Title
MECHANICAL SERVICES
UPPER CAMPFIELD
MEZZANINE LEVEL
HEATING & COOLING

Scale	1:100 @A1	Drawn	W.H.
Project No.	Zone	Originator	Checklist
22_023 - UC - MEP	- GS23 - PL - M1 - 001 - PO2		



UPPER CAMPFIELD MEZZANINE PLAN