

					VSC (WINDOW)					NSL					APSH (ROOM)								
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX		PR.		LOSS %		MEETS		
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA		
LONDON ROAD FIRE STATION																							
F01	R11	HOTEL	BEDROOM	W24/F01	21.7	18.4	3.3	15.2%	YES	92.9	86.7	1.4	6.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W25/F01	22.1	18.3	3.8	17.2%	YES														
			BEDROOM	W26/F01	24.4	20.3	4.1	16.8%	YES														
	R12	HOTEL	BEDROOM	W27/F01	26.5	21.4	5.1	19.2%	YES	96.1	87.9	1.5	8.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W28/F01	27.2	21.6	5.6	20.6%	NO														
F02	R13	HOTEL	BEDROOM	W29/F01	27.8	22.1	5.7	20.5%	NO	97.1	96.1	0.2	10%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W30/F01	28.3	22.6	5.7	20.1%	NO														
			BEDROOM	W23/F02	27.2	23.3	3.9	14.3%	YES	96	80.5	2.8	16.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	R11	HOTEL	BEDROOM	W24/F02	27.9	23.4	4.5	16.1%	YES														
			BEDROOM	W25/F02	28.2	23.4	4.8	17.0%	YES	92.5	82.2	1.8	11.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
F03	R12	HOTEL	BEDROOM	W26/F02	28.6	23.4	5.2	18.2%	YES														
			BEDROOM	W27/F02	29.5	23.5	6	20.3%	NO	95.3	86.2	1.9	9.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W28/F02	30.2	23.8	6.4	21.2%	NO														
	R13	HOTEL	BEDROOM	W29/F02	31	24.3	6.7	21.6%	NO	97.1	96.8	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W30/F02	31.5	24.6	6.9	21.9%	NO														
F04	R10	HOTEL	BEDROOM	W33/F03	30.2	25.1	5.1	16.9%	YES	98.4	83.5	2.7	15.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W34/F03	30.9	25.2	5.7	18.4%	YES														
			BEDROOM	W35/F03	31.2	25.2	6	19.2%	YES	96.9	90	1.2	7.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	R11	HOTEL	BEDROOM	W36/F03	31.4	25.1	6.3	20.1%	NO														
			BEDROOM	W37/F03	29.9	22.7	7.2	24.1%	NO	79.6	67.6	2.5	15.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
F05	R12	HOTEL	BEDROOM	W38/F03	31	23.3	7.7	24.8%	NO	83.4	66.9	2.3	19.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	FAIRFIELD HOUSE																						
	F00	R1	RESIDENTIAL	UNKNOWN	W1/F00	10.9	9	1.9	17.4%	YES	64.1	63.1	0.8	16%	YES	41	6	29	0	29.3%	100.0%	NO	
UNKNOWN				W2/F00	11.5	9.6	1.9	16.5%	YES														
UNKNOWN				W3/F00	12.7	10.7	2	15.7%	YES														
UNKNOWN				W4/F00	13.4	11.4	2	14.9%	YES														
UNKNOWN				W16/F00	17.4	17.4	0	0.0%	YES														
UNKNOWN				W17/F00	17.4	17.4	0	0.0%	YES														
UNKNOWN		W18/F00	16.9	16.9	0	0.0%	YES																
R2 (3)	RESIDENTIAL	UNKNOWN	W5/F00	12.7	6.9	5.8	45.7%	NO	52.9	21.7	8.3	59.0%	NO	30	12	0	0	100.0%	100.0%	NO			
FAIRFIELD HOUSE (CONTINUED)																							
F01	R3	RESIDENTIAL	UNKNOWN	W6/F00	13.5	6.2	7.3	54.1%	NO														
			UNKNOWN	W7/F00	16.3	7.7	8.6	52.8%	NO	96.6	70.6	3.8	27.0%	NO	70	15	20	1	71.4%	93.3%	NO		

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX.		PR.		LOSS %		MEETS CRITERIA
					%	%	%	%		%	%	SQM	%		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
			UNKNOWN	W8/F00	26.8	41	22.7	84.7%	NO												
			UNKNOWN	W9/F00	26.8	5	21.8	81.3%	NO												
	R4	RESIDENTIAL	UNKNOWN	W10/F00	26.7	7.2	19.5	73.0%	NO	84.9	56.8	4.7	33.1%	NO	69	15	31	3	55.1%	80.0%	NO
			UNKNOWN	W11/F00	26.5	9.4	17.1	64.5%	NO												
	R5	RESIDENTIAL	UNKNOWN	W12/F00	26.6	13.9	12.7	47.7%	NO	80	80	0.0	0.0%	YES	71	15	41	6	42.3%	60.0%	YES
			UNKNOWN	W13/F00	26.4	13.8	12.6	47.7%	NO												
			UNKNOWN	W14/F00	18.6	18.6	0	0.0%	YES												
			UNKNOWN	W15/F00	17.1	17.1	0	0.0%	YES												
F01	R1	RESIDENTIAL	UNKNOWN	W1/F01	12.6	10.4	2.2	17.5%	YES	63	62.8	0.1	0.4%	YES	36	7	24	1	33.3%	85.7%	NO
			UNKNOWN	W2/F01	13.2	11	2.2	16.7%	YES												
			UNKNOWN	W20/F01	20	20	0	0.0%	YES												
			UNKNOWN	W21/F01	19.9	19.9	0	0.0%	YES												
			UNKNOWN	W22/F01	19.1	19.1	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F01	14.6	12.3	2.3	15.8%	YES	43.5	42.1	0.1	3.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F01	15.5	13.1	2.4	15.5%	YES	43.8	41.9	0.1	4.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F01	16	13.2	2.8	17.5%	YES	31	29	0.2	6.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W6/F01	16.5	12.9	3.6	21.8%	NO	46.4	40	0.5	13.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F01	16.4	12.4	4	24.4%	NO	45.8	42.1	0.2	8.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F01	16	11.3	4.7	29.4%	NO	47.7	41	0.5	14.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F01	14.9	9.7	5.2	34.9%	NO	41.6	35.9	0.4	13.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F01	14.1	8	6.1	43.3%	NO	34.8	24.6	0.7	29.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W11/F01	15	7.2	7.8	52.0%	NO	50.9	21.3	2.2	58.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F01	17.8	8.5	9.3	52.2%	NO	90.3	68.5	3.4	24.2%	NO	77	20	24	2	68.8%	90.0%	NO
			UNKNOWN	W13/F01	30.4	4.5	25.9	85.2%	NO												
			UNKNOWN	W14/F01	30.4	5.5	24.9	81.9%	NO												
	R12	RESIDENTIAL	BEDROOM	W15/F01	30.3	8.1	22.2	73.3%	NO	95.4	23.3	7.6	75.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F01	30.2	10.6	19.6	64.9%	NO	93.9	29.7	6.7	68.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F01	30	15.5	14.5	48.3%	NO	92.4	87.6	1.0	5.2%	YES	76	20	43	8	43.4%	60.0%	YES
			UNKNOWN	W18/F01	29.5	15.7	13.8	46.8%	NO												
FAIRFIELD HOUSE (CONTINUED)																					
			UNKNOWN	W19/F01	22.5	22.5	0	0.0%	YES												
F02	R1	RESIDENTIAL	UNKNOWN	W1/F02	14.9	12.3	2.6	17.4%	YES	71.8	71.4	0.1	0.5%	YES	38	8	25	1	34.2%	87.5%	NO
			UNKNOWN	W2/F02	15.7	13.1	2.6	16.6%	YES												
			UNKNOWN	W20/F02	22.6	22.6	0	0.0%	YES												
			UNKNOWN	W21/F02	22.7	22.7	0	0.0%	YES												

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
			UNKNOWN	W22/F02	21.7	21.7	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F02	17.1	14.4	2.7	15.8%	YES	60.1	57	0.2	5.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F02	18	15.4	2.6	14.4%	YES	59.7	57.1	0.2	4.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F02	18.6	15.5	3.1	16.7%	YES	42.9	40.9	0.2	4.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W6/F02	18.9	15.2	3.7	19.6%	YES	61.6	55.7	0.4	9.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F02	18.7	14.5	4.2	22.5%	NO	63.8	60.3	0.2	5.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F02	17.9	13	4.9	27.4%	NO	58.1	51.2	0.5	12.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F02	16.7	11.2	5.5	32.9%	NO	53.3	47.4	0.4	11.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F02	15.9	9.5	6.4	40.3%	NO	40.5	30.4	0.7	24.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W11/F02	16.7	8.5	8.2	49.1%	NO	58.3	29.9	2.1	48.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F02	19.4	9.6	9.8	50.5%	NO	90.9	71.7	3.0	21.2%	NO	78	21	24	2	69.2%	90.5%	NO
			UNKNOWN	W13/F02	32.8	4.8	28	85.4%	NO												
			UNKNOWN	W14/F02	33	6	27	81.8%	NO												
	R12	RESIDENTIAL	BEDROOM	W15/F02	33.1	9	24.1	72.8%	NO	97.1	23.5	7.7	75.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F02	33	11.8	21.2	64.2%	NO	96.1	30.2	6.9	68.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F02	32.6	17.2	15.4	47.2%	NO	95.9	93.6	0.5	2.4%	YES	79	21	44	8	44.3%	61.9%	YES
			UNKNOWN	W18/F02	32.2	17.6	14.6	45.3%	NO												
			UNKNOWN	W19/F02	27.3	27.3	0	0.0%	YES												
F03	R1	RESIDENTIAL	UNKNOWN	W1/F03	17.9	14.9	3	16.8%	YES	83.8	82.7	0.4	1.2%	YES	41	10	28	2	31.7%	80.0%	NO
			UNKNOWN	W2/F03	18.8	15.6	3.2	17.0%	YES												
			UNKNOWN	W20/F03	25.7	25.7	0	0.0%	YES												
			UNKNOWN	W21/F03	25.7	25.7	0	0.0%	YES												
			UNKNOWN	W22/F03	24.1	24.1	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F03	20.1	16.9	3.2	15.9%	YES	75.2	68.7	0.4	8.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F03	21.1	17.9	3.2	15.2%	YES	75.4	71.7	0.3	4.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F03	21.6	18.3	3.3	15.3%	YES	56.4	54.4	0.2	3.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
FAIRFIELD HOUSE (CONTINUED)																					
	R5	RESIDENTIAL	BEDROOM	W6/F03	21.8	17.8	4	18.3%	YES	75.5	69.8	0.4	7.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F03	21.2	16.8	4.4	20.8%	NO	80.8	77.5	0.2	4.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F03	20.1	15	5.1	25.4%	NO	67.5	60.9	0.4	9.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F03	18.8	13.1	5.7	30.3%	NO	60.7	55.3	0.4	8.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F03	17.9	11.3	6.6	36.9%	NO	43.4	33.5	0.7	22.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W11/F03	18.5	10.2	8.3	44.9%	NO	61.9	34.7	2.0	44.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F03	21	11.1	9.9	47.1%	NO	91.3	73.1	2.9	19.9%	YES	80	22	25	3	68.8%	86.4%	NO
			UNKNOWN	W13/F03	33.6	5.1	28.5	84.8%	NO												

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
			UNKNOWN	W14/F03	33.8	6.3	27.5	81.4%	NO												
	R12	RESIDENTIAL	BEDROOM	W15/F03	34	9.4	24.6	72.4%	NO	97.4	23.6	7.7	75.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F03	34.1	12.5	21.6	63.3%	NO	97	30.3	7.0	68.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F03	34.2	18.5	15.7	45.9%	NO	96.2	94.2	0.4	2.1%	YES	81	22	45	9	44.4%	59.1%	YES
			UNKNOWN	W18/F03	34.2	19.3	14.9	43.6%	NO												
			UNKNOWN	W19/F03	32.1	32.1	0	0.0%	YES												
F04	R1	RESIDENTIAL	UNKNOWN	W1/F04	21.4	18.1	3.3	15.4%	YES	88.7	88.6	0.0	0.1%	YES	49	12	34	2	30.6%	83.3%	NO
			UNKNOWN	W2/F04	22.4	18.8	3.6	16.1%	YES												
			UNKNOWN	W20/F04	28.5	28.5	0	0.0%	YES												
			UNKNOWN	W21/F04	28.5	28.5	0	0.0%	YES												
			UNKNOWN	W22/F04	26.9	26.9	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F04	23.8	20	3.8	16.0%	YES	86.7	77.8	0.6	10.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F04	24.6	20.7	3.9	15.9%	YES	87.7	82.1	0.4	6.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F04	25	21.1	3.9	15.6%	YES	69.5	66.6	0.3	4.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W6/F04	24.7	20.4	4.3	17.4%	YES	80.6	74.8	0.4	7.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F04	24	19.2	4.8	20.0%	YES	85	82	0.2	3.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F04	22.7	17.3	5.4	23.8%	NO	69.5	63.3	0.4	8.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F04	21.4	15.4	6	28.0%	NO	63.1	58.5	0.3	7.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F04	20.4	13.5	6.9	33.8%	NO	45.7	36.4	0.6	20.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W11/F04	20.9	12.4	8.5	40.7%	NO	63	38.1	1.8	39.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F04	23.1	12.9	10.2	44.2%	NO	91.7	73.5	2.9	19.8%	YES	80	22	25	3	68.8%	86.4%	NO
			UNKNOWN	W13/F04	34.3	5.3	29	84.5%	NO												
			UNKNOWN	W14/F04	34.5	6.5	28	81.2%	NO												
FAIRFIELD HOUSE (CONTINUED)																					
	R12	RESIDENTIAL	BEDROOM	W15/F04	34.7	9.7	25	72.0%	NO	98	23.7	7.8	75.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F04	34.8	12.8	22	63.2%	NO	97.9	30.4	7.1	69.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F04	35	18.9	16.1	46.0%	NO	99	97.4	0.3	1.7%	YES	82	23	46	10	43.9%	56.5%	YES
			UNKNOWN	W18/F04	35	19.8	15.2	43.4%	NO												
			UNKNOWN	W19/F04	35.4	35.4	0	0.0%	YES												
F05	R1	RESIDENTIAL	UNKNOWN	W1/F05	26	22.4	3.6	13.8%	YES	95.6	95.6	0.0	0.0%	YES	52	13	38	3	26.9%	76.9%	NO
			UNKNOWN	W2/F05	26.8	23	3.8	14.2%	YES												
			UNKNOWN	W20/F05	30.8	30.8	0	0.0%	YES												
			UNKNOWN	W21/F05	30.8	30.8	0	0.0%	YES												
			UNKNOWN	W22/F05	29.7	29.7	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F05	27.8	23.6	4.2	15.1%	YES	96.2	87.2	0.6	9.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX		PR.		LOSS %		MEETS CRITERIA	
					%	%		%	CRITERIA		%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL		WINTER
	R3	RESIDENTIAL	BEDROOM	W4/F05	28.4	23.9	4.5	15.8%	YES	96.7	91.7	0.4	5.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F05	28.5	23.7	4.8	16.8%	YES	86.1	82.9	0.3	3.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W6/F05	27.9	22.8	5.1	18.3%	YES	89.7	81.1	0.6	9.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F05	26.9	21.7	5.2	19.3%	YES	91.5	88.4	0.2	3.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F05	25.6	19.8	5.8	22.7%	NO	75.5	68.2	0.5	9.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F05	24.5	18	6.5	26.5%	NO	70.4	65	0.4	7.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F05	23.6	16.2	7.4	31.4%	NO	55.5	44.6	0.7	19.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W11/F05	24	15.1	8.9	37.1%	NO	67.4	49.1	1.4	27.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F05	25.7	15.4	10.3	40.1%	NO	92.4	74.6	2.8	19.2%	YES	83	24	27	4	67.5%	83.3%	NO	
			UNKNOWN	W13/F05	34.9	5.5	29.4	84.2%	NO													
			UNKNOWN	W14/F05	35.1	6.8	28.3	80.6%	NO													
	R12	RESIDENTIAL	BEDROOM	W15/F05	35.3	10	25.3	71.7%	NO	98.1	23.7	7.8	75.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W16/F05	35.4	13.1	22.3	63.0%	NO	98.1	30.5	7.1	69.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	UNKNOWN	W17/F05	35.6	19.3	16.3	45.8%	NO	99	97.4	0.3	1.7%	YES	83	24	47	11	43.4%	54.2%	YES	
			UNKNOWN	W18/F05	35.7	20.2	15.5	43.4%	NO													
			UNKNOWN	W19/F05	36.4	36.4	0	0.0%	YES													
F06	R1	RESIDENTIAL	UNKNOWN	W1/F06	30	26.3	3.7	12.3%	YES	100	100	0.0	0.0%	YES	59	14	45	3	23.7%	78.6%	NO	
			UNKNOWN	W2/F06	30.5	26.4	4.1	13.4%	YES													
			UNKNOWN	W20/F06	32.5	32.5	0	0.0%	YES													
			UNKNOWN	W21/F06	32.5	32.5	0	0.0%	YES													
FAIRFIELD HOUSE (CONTINUED)																						
			UNKNOWN	W22/F06	32	32	0	0.0%	YES													
	R2	RESIDENTIAL	BEDROOM	W3/F06	30.8	26.3	4.5	14.6%	YES	96.3	87.7	0.6	8.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R3	RESIDENTIAL	BEDROOM	W4/F06	31	26.1	4.9	15.8%	YES	96.7	92.4	0.3	4.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F06	31	25.6	5.4	17.4%	YES	90.5	88	0.3	2.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W6/F06	30.6	24.9	5.7	18.6%	YES	96.6	85.8	0.8	11.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F06	29.9	23.9	6	20.1%	NO	97.1	94.6	0.2	2.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F06	28.8	22.4	6.4	22.2%	NO	90.5	81.3	0.6	10.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F06	28	20.9	7.1	25.4%	NO	88.5	81.8	0.5	7.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F06	27.4	19.3	8.1	29.6%	NO	86	68.3	1.2	20.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W11/F06	27.7	18.4	9.3	33.6%	NO	87	80.8	0.5	7.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F06	28.9	18.3	10.6	36.7%	NO	93.2	76.5	2.6	17.8%	YES	86	24	31	4	64.0%	83.3%	NO	
			UNKNOWN	W13/F06	35.4	5.7	29.7	83.9%	NO													
			UNKNOWN	W14/F06	35.6	6.9	28.7	80.6%	NO													
	R12	RESIDENTIAL	BEDROOM	W15/F06	35.8	10.2	25.6	71.5%	NO	98.2	23.9	7.8	75.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	VSC (WINDOW)					NSL					APSH (ROOM)						
					EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%	%	%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
	R13	RESIDENTIAL	BEDROOM	W16/F06	35.9	13.3	22.6	63.0%	NO	98.1	30.5	7.1	68.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F06	36.1	19.5	16.6	46.0%	NO	99.1	97.4	0.4	1.7%	YES	86	26	49	12	43.0%	53.8%	YES
			UNKNOWN	W18/F06	36.2	20.5	15.7	43.4%	NO												
			UNKNOWN	W19/F06	37	37	0	0.0%	YES												
F07	R1	RESIDENTIAL	UNKNOWN	W1/F07	33.3	29.4	3.9	11.7%	YES	100	100	0.0	0.0%	YES	63	17	48	5	23.8%	70.6%	YES
			UNKNOWN	W2/F07	33.2	29	4.2	12.7%	YES												
			UNKNOWN	W20/F07	33.4	33.4	0	0.0%	YES												
			UNKNOWN	W21/F07	33.5	33.5	0	0.0%	YES												
			UNKNOWN	W22/F07	34.1	34.1	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F07	33.1	28.4	4.7	14.2%	YES	96.3	89.4	0.5	7.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F07	33	27.9	5.1	15.5%	YES	96.7	93.1	0.3	3.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F07	32.9	27.3	5.6	17.0%	YES	96.2	94.1	0.2	2.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W6/F07	32.8	26.6	6.2	18.9%	YES	96.6	87.2	0.7	9.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F07	32.5	26	6.5	20.0%	YES	97.1	95	0.1	2.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F07	31.7	24.7	7	22.1%	NO	97	88.5	0.6	8.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F07	31.3	23.6	7.7	24.6%	NO	97.1	93.7	0.2	3.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F07	31.2	22.5	8.7	27.9%	NO	97.2	85.8	0.8	11.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
FAIRFIELD HOUSE (CONTINUED)																					
	R10	RESIDENTIAL	BEDROOM	W11/F07	31.6	21.9	9.7	30.7%	NO	95.9	91.8	0.3	4.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F07	32.2	21.4	10.8	33.5%	NO	95.2	85.3	1.6	10.4%	YES	92	25	36	4	60.9%	84.0%	NO
			UNKNOWN	W13/F07	35.9	5.8	30.1	83.8%	NO												
			UNKNOWN	W14/F07	36	7	29	80.6%	NO												
	R12	RESIDENTIAL	BEDROOM	W15/F07	36.2	10.3	25.9	71.5%	NO	98.1	24.1	7.8	75.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F07	36.3	13.4	22.9	63.1%	NO	98.1	30.6	7.1	68.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F07	36.5	19.6	16.9	46.3%	NO	99.2	97.4	0.4	1.8%	YES	86	26	49	12	43.0%	53.8%	YES
			UNKNOWN	W18/F07	36.6	20.6	16	43.7%	NO												
			UNKNOWN	W19/F07	37.4	37.4	0	0.0%	YES												
F08	R1	RESIDENTIAL	UNKNOWN	W1/F08	34.9	30.7	4.2	12.0%	YES	100	100	0.0	0.0%	YES	64	17	49	5	23.4%	70.6%	YES
			UNKNOWN	W12/F08	34.3	34.3	0	0.0%	YES												
			UNKNOWN	W13/F08	35	35	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W2/F08	34.7	29.6	5.1	14.7%	YES	99.2	96.8	0.5	2.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W3/F08	34.5	28.7	5.8	16.8%	YES	98.4	96.5	0.2	1.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W4/F08	34.3	27.7	6.6	19.2%	YES	99.2	95.8	0.8	3.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W5/F08	33.8	26	7.8	23.1%	NO	99.4	96.5	0.7	2.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W6/F08	33.9	24.2	9.7	28.6%	NO	99.3	95.7	0.8	3.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA		%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	
	R7	RESIDENTIAL	UNKNOWN	W7/F08	33.6	22.7	10.9	32.4%	NO	98.9	91.2	1.2	7.8%	YES	94	26	36	4	61.7%	84.6%	NO
			UNKNOWN	W8/F08	36.4	6.5	29.9	82.1%	NO												
	R8 (3)	RESIDENTIAL	UNKNOWN	W9/F08	36.7	11.9	24.8	67.6%	NO	99.5	60.4	11.7	39.3%	NO	85	26	34	6	60.0%	76.9%	YES
	R9	RESIDENTIAL	UNKNOWN	W10/F08	36.9	20.3	16.6	45.0%	NO	99.8	97.8	0.4	2.0%	YES	86	26	48	12	44.2%	53.8%	YES
			UNKNOWN	W11/F08	37.6	37.6	0	0.0%	YES												
LAMBERT HALL																					
B01	R1	RESIDENTIAL	UNKNOWN	W1/B01	9.8	4.7	5.1	52.0%	NO	44.1	6.3	7.3	85.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/B01	10.7	4.5	6.2	57.9%	NO												
	R2	RESIDENTIAL	UNKNOWN	W3/B01	13.5	6	7.5	55.6%	NO	80.1	49	7.0	38.8%	NO	70	18	15	0	78.6%	100.0%	NO
			UNKNOWN	W4/B01	15.2	7.2	8	52.6%	NO												
			UNKNOWN	W5/B01	27.5	2.3	25.2	91.6%	NO												
	R3	RESIDENTIAL	UNKNOWN	W6/B01	27.3	2.2	25.1	91.9%	NO	88.8	0	19.8	100.0%	NO	69	17	11	1	84.1%	94.1%	NO
			UNKNOWN	W7/B01	27.1	2.2	24.9	91.9%	NO												
LAMBERT HALL (CONTINUED)																					
	R4	RESIDENTIAL	UNKNOWN	W8/B01	26.2	2.7	23.5	89.7%	NO	88.6	2.6	19.2	97.0%	NO	69	19	16	3	76.8%	84.2%	NO
			UNKNOWN	W9/B01	25.9	2.9	23	88.8%	NO												
	R5	RESIDENTIAL	UNKNOWN	W10/B01	25.5	3.3	22.2	87.1%	NO	89.3	6.9	18.6	92.3%	NO	69	18	20	4	71.0%	77.8%	NO
			UNKNOWN	W11/B01	25.4	3.6	21.8	85.8%	NO												
	R6	RESIDENTIAL	UNKNOWN	W12/B01	24.9	4.3	20.6	82.7%	NO	89.3	15.6	16.6	82.5%	NO	70	20	24	6	65.7%	70.0%	NO
			UNKNOWN	W13/B01	24.6	4.9	19.7	80.1%	NO												
	R7	RESIDENTIAL	UNKNOWN	W14/B01	25	6.3	18.7	74.8%	NO	89.4	31.3	13.0	65.0%	NO	69	19	26	7	62.3%	63.2%	YES
			UNKNOWN	W15/B01	25.5	7.3	18.2	71.4%	NO												
	R8	RESIDENTIAL	UNKNOWN	W16/B01	26.3	9.7	16.6	63.1%	NO	89.3	51.9	8.7	41.9%	NO	69	21	36	13	47.8%	38.1%	YES
			UNKNOWN	W17/B01	26.6	11.5	15.1	56.8%	NO												
F00	R1	RESIDENTIAL	UNKNOWN	W1/F00	10.9	5.5	5.4	49.5%	NO	48.5	13.9	7.5	71.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/F00	11.8	5.3	6.5	55.1%	NO												
	R2	RESIDENTIAL	UNKNOWN	W3/F00	14.8	6.9	7.9	53.4%	NO	78.4	60.7	2.3	22.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W4/F00	17.1	8.3	8.8	51.5%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F00	29.1	2.4	26.7	91.8%	NO	96.1	2.8	6.8	97.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F00	28.7	2.4	26.3	91.6%	NO	93.8	2.3	6.7	97.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F00	28.3	2.3	26	91.9%	NO	96.5	2.4	6.9	97.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F00	26.8	2.8	24	89.6%	NO	88.3	4.3	6.1	95.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F00	26.5	3.1	23.4	88.3%	NO	96.4	3.1	6.8	96.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F00	26	3.4	22.6	86.9%	NO	85.5	7.4	5.7	91.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA	
	R9	RESIDENTIAL	BEDROOM	W11/F00	25.8	3.7	22.1	85.7%	NO	92.8	4.2	6.5	95.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F00	25.3	4.4	20.9	82.6%	NO	89.4	11.2	5.7	87.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F00	25	5	20	80.0%	NO	87.8	6.2	6.0	92.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F00	25.4	6.4	19	74.8%	NO	87.5	18.1	5.1	79.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F00	25.9	7.5	18.4	71.0%	NO	86.9	10.1	5.6	88.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F00	26.8	9.8	17	63.4%	NO	90.4	411	3.6	54.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F00	27.1	11.7	15.4	56.8%	NO	85.5	26.9	4.5	68.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F01	R1	RESIDENTIAL	UNKNOWN	W1/F01	12.4	6.9	5.5	44.4%	NO	51.3	17.1	7.4	66.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F01	13.3	6.7	6.6	49.6%	NO													
	R2	RESIDENTIAL	UNKNOWN	W3/F01	16.3	8.1	8.2	50.3%	NO	79.3	62.5	2.2	211%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F01	18.5	9.4	9.1	49.2%	NO													
LAMBERT HALL (CONTINUED)																						
	R3	RESIDENTIAL	BEDROOM	W5/F01	30.5	2.6	27.9	91.5%	NO	96.2	3.2	6.8	96.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F01	29.7	2.5	27.2	91.6%	NO	93.8	3	6.6	96.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W7/F01	29.3	2.6	26.7	91.1%	NO	96.5	3.2	6.8	96.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F01	28.5	2.7	25.8	90.5%	NO	93	3.6	6.5	96.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F01	28.1	2.8	25.3	90.0%	NO	96.8	4.1	6.8	95.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F01	27.5	3.1	24.4	88.7%	NO	88.4	5.4	6.1	93.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F01	27	3.3	23.7	87.8%	NO	96.3	4.2	6.7	95.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F01	26.5	3.6	22.9	86.4%	NO	85.4	8.1	5.7	90.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F01	26.3	3.9	22.4	85.2%	NO	92.8	5.2	6.4	94.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F01	25.8	4.6	21.2	82.2%	NO	89.4	12.2	5.6	86.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F01	25.5	5.2	20.3	79.6%	NO	87.9	6.9	5.9	92.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F01	25.9	6.5	19.4	74.9%	NO	87.8	18.6	5.1	78.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F01	26.4	7.6	18.8	71.2%	NO	86.9	10.7	5.6	87.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F01	27.2	10	17.2	63.2%	NO	90.6	41.5	3.6	54.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F01	27.6	12	15.6	56.5%	NO	84.9	28.5	4.2	66.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R18	RESIDENTIAL	BEDROOM	W20/F01	27.9	16.6	11.3	40.5%	NO	91.7	68.5	1.7	25.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F01	28.1	19.5	8.6	30.6%	NO	82.3	53.7	2.2	34.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F02	R1	RESIDENTIAL	UNKNOWN	W1/F02	14.3	8.7	5.6	39.2%	NO	52.7	21.1	6.9	59.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F02	15.2	8.5	6.7	44.1%	NO													
	R2	RESIDENTIAL	UNKNOWN	W3/F02	18.1	9.8	8.3	45.9%	NO	81	65.2	2.1	19.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F02	20.2	11	9.2	45.5%	NO													
	R3	RESIDENTIAL	BEDROOM	W5/F02	31.2	2.7	28.5	91.3%	NO	96.2	2.2	6.9	97.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F02	30.4	2.7	27.7	91.1%	NO	94	2.5	6.7	97.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	VSC (WINDOW)					NSL					APSH (ROOM)						
					EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%	%	%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
	R5	RESIDENTIAL	BEDROOM	W7/F02	29.9	2.7	27.2	91.0%	NO	96.4	3.4	6.8	96.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F02	29.2	2.9	26.3	90.1%	NO	93	4.1	6.5	95.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F02	28.7	3	25.7	89.5%	NO	96.8	4.8	6.7	95.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F02	28.1	3.3	24.8	88.3%	NO	88.6	6.4	6.0	92.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F02	27.6	3.5	24.1	87.3%	NO	96.3	5.1	6.7	94.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W12/F02	27	3.9	23.1	85.6%	NO	85.4	9	5.6	89.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM	W13/F02	26.8	4.1	22.7	84.7%	NO	92.8	6.2	6.3	93.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM	W14/F02	26.2	4.8	21.4	81.7%	NO	89.4	13.1	5.6	85.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
LAMBERT HALL (CONTINUED)																					
	R13	RESIDENTIAL	BEDROOM	W15/F02	26	5.4	20.6	79.2%	NO	87.8	7.8	5.8	91.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	BEDROOM	W16/F02	26.3	6.7	19.6	74.5%	NO	87.9	19.2	5.0	78.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R15	RESIDENTIAL	BEDROOM	W17/F02	26.8	7.8	19	70.9%	NO	87	10.8	5.6	87.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R16	RESIDENTIAL	BEDROOM	W18/F02	27.7	10.2	17.5	63.2%	NO	90.6	41.7	3.6	53.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R17	RESIDENTIAL	BEDROOM	W19/F02	28.1	12.2	15.9	56.6%	NO	84.9	28.4	4.2	66.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R18	RESIDENTIAL	BEDROOM	W20/F02	28.4	16.9	11.5	40.5%	NO	91.7	68.4	1.7	25.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R19	RESIDENTIAL	BEDROOM	W21/F02	28.7	19.7	9	31.4%	NO	82.3	53.7	2.2	34.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN	W1/F03	16.9	11.2	5.7	33.7%	NO	53.3	23.3	6.5	56.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/F03	17.7	10.9	6.8	38.4%	NO												
	R2	RESIDENTIAL	UNKNOWN	W3/F03	20.4	12	8.4	41.2%	NO	81.8	67.5	1.9	17.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W4/F03	22.4	13	9.4	42.0%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F03	31.8	2.9	28.9	90.9%	NO	96.3	4	6.8	95.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F03	31	2.8	28.2	91.0%	NO	94.4	3.9	6.6	95.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F03	30.6	2.9	27.7	90.5%	NO	96.5	4.6	6.7	95.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F03	29.8	3	26.8	89.9%	NO	93	4.6	6.5	95.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F03	29.3	3.2	26.1	89.1%	NO	96.8	5.8	6.7	94.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F03	28.6	3.6	25	87.4%	NO	88.7	7.4	5.9	91.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F03	28.2	3.8	24.4	86.5%	NO	96.3	6.4	6.6	93.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W12/F03	27.6	4.1	23.5	85.1%	NO	85.4	10.2	5.5	88.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM	W13/F03	27.4	4.4	23	83.9%	NO	92.8	7.2	6.3	92.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM	W14/F03	26.8	5.1	21.7	81.0%	NO	89.5	13.7	5.5	84.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F03	26.5	5.7	20.8	78.5%	NO	87.9	8.7	5.8	90.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	BEDROOM	W16/F03	26.8	6.9	19.9	74.3%	NO	88.2	19.8	5.0	77.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R15	RESIDENTIAL	BEDROOM	W17/F03	27.3	8	19.3	70.7%	NO	87	11.8	5.5	86.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R16	RESIDENTIAL	BEDROOM	W18/F03	28.1	10.4	17.7	63.0%	NO	90.6	41.8	3.6	53.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R17	RESIDENTIAL	BEDROOM	W19/F03	28.6	12.4	16.2	56.6%	NO	84.8	28.5	4.2	66.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
	R18	RESIDENTIAL	BEDROOM	W20/F03	28.9	17.1	11.8	40.8%	NO	91.7	68.8	1.7	25.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R19	RESIDENTIAL	BEDROOM	W21/F03	29.2	20	9.2	31.5%	NO	82.3	53.8	2.2	34.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	UNKNOWN	W1/F04	20.6	14.7	5.9	28.6%	NO	55	30.3	5.4	44.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/F04	21.2	14.3	6.9	32.5%	NO												
	R2	RESIDENTIAL	UNKNOWN	W3/F04	23.6	15	8.6	36.4%	NO	84.3	72.4	1.6	14.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
LAMBERT HALL (CONTINUED)																					
			UNKNOWN	W4/F04	25.2	15.7	9.5	37.7%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F04	32.5	3	29.5	90.8%	NO	96.2	4.9	6.7	94.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F04	31.7	3	28.7	90.5%	NO	94.9	4.6	6.6	95.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F04	31.2	3.1	28.1	90.1%	NO	96.4	5.7	6.6	94.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F04	30.4	3.3	27.1	89.1%	NO	93.1	6.1	6.4	93.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F04	30	3.5	26.5	88.3%	NO	96.8	7	6.6	92.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F04	29.3	3.9	25.4	86.7%	NO	88.6	9.2	5.8	89.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F04	28.8	4.1	24.7	85.8%	NO	96.2	7.9	6.5	91.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W12/F04	28.2	4.5	23.7	84.0%	NO	85.4	11.5	5.4	86.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM	W13/F04	27.9	4.7	23.2	83.2%	NO	92.8	8.8	6.1	90.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM	W14/F04	27.3	5.4	21.9	80.2%	NO	89.5	15.3	5.4	82.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F04	27.1	6	21.1	77.9%	NO	87.9	9.9	5.7	88.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	BEDROOM	W16/F04	27.3	7.2	20.1	73.6%	NO	88.3	21.4	4.9	75.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R15	RESIDENTIAL	BEDROOM	W17/F04	27.7	8.2	19.5	70.4%	NO	87.1	12.6	5.4	85.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R16	RESIDENTIAL	BEDROOM	W18/F04	28.6	10.6	18	62.9%	NO	90.6	42	3.6	53.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R17	RESIDENTIAL	BEDROOM	W19/F04	29.1	12.6	16.5	56.7%	NO	84.8	28.7	4.1	66.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R18	RESIDENTIAL	BEDROOM	W20/F04	29.4	17.3	12.1	41.2%	NO	91.7	68.7	1.7	25.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R19	RESIDENTIAL	BEDROOM	W21/F04	29.8	20.3	9.5	31.9%	NO	82.3	53.9	2.2	34.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN	W1/F05	25.3	19.3	6	23.7%	NO	62.4	45.6	3.6	26.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/F05	25.7	18.8	6.9	26.8%	NO												
	R2	RESIDENTIAL	UNKNOWN	W3/F05	27.5	18.9	8.6	31.3%	NO	90.1	82.4	1.0	8.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W4/F05	28.7	19.2	9.5	33.1%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F05	33.1	3.2	29.9	90.3%	NO	96.2	5.3	6.7	94.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F05	32.3	3.2	29.1	90.1%	NO	95.5	5	6.6	94.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F05	31.8	3.2	28.6	89.9%	NO	96.4	6.4	6.6	93.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F05	31.1	3.5	27.6	88.7%	NO	94	7.5	6.3	92.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F05	30.6	3.8	26.8	87.6%	NO	96.8	8.1	6.5	91.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F05	29.9	4.3	25.6	85.6%	NO	88.7	10.7	5.7	88.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F05	29.4	4.6	24.8	84.4%	NO	96.2	9.2	6.4	90.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	VSC (WINDOW)					NSL					APSH (ROOM)						
					EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%	%	%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
	R10	RESIDENTIAL	BEDROOM	W12/F05	28.8	4.9	23.9	83.0%	NO	85.4	12.9	5.3	84.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM	W13/F05	28.5	5.1	23.4	82.1%	NO	92.8	10.2	6.0	89.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
LAMBERT HALL (CONTINUED)																					
	R12	RESIDENTIAL	BEDROOM	W14/F05	27.9	5.8	22.1	79.2%	NO	89.5	16.7	5.3	81.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F05	27.7	6.3	21.4	77.3%	NO	87.9	11.2	5.6	87.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	BEDROOM	W16/F05	27.9	7.5	20.4	73.1%	NO	88.3	22.6	4.8	74.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R15	RESIDENTIAL	BEDROOM	W17/F05	28.3	8.4	19.9	70.3%	NO	87.1	13.7	5.4	84.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R16	RESIDENTIAL	BEDROOM	W18/F05	29.2	10.8	18.4	63.0%	NO	90.6	42.2	3.5	53.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R17	RESIDENTIAL	BEDROOM	W19/F05	29.6	12.9	16.7	56.4%	NO	84.8	28.8	4.1	66.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R18	RESIDENTIAL	BEDROOM	W20/F05	30	17.6	12.4	41.3%	NO	91.7	68.8	1.7	24.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R19	RESIDENTIAL	BEDROOM	W21/F05	30.4	20.6	9.8	32.2%	NO	82.3	53.9	2.2	34.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F06	R1	RESIDENTIAL	UNKNOWN	W1/F06	30	23.9	6.1	20.3%	NO	80.3	73.8	1.4	8.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/F06	30.3	23.4	6.9	22.8%	NO												
	R2	RESIDENTIAL	UNKNOWN	W3/F06	31.5	22.9	8.6	27.3%	NO	98.7	94.8	0.5	3.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W4/F06	32.3	22.6	9.7	30.0%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F06	33.7	3.4	30.3	89.9%	NO	96.2	6.3	6.6	93.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F06	32.9	3.4	29.5	89.7%	NO	96.5	7.1	6.5	92.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F06	32.5	3.4	29.1	89.5%	NO	96.5	7.2	6.5	92.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F06	31.7	3.8	27.9	88.0%	NO	94.4	9.8	6.2	89.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F06	31.3	4.1	27.2	86.9%	NO	96.8	10.1	6.3	89.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F06	30.6	4.8	25.8	84.3%	NO	88.9	13	5.5	85.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F06	30.1	5.1	25	83.1%	NO	96.3	11.8	6.2	87.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W12/F06	29.4	5.4	24	81.6%	NO	85.5	15.4	5.1	82.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM	W13/F06	29.2	5.7	23.5	80.5%	NO	92.9	12.7	5.9	86.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM	W14/F06	28.5	6.3	22.2	77.9%	NO	89.5	19.5	5.1	78.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F06	28.3	6.8	21.5	76.0%	NO	87.9	13.9	5.4	84.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	BEDROOM	W16/F06	28.5	7.8	20.7	72.6%	NO	88.4	24.7	4.7	72.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R15	RESIDENTIAL	BEDROOM	W17/F06	28.8	8.7	20.1	69.8%	NO	87.1	15.1	5.3	82.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R16	RESIDENTIAL	BEDROOM	W18/F06	29.7	11.1	18.6	62.6%	NO	90.6	42.4	3.5	53.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R17	RESIDENTIAL	BEDROOM	W19/F06	30.2	13.1	17.1	56.6%	NO	84.8	29	4.1	65.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R18	RESIDENTIAL	BEDROOM	W20/F06	30.7	17.8	12.9	42.0%	NO	91.7	68.9	1.7	24.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R19	RESIDENTIAL	BEDROOM	W21/F06	31	20.9	10.1	32.6%	NO	82.5	54.3	2.2	34.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA		%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
STONEBRIDGE HOUSE																						
F00	R1	RESIDENTIAL	BEDROOM	W1/F00	10.6	9	1.6	15.1%	YES	64.4	64.4	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F00	7.8	7.6	0.2	2.6%	YES	60.4	60.4	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F00	5.5	5.3	0.2	3.6%	YES													
			LKD	W4/F00	8.5	7.8	0.7	8.2%	YES													
F01	R1	RESIDENTIAL	BEDROOM	W1/F01	13.6	11.3	2.3	16.9%	YES	78.8	78.8	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F01	10.3	9.8	0.5	4.9%	YES	75.4	75.3	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F01	9	8.3	0.7	7.8%	YES													
			LKD	W4/F01	9.2	7.7	1.5	16.3%	YES													
			LKD	W5/F01	0.1	0.1	0	0.0%	YES													
			LKD	W6/F01	10.3	8.9	1.4	13.6%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F01	14.7	14.1	0.6	4.1%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F01	14.3	14.3	0	0.0%	YES	92.3	92.3	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F01	13.5	13.5	0	0.0%	YES													
			LKD	W10/F01	13.1	13.1	0	0.0%	YES													
			LKD	W11/F01	14.3	14.3	0	0.0%	YES													
			LKD	W12/F01	12.7	12.7	0	0.0%	YES													
F02	R1	RESIDENTIAL	BEDROOM	W1/F02	17.7	14.6	3.1	17.5%	YES	83.1	83.1	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F02	13.3	12.6	0.7	5.3%	YES	85.1	85	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F02	12	10.6	1.4	11.7%	YES													
			LKD	W4/F02	12.2	9.8	2.4	19.7%	YES													
			LKD	W5/F02	0	0	0	-	YES													
			LKD	W6/F02	13.1	10.9	2.2	16.8%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F02	18.5	17.1	1.4	7.6%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F02	17.6	17.4	0.2	11%	YES	99.2	99.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F02	16.3	16.3	0	0.0%	YES													
			LKD	W10/F02	15.7	15.7	0	0.0%	YES													
			LKD	W11/F02	17.1	17.1	0	0.0%	YES													
			LKD	W12/F02	15	15	0	0.0%	YES													
F03	R1	RESIDENTIAL	BEDROOM	W1/F03	22.6	18.7	3.9	17.3%	YES	90.7	90.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F03	18.3	16.6	1.7	9.3%	YES	94.8	94.7	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F03	17.6	14.7	2.9	16.5%	YES													
STONEBRIDGE HOUSE (CONTINUED)																						
			LKD	W4/F03	17.7	14.2	3.5	19.8%	YES													
			LKD	W5/F03	0.3	0.3	0	0.0%	YES													

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA	
			LKD	W6/F03	18.5	15	3.5	18.9%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F03	23	20.4	2.6	11.3%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F03	21.4	20.4	1	4.7%	YES	99.2	99.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F03	19.6	19.4	0.2	1.0%	YES													
			LKD	W10/F03	18.6	18.6	0	0.0%	YES													
			LKD	W11/F03	20.4	20.3	0.1	0.5%	YES													
			LKD	W12/F03	17.6	17.6	0	0.0%	YES													
F04	R1	RESIDENTIAL	BEDROOM	W1/F04	27	22.5	4.5	16.7%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F04	22.7	20	2.7	11.9%	YES	100	99.9	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F04	22.3	18.3	4	17.9%	YES													
			LKD	W4/F04	22.4	17.7	4.7	21.0%	NO													
			LKD	W5/F04	0.6	0.6	0	0.0%	YES													
			LKD	W6/F04	22.9	18.1	4.8	21.0%	NO													
	R3	RESIDENTIAL	BEDROOM	W7/F04	27.5	22.9	4.6	16.7%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F04	25.9	22.7	3.2	12.4%	YES	99.2	99.1	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F04	23.7	22.1	1.6	6.8%	YES													
			LKD	W10/F04	22.3	21.7	0.6	2.7%	YES													
			LKD	W11/F04	20.7	20.7	0	0.0%	YES													
			LKD	W12/F04	24.4	22.2	2.2	9.0%	YES													
F05	R1	RESIDENTIAL	BEDROOM	W1/F05	22.9	19.6	3.3	14.4%	YES	100	99.9	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F05	17	14.7	2.3	13.5%	YES	100	99.9	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F05	18.6	15.2	3.4	18.3%	YES													
			LKD	W4/F05	18.6	14.4	4.2	22.6%	NO													
			LKD	W5/F05	1.8	1.3	0.5	27.8%	NO													
			LKD	W6/F05	17	12.4	4.6	27.1%	NO													
	R3	RESIDENTIAL	BEDROOM	W7/F05	22.5	18.2	4.3	19.1%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F05	18.4	16.7	1.7	9.2%	YES	99.1	98.9	0.0	0.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F05	17.8	15.2	2.6	14.6%	YES													
			LKD	W10/F05	16.7	14	2.7	16.2%	YES													
STONEBRIDGE HOUSE (CONTINUED)																						
			LKD	W11/F05	15.4	12.9	2.5	16.2%	YES													
			LKD	W12/F05	1.5	1.5	0	0.0%	YES													
F06	R1	RESIDENTIAL	BEDROOM	W1/F06	5.1	4.2	0.9	17.6%	YES	96.8	96.7	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F06	5.1	4.2	0.9	17.6%	YES	98.9	98.7	0.0	0.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F06	8.6	7.1	1.5	17.4%	YES													

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS SQM	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA						%	%	ANNUAL	WINTER	ANNUAL	WINTER	
			LKD	W4/F06	8.6	7.1	1.5	17.4%	YES												
			LKD	W5/F06	5.2	4.2	1	19.2%	YES												
	R3	RESIDENTIAL	BEDROOM	W6/F06	5.3	4.2	11	20.8%	NO	97.6	96.7	0.1	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	LKD	W7/F06	5.4	4.1	1.3	24.1%	NO	98.5	98	0.1	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			LKD	W8/F06	9.1	6.7	2.4	26.4%	NO												
			LKD	W9/F06	9.5	6.7	2.8	29.5%	NO												
			LKD	W10/F06	9.8	6.4	3.4	34.7%	NO												
			LKD	W11/F06	0	0	0	-	YES												

WAREHOUSE ONE																					
B01	R1	RESIDENTIAL	UNKNOWN	W1/B01	10.5	5.7	4.8	45.7%	NO	46.6	14.8	9.4	68.2%	NO	23	2	12	0	47.8%	100.0%	NO
			UNKNOWN	W2/B01	9.8	5.7	4.1	41.8%	NO												
			UNKNOWN	W3/B01	8.8	5.8	3	34.1%	NO												
	R2	RESIDENTIAL	UNKNOWN	W4/B01	6.4	5.4	1	15.6%	YES	19.7	15.7	11	20.5%	NO	8	0	8	0	0.0%	0.0%	YES
			UNKNOWN	W5/B01	6.2	5.4	0.8	12.9%	YES												
F00	R1	RESIDENTIAL	UNKNOWN	W1/F00	12.1	9.9	2.2	18.2%	YES	90.7	40.5	14.9	55.3%	NO	36	6	20	0	44.4%	100.0%	NO
			UNKNOWN	W2/F00	14.3	6.9	7.4	51.7%	NO												
			UNKNOWN	W3/F00	13.5	7	6.5	48.1%	NO												
			UNKNOWN	W4/F00	12.8	7.1	5.7	44.5%	NO												
			UNKNOWN	W5/F00	12.1	7.2	4.9	40.5%	NO												
			UNKNOWN	W6/F00	11	7.3	3.7	33.6%	NO												
	R2	RESIDENTIAL	UNKNOWN	W7/F00	7.9	6.4	1.5	19.0%	YES	26.5	22	1.2	17.1%	YES	13	0	13	0	0.0%	0.0%	YES
			UNKNOWN	W8/F00	7.8	6.5	1.3	16.7%	YES												
	R3	RESIDENTIAL	UNKNOWN	W9/F00	7.5	6.3	1.2	16.0%	YES	16.8	16.3	0.2	3.0%	YES	9	0	9	0	0.0%	0.0%	YES
			UNKNOWN	W10/F00	7.3	6.1	1.2	16.4%	YES												
F01	R1	RESIDENTIAL	UNKNOWN	W1/F01	7.5	7.2	0.3	4.0%	YES	39.6	38	0.6	4.1%	YES	29	0	21	0	27.6%	0.0%	NO
WAREHOUSE ONE (CONTINUED)																					
			UNKNOWN	W10/F01	11	8.3	2.7	24.5%	NO												
			UNKNOWN	W11/F01	10.5	7.8	2.7	25.7%	NO												
	R2	RESIDENTIAL	UNKNOWN	W2/F01	14.8	12.4	2.4	16.2%	YES	93.8	47.3	13.7	49.5%	NO	49	7	29	1	40.8%	85.7%	NO
			UNKNOWN	W3/F01	17.9	8.9	9	50.3%	NO												
			UNKNOWN	W4/F01	17.2	9.1	8.1	47.1%	NO												
			UNKNOWN	W5/F01	16.6	9.2	7.4	44.6%	NO												
			UNKNOWN	W6/F01	16	9.3	6.7	41.9%	NO												
			UNKNOWN	W7/F01	15	9.4	5.6	37.3%	NO												

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	VSC (WINDOW)					NSL					APSH (ROOM)						
					EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%	%	%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
F02	R3	RESIDENTIAL	UNKNOWN	W8/F01	11.6	8.5	3.1	26.7%	NO	41	35.9	1.4	12.4%	YES	31	0	24	0	22.6%	0.0%	NO
			UNKNOWN	W9/F01	11.3	8.5	2.8	24.8%	NO												
	R1	RESIDENTIAL	UNKNOWN	W1/F02	11.1	10.5	0.6	5.4%	YES	65.4	60.4	1.9	7.5%	YES	45	2	29	1	35.6%	50.0%	NO
			UNKNOWN	W10/F02	16.1	10.6	5.5	34.2%	NO												
			UNKNOWN	W11/F02	15.8	10.3	5.5	34.8%	NO												
	R2	RESIDENTIAL	UNKNOWN	W2/F02	19.2	16.5	2.7	14.1%	YES	98.1	70	8.3	28.6%	NO	62	13	39	3	37.1%	76.9%	NO
			UNKNOWN	W3/F02	23.4	11.2	12.2	52.1%	NO												
			UNKNOWN	W4/F02	22.9	11.4	11.5	50.2%	NO												
			UNKNOWN	W5/F02	22.4	11.6	10.8	48.2%	NO												
			UNKNOWN	W6/F02	22	11.7	10.3	46.8%	NO												
			UNKNOWN	W7/F02	21.3	11.8	9.5	44.6%	NO												
	R3	RESIDENTIAL	UNKNOWN	W8/F02	16.7	10.7	6	35.9%	NO	64.3	56.3	2.2	12.5%	YES	45	1	32	1	28.9%	0.0%	YES
			UNKNOWN	W9/F02	16.7	10.7	6	35.9%	NO												
	R1	RESIDENTIAL	UNKNOWN	W1/F03	16.2	15.3	0.9	5.6%	YES	98.9	94.4	1.7	4.5%	YES	64	11	40	5	37.5%	54.5%	YES
			UNKNOWN	W8/F03	23.6	13.4	10.2	43.2%	NO												
			UNKNOWN	W9/F03	23	13.4	9.6	41.7%	NO												
	R2	RESIDENTIAL	UNKNOWN	W2/F03	27.5	13	14.5	52.7%	NO	80.6	54.8	7.6	32.0%	NO	65	14	42	4	35.4%	71.4%	NO
			UNKNOWN	W3/F03	27.1	13.1	14	51.7%	NO												
			UNKNOWN	W4/F03	26.8	13.3	13.5	50.4%	NO												
			UNKNOWN	W5/F03	26.6	13.4	13.2	49.6%	NO												
			UNKNOWN	W1/F04	25.3	22.4	2.9	11.5%	YES												
	R3	RESIDENTIAL	UNKNOWN	W6/F03	24.4	13.2	11.2	45.9%	NO	99.1	88.7	2.8	10.4%	YES	63	11	39	4	38.1%	63.6%	NO
			UNKNOWN	W7/F03	24	13.3	10.7	44.6%	NO												
WAREHOUSE ONE (CONTINUED)																					
F04	R1	RESIDENTIAL	UNKNOWN	W2/F04	29.8	15.3	14.5	48.7%	NO	82.1	47.5	13.5	42.2%	NO	77	21	45	7	41.6%	66.7%	YES
			UNKNOWN	W3/F04	29.6	15.6	14	47.3%	NO												
	R2	RESIDENTIAL	UNKNOWN	W4/F04	29.2	15.9	13.3	45.5%	NO	79.8	41.7	10.2	47.7%	NO	73	17	43	6	41.1%	64.7%	YES

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m





NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL1

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID








FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
B01	R1	RESIDENTIAL	UNKNOWN	29.6	46.6	14.8	9.4	68.2
B01	R2	RESIDENTIAL	UNKNOWN	26.9	19.7	15.7	1.1	20.5
F00	R1	RESIDENTIAL	UNKNOWN	29.6	90.7	40.5	14.9	55.3
F00	R2	RESIDENTIAL	UNKNOWN	26.9	26.5	22	1.2	17.1
F00	R3	RESIDENTIAL	UNKNOWN	38.8	16.8	16.3	0.2	3
F01	R1	RESIDENTIAL	UNKNOWN	38.8	39.6	38	0.6	4.1
F01	R2	RESIDENTIAL	UNKNOWN	29.6	93.8	47.3	13.7	49.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL2

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
F01	R3	RESIDENTIAL	UNKNOWN	26.9	41	35.9	1.4	12.4
F02	R1	RESIDENTIAL	UNKNOWN	38.8	65.4	60.4	1.9	7.5
F02	R2	RESIDENTIAL	UNKNOWN	29.6	98.1	70	8.3	28.6
F02	R3	RESIDENTIAL	UNKNOWN	26.9	64.3	56.3	2.2	12.5
F03	R1	RESIDENTIAL	UNKNOWN	38.8	98.9	94.4	1.7	4.5
F03	R2	RESIDENTIAL	UNKNOWN	29.6	80.6	54.8	7.6	32

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: WAREHOUSE ONE
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL3



KEY:

GAIN

LOSS

MAINTAINED LIT AREA

1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
F03	R3	RESIDENTIAL	UNKNOWN	26.9	99.1	88.7	2.8	10.4
F04	R1	RESIDENTIAL	UNKNOWN	38.9	82.1	47.5	13.5	42.2
F04	R2	RESIDENTIAL	UNKNOWN	26.8	79.8	41.7	10.2	47.7


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LONDON ROAD FIRE STATION
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL4

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LONDON ROAD FIRE STATION								
F01	R11	HOTEL	BEDROOM	23.3	92.9	86.7	1.4	6.7
F01	R12	HOTEL	BEDROOM	18.2	96.1	87.9	1.5	8.5
F01	R13	HOTEL	BEDROOM	17.1	97.1	96.1	0.2	1
F02	R10	HOTEL	BEDROOM	18.0	96	80.5	2.8	16.1
F02	R11	HOTEL	BEDROOM	17.7	92.5	82.2	1.8	11.1
F02	R12	HOTEL	BEDROOM	21.0	95.3	86.2	1.9	9.6
F02	R13	HOTEL	BEDROOM	13.9	97.1	96.8	0.0	0.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: LONDON ROAD FIRE STATION
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL5

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F03



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LONDON ROAD FIRE STATION								
F03	R10	HOTEL	BEDROOM	18.0	98.4	83.5	2.7	15.1
F03	R11	HOTEL	BEDROOM	17.7	96.9	90	1.2	7.1
F03	R12	HOTEL	BEDROOM	21.0	79.6	67.6	2.5	15.1
F03	R13	HOTEL	BEDROOM	13.9	83.4	66.9	2.3	19.8

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL6

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F00

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F00	R1	RESIDENTIAL	UNKNOWN	76.2	64.1	63.1	0.8	1.6
F00	R2	RESIDENTIAL	UNKNOWN	26.5	52.9	21.7	8.3	59
F00	R3	RESIDENTIAL	UNKNOWN	14.7	96.6	70.6	3.8	27
F00	R4	RESIDENTIAL	UNKNOWN	16.7	84.9	56.8	4.7	33.1
F00	R5	RESIDENTIAL	UNKNOWN	50.9	80	80	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL7

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R1	RESIDENTIAL	UNKNOWN	34.4	63	62.8	0.1	0.4
F01	R2	RESIDENTIAL	BEDROOM	6.8	43.5	42.1	0.1	3.2
F01	R3	RESIDENTIAL	BEDROOM	7.3	43.8	41.9	0.1	4.4
F01	R4	RESIDENTIAL	BEDROOM	10.2	31	29	0.2	6.5
F01	R5	RESIDENTIAL	BEDROOM	7.3	46.4	40	0.5	13.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL8

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R6	RESIDENTIAL	BEDROOM	6.8	45.8	42.1	0.2	8
F01	R7	RESIDENTIAL	BEDROOM	6.8	47.7	41	0.5	14.1
F01	R8	RESIDENTIAL	BEDROOM	6.9	41.6	35.9	0.4	13.7
F01	R9	RESIDENTIAL	BEDROOM	6.9	34.8	24.6	0.7	29.5
F01	R10	RESIDENTIAL	BEDROOM	7.4	50.9	21.3	2.2	58.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL9

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R11	RESIDENTIAL	UNKNOWN	15.8	90.3	68.5	3.4	24.2
F01	R12	RESIDENTIAL	BEDROOM	10.5	95.4	23.3	7.6	75.6
F01	R13	RESIDENTIAL	BEDROOM	10.5	93.9	29.7	6.7	68.4
F01	R14	RESIDENTIAL	UNKNOWN	20.9	92.4	87.6	1.0	5.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL10

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R1	RESIDENTIAL	UNKNOWN	34.4	71.8	71.4	0.1	0.5
F02	R2	RESIDENTIAL	BEDROOM	6.8	60.1	57	0.2	5.1
F02	R3	RESIDENTIAL	BEDROOM	7.3	59.7	57.1	0.2	4.3
F02	R4	RESIDENTIAL	BEDROOM	10.2	42.9	40.9	0.2	4.6
F02	R5	RESIDENTIAL	BEDROOM	7.3	61.6	55.7	0.4	9.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL11

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R6	RESIDENTIAL	BEDROOM	6.8	63.8	60.3	0.2	5.6
F02	R7	RESIDENTIAL	BEDROOM	6.8	58.1	51.2	0.5	12
F02	R8	RESIDENTIAL	BEDROOM	6.9	53.3	47.4	0.4	11.1
F02	R9	RESIDENTIAL	BEDROOM	6.9	40.5	30.4	0.7	24.8
F02	R10	RESIDENTIAL	BEDROOM	7.4	58.3	29.9	2.1	48.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL12

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R11	RESIDENTIAL	UNKNOWN	15.8	90.9	71.7	3.0	21.2
F02	R12	RESIDENTIAL	BEDROOM	10.5	97.1	23.5	7.7	75.8
F02	R13	RESIDENTIAL	BEDROOM	10.5	96.1	30.2	6.9	68.6
F02	R14	RESIDENTIAL	UNKNOWN	20.9	95.9	93.6	0.5	2.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: FAIRFIELD HOUSE
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL13

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R1	RESIDENTIAL	UNKNOWN	34.4	83.8	82.7	0.4	1.2
F03	R2	RESIDENTIAL	BEDROOM	6.8	75.2	68.7	0.4	8.6
F03	R3	RESIDENTIAL	BEDROOM	7.3	75.4	71.7	0.3	4.9
F03	R4	RESIDENTIAL	BEDROOM	10.2	56.4	54.4	0.2	3.6
F03	R5	RESIDENTIAL	BEDROOM	7.3	75.5	69.8	0.4	7.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL14

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R6	RESIDENTIAL	BEDROOM	6.8	80.8	77.5	0.2	4
F03	R7	RESIDENTIAL	BEDROOM	6.8	67.5	60.9	0.4	9.7
F03	R8	RESIDENTIAL	BEDROOM	6.9	60.7	55.3	0.4	8.8
F03	R9	RESIDENTIAL	BEDROOM	6.9	43.4	33.5	0.7	22.9
F03	R10	RESIDENTIAL	BEDROOM	7.4	61.9	34.7	2.0	44

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL15

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R11	RESIDENTIAL	UNKNOWN	15.8	91.3	73.1	2.9	19.9
F03	R12	RESIDENTIAL	BEDROOM	10.5	97.4	23.6	7.7	75.8
F03	R13	RESIDENTIAL	BEDROOM	10.5	97	30.3	7.0	68.7
F03	R14	RESIDENTIAL	UNKNOWN	20.9	96.2	94.2	0.4	2.1

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL16

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R1	RESIDENTIAL	UNKNOWN	34.4	88.7	88.6	0.0	0.1
F04	R2	RESIDENTIAL	BEDROOM	6.8	86.7	77.8	0.6	10.3
F04	R3	RESIDENTIAL	BEDROOM	7.3	87.7	82.1	0.4	6.3
F04	R4	RESIDENTIAL	BEDROOM	10.2	69.5	66.6	0.3	4.1
F04	R5	RESIDENTIAL	BEDROOM	7.3	80.6	74.8	0.4	7.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: FAIRFIELD HOUSE
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL17

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R6	RESIDENTIAL	BEDROOM	6.8	85	82	0.2	3.5
F04	R7	RESIDENTIAL	BEDROOM	6.8	69.5	63.3	0.4	8.9
F04	R8	RESIDENTIAL	BEDROOM	6.9	63.1	58.5	0.3	7.3
F04	R9	RESIDENTIAL	BEDROOM	6.9	45.7	36.4	0.6	20.3
F04	R10	RESIDENTIAL	BEDROOM	7.4	63	38.1	1.8	39.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL18

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R11	RESIDENTIAL	UNKNOWN	15.8	91.7	73.5	2.9	19.8
F04	R12	RESIDENTIAL	BEDROOM	10.5	98	23.7	7.8	75.8
F04	R13	RESIDENTIAL	BEDROOM	10.5	97.9	30.4	7.1	69
F04	R14	RESIDENTIAL	UNKNOWN	20.9	99	97.4	0.3	1.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL19

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R1	RESIDENTIAL	UNKNOWN	34.4	95.6	95.6	0.0	0
F05	R2	RESIDENTIAL	BEDROOM	6.8	96.2	87.2	0.6	9.4
F05	R3	RESIDENTIAL	BEDROOM	7.3	96.7	91.7	0.4	5.1
F05	R4	RESIDENTIAL	BEDROOM	10.2	86.1	82.9	0.3	3.7
F05	R5	RESIDENTIAL	BEDROOM	7.3	89.7	81.1	0.6	9.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL20

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R6	RESIDENTIAL	BEDROOM	6.8	91.5	88.4	0.2	3.5
F05	R7	RESIDENTIAL	BEDROOM	6.8	75.5	68.2	0.5	9.7
F05	R8	RESIDENTIAL	BEDROOM	6.9	70.4	65	0.4	7.7
F05	R9	RESIDENTIAL	BEDROOM	6.9	55.5	44.6	0.7	19.7
F05	R10	RESIDENTIAL	BEDROOM	7.4	67.4	49.1	1.4	27.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL21

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R11	RESIDENTIAL	UNKNOWN	15.8	92.4	74.6	2.8	19.2
F05	R12	RESIDENTIAL	BEDROOM	10.5	98.1	23.7	7.8	75.8
F05	R13	RESIDENTIAL	BEDROOM	10.5	98.1	30.5	7.1	69
F05	R14	RESIDENTIAL	UNKNOWN	20.9	99	97.4	0.3	1.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL22

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F06	R2	RESIDENTIAL	BEDROOM	6.8	96.3	87.7	0.6	8.9
F06	R3	RESIDENTIAL	BEDROOM	7.3	96.7	92.4	0.3	4.4
F06	R4	RESIDENTIAL	BEDROOM	10.2	90.5	88	0.3	2.8
F06	R5	RESIDENTIAL	BEDROOM	7.3	96.6	85.8	0.8	11.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: FAIRFIELD HOUSE
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL23

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R6	RESIDENTIAL	BEDROOM	6.8	97.1	94.6	0.2	2.5
F06	R7	RESIDENTIAL	BEDROOM	6.8	90.5	81.3	0.6	10.2
F06	R8	RESIDENTIAL	BEDROOM	6.9	88.5	81.8	0.5	7.6
F06	R9	RESIDENTIAL	BEDROOM	6.9	86	68.3	1.2	20.5
F06	R10	RESIDENTIAL	BEDROOM	7.4	87	80.8	0.5	7.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL24

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R11	RESIDENTIAL	UNKNOWN	15.8	93.2	76.5	2.6	17.8
F06	R12	RESIDENTIAL	BEDROOM	10.5	98.2	23.9	7.8	75.7
F06	R13	RESIDENTIAL	BEDROOM	10.5	98.1	30.5	7.1	68.9
F06	R14	RESIDENTIAL	UNKNOWN	20.9	99.1	97.4	0.4	1.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL25

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F07	R2	RESIDENTIAL	BEDROOM	6.8	96.3	89.4	0.5	7.1
F07	R3	RESIDENTIAL	BEDROOM	7.3	96.7	93.1	0.3	3.7
F07	R4	RESIDENTIAL	BEDROOM	10.2	96.2	94.1	0.2	2.2
F07	R5	RESIDENTIAL	BEDROOM	7.3	96.6	87.2	0.7	9.8

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL26

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R6	RESIDENTIAL	BEDROOM	6.8	97.1	95	0.1	2.1
F07	R7	RESIDENTIAL	BEDROOM	6.8	97	88.5	0.6	8.7
F07	R8	RESIDENTIAL	BEDROOM	6.9	97.1	93.7	0.2	3.5
F07	R9	RESIDENTIAL	BEDROOM	6.9	97.2	85.8	0.8	11.8
F07	R10	RESIDENTIAL	BEDROOM	7.4	95.9	91.8	0.3	4.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL27

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R11	RESIDENTIAL	UNKNOWN	15.8	95.2	85.3	1.6	10.4
F07	R12	RESIDENTIAL	BEDROOM	10.5	98.1	24.1	7.8	75.4
F07	R13	RESIDENTIAL	BEDROOM	10.5	98.1	30.6	7.1	68.8
F07	R14	RESIDENTIAL	UNKNOWN	20.9	99.2	97.4	0.4	1.8

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL28

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F08

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F08	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F08	R2	RESIDENTIAL	BEDROOM	23.1	99.2	96.8	0.5	2.4
F08	R3	RESIDENTIAL	BEDROOM	10.2	98.4	96.5	0.2	1.9
F08	R4	RESIDENTIAL	BEDROOM	23.1	99.2	95.8	0.8	3.4
F08	R5	RESIDENTIAL	BEDROOM	22.4	99.4	96.5	0.7	2.9



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL29

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F08

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F08	R6	RESIDENTIAL	BEDROOM	23.3	99.3	95.7	0.8	3.6
F08	R7	RESIDENTIAL	UNKNOWN	15.8	98.9	91.2	1.2	7.8
F08	R8	RESIDENTIAL	UNKNOWN	29.9	99.5	60.4	11.7	39.3
F08	R9	RESIDENTIAL	UNKNOWN	20.9	99.8	97.8	0.4	2


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL30

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



B01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
B01	R1	RESIDENTIAL	UNKNOWN	19.3	44.1	6.3	7.3	85.8
B01	R2	RESIDENTIAL	UNKNOWN	22.5	80.1	49	7.0	38.8
B01	R3	RESIDENTIAL	UNKNOWN	22.4	88.8	0	19.8	100
B01	R4	RESIDENTIAL	UNKNOWN	22.3	88.6	2.6	19.2	97

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: LAMBERT HALL
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL31

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



B01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
B01	R5	RESIDENTIAL	UNKNOWN	22.6	89.3	6.9	18.6	92.3
B01	R6	RESIDENTIAL	UNKNOWN	22.5	89.3	15.6	16.6	82.5
B01	R7	RESIDENTIAL	UNKNOWN	22.5	89.4	31.3	13.0	65
B01	R8	RESIDENTIAL	UNKNOWN	23.2	89.3	51.9	8.7	41.9

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL32



KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R1	RESIDENTIAL	UNKNOWN	21.7	48.5	13.9	7.5	71.4
F00	R2	RESIDENTIAL	UNKNOWN	13.1	78.4	60.7	2.3	22.6
F00	R3	RESIDENTIAL	BEDROOM	7.3	96.1	2.8	6.8	97.1
F00	R4	RESIDENTIAL	BEDROOM	7.3	93.8	2.3	6.7	97.5
F00	R5	RESIDENTIAL	BEDROOM	7.3	96.5	2.4	6.9	97.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL33

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F00

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R6	RESIDENTIAL	BEDROOM	7.3	88.3	4.3	6.1	95.1
F00	R7	RESIDENTIAL	BEDROOM	7.3	96.4	3.1	6.8	96.8
F00	R8	RESIDENTIAL	BEDROOM	7.3	85.5	7.4	5.7	91.4
F00	R9	RESIDENTIAL	BEDROOM	7.3	92.8	4.2	6.5	95.4
F00	R10	RESIDENTIAL	BEDROOM	7.3	89.4	11.2	5.7	87.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL34

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F00


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R11	RESIDENTIAL	BEDROOM	7.3	87.8	6.2	6.0	92.9
F00	R12	RESIDENTIAL	BEDROOM	7.3	87.5	18.1	5.1	79.4
F00	R13	RESIDENTIAL	BEDROOM	7.3	86.9	10.1	5.6	88.3
F00	R14	RESIDENTIAL	BEDROOM	7.3	90.4	41.1	3.6	54.5
F00	R15	RESIDENTIAL	BEDROOM	7.7	85.5	26.9	4.5	68.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL35

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R1	RESIDENTIAL	UNKNOWN	21.7	51.3	17.1	7.4	66.6
F01	R2	RESIDENTIAL	UNKNOWN	13.1	79.3	62.5	2.2	21.1
F01	R3	RESIDENTIAL	BEDROOM	7.3	96.2	3.2	6.8	96.7
F01	R4	RESIDENTIAL	BEDROOM	7.3	93.8	3	6.6	96.8
F01	R5	RESIDENTIAL	BEDROOM	7.3	96.5	3.2	6.8	96.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: LAMBERT HALL
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL36

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R6	RESIDENTIAL	BEDROOM	7.3	93	3.6	6.5	96.1
F01	R7	RESIDENTIAL	BEDROOM	7.3	96.8	4.1	6.8	95.8
F01	R8	RESIDENTIAL	BEDROOM	7.3	88.4	5.4	6.1	93.8
F01	R9	RESIDENTIAL	BEDROOM	7.3	96.3	4.2	6.7	95.6
F01	R10	RESIDENTIAL	BEDROOM	7.3	85.4	8.1	5.7	90.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL37

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R11	RESIDENTIAL	BEDROOM	7.3	92.8	5.2	6.4	94.4
F01	R12	RESIDENTIAL	BEDROOM	7.3	89.4	12.2	5.6	86.3
F01	R13	RESIDENTIAL	BEDROOM	7.3	87.9	6.9	5.9	92.1
F01	R14	RESIDENTIAL	BEDROOM	7.3	87.8	18.6	5.1	78.8
F01	R15	RESIDENTIAL	BEDROOM	7.3	86.9	10.7	5.6	87.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL38

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R16	RESIDENTIAL	BEDROOM	7.3	90.6	41.5	3.6	54.2
F01	R17	RESIDENTIAL	BEDROOM	7.4	84.9	28.5	4.2	66.5
F01	R18	RESIDENTIAL	BEDROOM	7.3	91.7	68.5	1.7	25.3
F01	R19	RESIDENTIAL	BEDROOM	7.7	82.3	53.7	2.2	34.7


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL39

KEY:


- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R1	RESIDENTIAL	UNKNOWN	21.7	52.7	21.1	6.9	59.9
F02	R2	RESIDENTIAL	UNKNOWN	13.1	81	65.2	2.1	19.4
F02	R3	RESIDENTIAL	BEDROOM	7.3	96.2	2.2	6.9	97.7
F02	R4	RESIDENTIAL	BEDROOM	7.3	94	2.5	6.7	97.4
F02	R5	RESIDENTIAL	BEDROOM	7.3	96.4	3.4	6.8	96.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: LAMBERT HALL
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL40

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R6	RESIDENTIAL	BEDROOM	7.3	93	4.1	6.5	95.5
F02	R7	RESIDENTIAL	BEDROOM	7.3	96.8	4.8	6.7	95.1
F02	R8	RESIDENTIAL	BEDROOM	7.3	88.6	6.4	6.0	92.8
F02	R9	RESIDENTIAL	BEDROOM	7.3	96.3	5.1	6.7	94.8
F02	R10	RESIDENTIAL	BEDROOM	7.3	85.4	9	5.6	89.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL41

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R11	RESIDENTIAL	BEDROOM	7.3	92.8	6.2	6.3	93.4
F02	R12	RESIDENTIAL	BEDROOM	7.3	89.4	13.1	5.6	85.4
F02	R13	RESIDENTIAL	BEDROOM	7.3	87.8	7.8	5.8	91.1
F02	R14	RESIDENTIAL	BEDROOM	7.3	87.9	19.2	5.0	78.2
F02	R15	RESIDENTIAL	BEDROOM	7.3	87	10.8	5.6	87.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL42

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F02



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R16	RESIDENTIAL	BEDROOM	7.3	90.6	41.7	3.6	53.9
F02	R17	RESIDENTIAL	BEDROOM	7.4	84.9	28.4	4.2	66.6
F02	R18	RESIDENTIAL	BEDROOM	7.3	91.7	68.4	1.7	25.4
F02	R19	RESIDENTIAL	BEDROOM	7.7	82.3	53.7	2.2	34.8

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL43

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F03



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R1	RESIDENTIAL	UNKNOWN	21.7	53.3	23.3	6.5	56.2
F03	R2	RESIDENTIAL	UNKNOWN	13.1	81.8	67.5	1.9	17.4
F03	R3	RESIDENTIAL	BEDROOM	7.3	96.3	4	6.8	95.9
F03	R4	RESIDENTIAL	BEDROOM	7.3	94.4	3.9	6.6	95.8
F03	R5	RESIDENTIAL	BEDROOM	7.3	96.5	4.6	6.7	95.3

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL44

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R6	RESIDENTIAL	BEDROOM	7.3	93	4.6	6.5	95.1
F03	R7	RESIDENTIAL	BEDROOM	7.3	96.8	5.8	6.7	94
F03	R8	RESIDENTIAL	BEDROOM	7.3	88.7	7.4	5.9	91.7
F03	R9	RESIDENTIAL	BEDROOM	7.3	96.3	6.4	6.6	93.4
F03	R10	RESIDENTIAL	BEDROOM	7.3	85.4	10.2	5.5	88

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL45

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R11	RESIDENTIAL	BEDROOM	7.3	92.8	7.2	6.3	92.2
F03	R12	RESIDENTIAL	BEDROOM	7.3	89.5	13.7	5.5	84.7
F03	R13	RESIDENTIAL	BEDROOM	7.3	87.9	8.7	5.8	90.1
F03	R14	RESIDENTIAL	BEDROOM	7.3	88.2	19.8	5.0	77.5
F03	R15	RESIDENTIAL	BEDROOM	7.3	87	11.8	5.5	86.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL46

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R16	RESIDENTIAL	BEDROOM	7.3	90.6	41.8	3.6	53.8
F03	R17	RESIDENTIAL	BEDROOM	7.4	84.8	28.5	4.2	66.4
F03	R18	RESIDENTIAL	BEDROOM	7.3	91.7	68.8	1.7	25
F03	R19	RESIDENTIAL	BEDROOM	7.7	82.3	53.8	2.2	34.6

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL47

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R1	RESIDENTIAL	UNKNOWN	21.7	55	30.3	5.4	44.9
F04	R2	RESIDENTIAL	UNKNOWN	13.1	84.3	72.4	1.6	14.1
F04	R3	RESIDENTIAL	BEDROOM	7.3	96.2	4.9	6.7	94.9
F04	R4	RESIDENTIAL	BEDROOM	7.3	94.9	4.6	6.6	95.1
F04	R5	RESIDENTIAL	BEDROOM	7.3	96.4	5.7	6.6	94.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL48

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R6	RESIDENTIAL	BEDROOM	7.3	93.1	6.1	6.4	93.5
F04	R7	RESIDENTIAL	BEDROOM	7.3	96.8	7	6.6	92.8
F04	R8	RESIDENTIAL	BEDROOM	7.3	88.6	9.2	5.8	89.6
F04	R9	RESIDENTIAL	BEDROOM	7.3	96.2	7.9	6.5	91.8
F04	R10	RESIDENTIAL	BEDROOM	7.3	85.4	11.5	5.4	86.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL49

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R11	RESIDENTIAL	BEDROOM	7.3	92.8	8.8	6.1	90.6
F04	R12	RESIDENTIAL	BEDROOM	7.3	89.5	15.3	5.4	82.9
F04	R13	RESIDENTIAL	BEDROOM	7.3	87.9	9.9	5.7	88.7
F04	R14	RESIDENTIAL	BEDROOM	7.3	88.3	21.4	4.9	75.8
F04	R15	RESIDENTIAL	BEDROOM	7.3	87.1	12.6	5.4	85.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL50

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R16	RESIDENTIAL	BEDROOM	7.3	90.6	42	3.6	53.6
F04	R17	RESIDENTIAL	BEDROOM	7.4	84.8	28.7	4.1	66.2
F04	R18	RESIDENTIAL	BEDROOM	7.3	91.7	68.7	1.7	25
F04	R19	RESIDENTIAL	BEDROOM	7.7	82.3	53.9	2.2	34.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL51

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R1	RESIDENTIAL	UNKNOWN	21.7	62.4	45.6	3.6	26.9
F05	R2	RESIDENTIAL	UNKNOWN	13.1	90.1	82.4	1.0	8.5
F05	R3	RESIDENTIAL	BEDROOM	7.3	96.2	5.3	6.7	94.5
F05	R4	RESIDENTIAL	BEDROOM	7.3	95.5	5	6.6	94.8
F05	R5	RESIDENTIAL	BEDROOM	7.3	96.4	6.4	6.6	93.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL52

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R6	RESIDENTIAL	BEDROOM	7.3	94	7.5	6.3	92.1
F05	R7	RESIDENTIAL	BEDROOM	7.3	96.8	8.1	6.5	91.6
F05	R8	RESIDENTIAL	BEDROOM	7.3	88.7	10.7	5.7	88
F05	R9	RESIDENTIAL	BEDROOM	7.3	96.2	9.2	6.4	90.5
F05	R10	RESIDENTIAL	BEDROOM	7.3	85.4	12.9	5.3	84.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL53

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R11	RESIDENTIAL	BEDROOM	7.3	92.8	10.2	6.0	89
F05	R12	RESIDENTIAL	BEDROOM	7.3	89.5	16.7	5.3	81.3
F05	R13	RESIDENTIAL	BEDROOM	7.3	87.9	11.2	5.6	87.3
F05	R14	RESIDENTIAL	BEDROOM	7.3	88.3	22.6	4.8	74.4
F05	R15	RESIDENTIAL	BEDROOM	7.3	87.1	13.7	5.4	84.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL54

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R16	RESIDENTIAL	BEDROOM	7.3	90.6	42.2	3.5	53.5
F05	R17	RESIDENTIAL	BEDROOM	7.4	84.8	28.8	4.1	66
F05	R18	RESIDENTIAL	BEDROOM	7.3	91.7	68.8	1.7	24.9
F05	R19	RESIDENTIAL	BEDROOM	7.7	82.3	53.9	2.2	34.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL55

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R1	RESIDENTIAL	UNKNOWN	21.7	80.3	73.8	1.4	8.1
F06	R2	RESIDENTIAL	UNKNOWN	13.1	98.7	94.8	0.5	3.9
F06	R3	RESIDENTIAL	BEDROOM	7.3	96.2	6.3	6.6	93.5
F06	R4	RESIDENTIAL	BEDROOM	7.3	96.5	7.1	6.5	92.6
F06	R5	RESIDENTIAL	BEDROOM	7.3	96.5	7.2	6.5	92.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL56

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R6	RESIDENTIAL	BEDROOM	7.3	94.4	9.8	6.2	89.6
F06	R7	RESIDENTIAL	BEDROOM	7.3	96.8	10.1	6.3	89.6
F06	R8	RESIDENTIAL	BEDROOM	7.3	88.9	13	5.5	85.3
F06	R9	RESIDENTIAL	BEDROOM	7.3	96.3	11.8	6.2	87.8
F06	R10	RESIDENTIAL	BEDROOM	7.3	85.5	15.4	5.1	82

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL57

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R11	RESIDENTIAL	BEDROOM	7.3	92.9	12.7	5.9	86.3
F06	R12	RESIDENTIAL	BEDROOM	7.3	89.5	19.5	5.1	78.2
F06	R13	RESIDENTIAL	BEDROOM	7.3	87.9	13.9	5.4	84.2
F06	R14	RESIDENTIAL	BEDROOM	7.3	88.4	24.7	4.7	72.1
F06	R15	RESIDENTIAL	BEDROOM	7.3	87.1	15.1	5.3	82.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL58

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R16	RESIDENTIAL	BEDROOM	7.3	90.6	42.4	3.5	53.2
F06	R17	RESIDENTIAL	BEDROOM	7.4	84.8	29	4.1	65.8
F06	R18	RESIDENTIAL	BEDROOM	7.3	91.7	68.9	1.7	24.9
F06	R19	RESIDENTIAL	BEDROOM	7.7	82.5	54.3	2.2	34.2



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL59

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F00	R1	RESIDENTIAL	BEDROOM	14.8	64.4	64.4	0.0	0
F00	R2	RESIDENTIAL	LKD	19.1	60.4	60.4	0.0	0.1
F01	R1	RESIDENTIAL	BEDROOM	14.8	78.8	78.8	0.0	0
F01	R2	RESIDENTIAL	LKD	19.1	75.4	75.3	0.0	0.1
F01	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F01	R4	RESIDENTIAL	LKD	22.9	92.3	92.3	0.0	0
F02	R1	RESIDENTIAL	BEDROOM	14.8	83.1	83.1	0.0	0
F02	R2	RESIDENTIAL	LKD	19.1	85.1	85	0.0	0.1


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL60

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F02	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F02	R4	RESIDENTIAL	LKD	22.9	99.2	99.2	0.0	0
F03	R1	RESIDENTIAL	BEDROOM	14.8	90.7	90.7	0.0	0
F03	R2	RESIDENTIAL	LKD	19.1	94.8	94.7	0.0	0.1
F03	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F03	R4	RESIDENTIAL	LKD	22.9	99.2	99.2	0.0	0
F04	R1	RESIDENTIAL	BEDROOM	14.8	100	100	0.0	0
F04	R2	RESIDENTIAL	LKD	19.1	100	99.9	0.0	0.1



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: EXISTING VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 05/04/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS02-NSL61

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F04	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F04	R4	RESIDENTIAL	LKD	22.9	99.2	99.1	0.0	0.1
F05	R1	RESIDENTIAL	BEDROOM	14.8	100	99.9	0.0	0.1
F05	R2	RESIDENTIAL	LKD	19.1	100	99.9	0.0	0.1
F05	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F05	R4	RESIDENTIAL	LKD	22.9	99.1	98.9	0.0	0.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
REPORT TITLE: EXISTING VS. PROPOSED
ADDRESS: STONEBRIDGE HOUSE
DATE: 05/04/2023
SCHEME IR: IR016
DRAWING No.: 0298-REL06-IS02-NSL62



KEY:

GAIN

LOSS

MAINTAINED LIT AREA

1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F06	R1	RESIDENTIAL	BEDROOM	14.8	96.8	96.7	0.0	0.1
F06	R2	RESIDENTIAL	LKD	19.1	98.9	98.7	0.0	0.2
F06	R3	RESIDENTIAL	BEDROOM	15.2	97.6	96.7	0.1	0.9
F06	R4	RESIDENTIAL	LKD	22.9	98.5	98	0.1	0.4

					VSC (WINDOW)					NSL					APSH (ROOM)								
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX		PR.		LOSS %		MEETS CRITERIA		
					%	%		%		%	%	SQM	%		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER			
LONDON ROAD FIRE STATION																							
F01	R11	HOTEL	BEDROOM	W24/F01	18.6	18.4	0.2	11%	YES	86.7	86.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W25/F01	18.7	18.3	0.4	21%	YES														
			BEDROOM	W26/F01	20.6	20.3	0.3	15%	YES														
	R12	HOTEL	BEDROOM	W27/F01	21.7	21.4	0.3	14%	YES	88.2	87.9	0.1	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W28/F01	22	21.6	0.4	18%	YES														
			BEDROOM	W29/F01	22.4	22.1	0.3	13%	YES	96.1	96.1	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W30/F01	22.9	22.7	0.2	0.9%	YES														
F02	R10	HOTEL	BEDROOM	W23/F02	23.7	23.4	0.3	13%	YES	81.3	80.5	0.1	10%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W24/F02	23.8	23.4	0.4	17%	YES														
			BEDROOM	W25/F02	23.8	23.4	0.4	17%	YES	82.2	82.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W26/F02	23.7	23.4	0.3	13%	YES														
			BEDROOM	W27/F02	23.9	23.6	0.3	13%	YES	86.2	86.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W28/F02	24.2	23.9	0.3	12%	YES														
	R13	HOTEL	BEDROOM	W29/F02	24.6	24.3	0.3	12%	YES	96.8	96.8	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W30/F02	25	24.7	0.3	12%	YES														
F03	R10	HOTEL	BEDROOM	W33/F03	25.5	25.1	0.4	16%	YES	83.7	83.5	0.0	0.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W34/F03	25.6	25.2	0.4	16%	YES														
			BEDROOM	W35/F03	25.6	25.2	0.4	16%	YES	92.2	90	0.4	2.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W36/F03	25.5	25.2	0.3	12%	YES														
			BEDROOM	W37/F03	23.1	22.7	0.4	17%	YES	69.5	67.6	0.4	2.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			BEDROOM	W38/F03	23.8	23.4	0.4	17%	YES	68.7	66.9	0.2	2.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
FAIRFIELD HOUSE																							
F00	R1	RESIDENTIAL	UNKNOWN	W1/F00	9.3	9	0.3	3.2%	YES	63.2	63.1	0.1	0.2%	YES	30	0	29	0	3.3%	0.0%	YES		
			UNKNOWN	W2/F00	9.9	9.6	0.3	3.0%	YES														
			UNKNOWN	W3/F00	10.9	10.8	0.1	0.9%	YES														
			UNKNOWN	W4/F00	11.5	11.4	0.1	0.9%	YES														
			UNKNOWN	W16/F00	17.4	17.4	0	0.0%	YES														
			UNKNOWN	W17/F00	17.4	17.4	0	0.0%	YES														
			UNKNOWN	W18/F00	17	17	0	0.0%	YES														
			R2 (3)	RESIDENTIAL	UNKNOWN	W5/F00	7	6.9	0.1	1.4%	YES	22.7	21.7	0.3	4.6%	YES	1	0	0	0	100.0%	0.0%	YES
			FAIRFIELD HOUSE (CONTINUED)																				
			UNKNOWN	W6/F00	6.5	6.3	0.2	3.1%	YES														
	R3	RESIDENTIAL	UNKNOWN	W7/F00	8	7.7	0.3	3.7%	YES	71.1	70.6	0.1	0.8%	YES	21	1	20	1	4.8%	0.0%	YES		

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%	%	%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
			UNKNOWN	W8/F00	4.4	41	0.3	6.8%	YES												
			UNKNOWN	W9/F00	5.2	5	0.2	3.8%	YES												
	R4	RESIDENTIAL	UNKNOWN	W10/F00	7.5	7.3	0.2	2.7%	YES	58.5	56.8	0.3	2.9%	YES	32	4	31	3	3.1%	25.0%	YES
			UNKNOWN	W11/F00	9.6	9.4	0.2	2.1%	YES												
	R5	RESIDENTIAL	UNKNOWN	W12/F00	14	13.9	0.1	0.7%	YES	80	80	0.0	0.0%	YES	41	6	41	6	0.0%	0.0%	YES
			UNKNOWN	W13/F00	13.9	13.8	0.1	0.7%	YES												
			UNKNOWN	W14/F00	18.6	18.6	0	0.0%	YES												
			UNKNOWN	W15/F00	17.2	17.2	0	0.0%	YES												
F01	R1	RESIDENTIAL	UNKNOWN	W1/F01	10.8	10.4	0.4	3.7%	YES	62.8	62.8	0.0	0.0%	YES	25	1	24	1	4.0%	0.0%	YES
			UNKNOWN	W2/F01	11.4	11.1	0.3	2.6%	YES												
			UNKNOWN	W20/F01	20	20	0	0.0%	YES												
			UNKNOWN	W21/F01	20	20	0	0.0%	YES												
			UNKNOWN	W22/F01	19.1	19.1	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F01	12.5	12.4	0.1	0.8%	YES	42.5	42.1	0.0	0.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F01	13.2	13.1	0.1	0.8%	YES	41.9	41.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F01	13.3	13.2	0.1	0.8%	YES	29	29	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W6/F01	13	12.9	0.1	0.8%	YES	40	40	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F01	12.5	12.4	0.1	0.8%	YES	42.1	42.1	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F01	11.4	11.3	0.1	0.9%	YES	41	41	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F01	9.8	9.7	0.1	1.0%	YES	35.9	35.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F01	8.1	8	0.1	1.2%	YES	26.3	24.6	0.1	6.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W11/F01	7.5	7.2	0.3	4.0%	YES	23.7	21.3	0.2	10.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F01	8.8	8.5	0.3	3.4%	YES	68.6	68.5	0.0	0.2%	YES	24	2	24	2	0.0%	0.0%	YES
			UNKNOWN	W13/F01	4.8	4.5	0.3	6.2%	YES												
			UNKNOWN	W14/F01	5.7	5.6	0.1	1.8%	YES												
	R12	RESIDENTIAL	BEDROOM	W15/F01	8.4	8.2	0.2	2.4%	YES	24.4	23.3	0.1	4.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F01	10.8	10.6	0.2	1.9%	YES	31.1	29.7	0.1	4.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F01	15.7	15.6	0.1	0.6%	YES	87.6	87.6	0.0	0.0%	YES	43	8	43	8	0.0%	0.0%	YES
			UNKNOWN	W18/F01	15.8	15.7	0.1	0.6%	YES												
FAIRFIELD HOUSE (CONTINUED)																					
			UNKNOWN	W19/F01	22.6	22.6	0	0.0%	YES												
F02	R1	RESIDENTIAL	UNKNOWN	W1/F02	12.8	12.3	0.5	3.9%	YES	71.4	71.4	0.0	0.0%	YES	26	1	25	1	3.8%	0.0%	YES
			UNKNOWN	W2/F02	13.5	13.1	0.4	3.0%	YES												
			UNKNOWN	W20/F02	22.7	22.7	0	0.0%	YES												
			UNKNOWN	W21/F02	22.7	22.7	0	0.0%	YES												

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 2

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX		PR.		LOSS %		MEETS CRITERIA	
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER		
			UNKNOWN	W22/F02	21.7	21.7	0	0.0%	YES													
	R2	RESIDENTIAL	BEDROOM	W3/F02	14.8	14.5	0.3	2.0%	YES	57.5	57	0.0	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R3	RESIDENTIAL	BEDROOM	W4/F02	15.6	15.4	0.2	1.3%	YES	57.3	57.1	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F02	15.7	15.6	0.1	0.6%	YES	40.9	40.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W6/F02	15.3	15.2	0.1	0.7%	YES	55.7	55.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F02	14.6	14.5	0.1	0.7%	YES	60.3	60.3	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F02	13.2	13.1	0.1	0.8%	YES	51.2	51.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F02	11.4	11.2	0.2	1.8%	YES	47.4	47.4	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F02	9.6	9.5	0.1	1.0%	YES	32.1	30.4	0.1	5.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W11/F02	8.9	8.6	0.3	3.4%	YES	33	29.9	0.2	9.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F02	10	9.7	0.3	3.0%	YES	72	71.7	0.0	0.4%	YES	25	2	24	2	4.0%	0.0%	YES	
			UNKNOWN	W13/F02	5.1	4.9	0.2	3.9%	YES													
			UNKNOWN	W14/F02	6.2	6	0.2	3.2%	YES													
	R12	RESIDENTIAL	BEDROOM	W15/F02	9.3	9	0.3	3.2%	YES	24.8	23.5	0.1	5.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W16/F02	12	11.8	0.2	1.7%	YES	31.9	30.2	0.2	5.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	UNKNOWN	W17/F02	17.3	17.2	0.1	0.6%	YES	93.6	93.6	0.0	0.0%	YES	45	8	44	8	2.2%	0.0%	YES	
			UNKNOWN	W18/F02	17.7	17.6	0.1	0.6%	YES													
			UNKNOWN	W19/F02	27.3	27.3	0	0.0%	YES													
F03	R1	RESIDENTIAL	UNKNOWN	W1/F03	15.4	14.9	0.5	3.2%	YES	82.8	82.7	0.0	0.0%	YES	29	2	28	2	3.4%	0.0%	YES	
			UNKNOWN	W2/F03	16.1	15.6	0.5	3.1%	YES													
			UNKNOWN	W20/F03	25.7	25.7	0	0.0%	YES													
			UNKNOWN	W21/F03	25.7	25.7	0	0.0%	YES													
			UNKNOWN	W22/F03	24.1	24.1	0	0.0%	YES													
	R2	RESIDENTIAL	BEDROOM	W3/F03	17.4	17	0.4	2.3%	YES	70.5	68.7	0.1	2.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R3	RESIDENTIAL	BEDROOM	W4/F03	18.3	17.9	0.4	2.2%	YES	72.6	71.7	0.1	1.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F03	18.5	18.3	0.2	1.1%	YES	54.5	54.4	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
FAIRFIELD HOUSE (CONTINUED)																						
	R5	RESIDENTIAL	BEDROOM	W6/F03	17.9	17.8	0.1	0.6%	YES	69.8	69.8	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F03	16.9	16.8	0.1	0.6%	YES	77.5	77.5	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F03	15.2	15	0.2	1.3%	YES	60.9	60.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F03	13.3	13.2	0.1	0.8%	YES	55.3	55.3	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F03	11.5	11.4	0.1	0.9%	YES	34.2	33.5	0.0	2.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W11/F03	10.6	10.3	0.3	2.8%	YES	38.1	34.7	0.3	9.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F03	11.5	11.1	0.4	3.5%	YES	73.3	73.1	0.0	0.2%	YES	27	3	25	3	7.4%	0.0%	YES	
			UNKNOWN	W13/F03	5.4	5.1	0.3	5.6%	YES													

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
			UNKNOWN	W14/F03	6.5	6.3	0.2	3.1%	YES												
	R12	RESIDENTIAL	BEDROOM	W15/F03	9.7	9.5	0.2	2.1%	YES	24.9	23.6	0.1	5.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F03	12.7	12.5	0.2	1.6%	YES	32.3	30.3	0.2	6.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F03	18.6	18.5	0.1	0.5%	YES	94.2	94.2	0.0	0.0%	YES	46	9	45	9	2.2%	0.0%	YES
			UNKNOWN	W18/F03	19.4	19.3	0.1	0.5%	YES												
			UNKNOWN	W19/F03	32.1	32.1	0	0.0%	YES												
F04	R1	RESIDENTIAL	UNKNOWN	W1/F04	18.7	18.2	0.5	2.7%	YES	88.6	88.6	0.0	0.0%	YES	36	2	34	2	5.6%	0.0%	YES
			UNKNOWN	W2/F04	19.4	18.9	0.5	2.6%	YES												
			UNKNOWN	W20/F04	28.5	28.5	0	0.0%	YES												
			UNKNOWN	W21/F04	28.5	28.5	0	0.0%	YES												
			UNKNOWN	W22/F04	27	27	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F04	20.5	20	0.5	2.4%	YES	79.1	77.8	0.1	1.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F04	21.3	20.8	0.5	2.3%	YES	83.3	82.1	0.1	1.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F04	21.5	21.1	0.4	1.9%	YES	67.1	66.6	0.0	0.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W6/F04	20.6	20.4	0.2	1.0%	YES	75	74.8	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W7/F04	19.3	19.2	0.1	0.5%	YES	82	82	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W8/F04	17.4	17.3	0.1	0.6%	YES	63.4	63.3	0.0	0.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W9/F04	15.6	15.4	0.2	1.3%	YES	59.3	58.5	0.1	1.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F04	13.8	13.5	0.3	2.2%	YES	38.8	36.4	0.2	6.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM	W11/F04	12.8	12.4	0.4	3.1%	YES	40	38.1	0.1	4.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	UNKNOWN	W12/F04	13.4	13	0.4	3.0%	YES	73.9	73.5	0.1	0.5%	YES	27	3	25	3	7.4%	0.0%	YES
			UNKNOWN	W13/F04	5.6	5.3	0.3	5.4%	YES												
			UNKNOWN	W14/F04	6.8	6.6	0.2	2.9%	YES												
FAIRFIELD HOUSE (CONTINUED)																					
	R12	RESIDENTIAL	BEDROOM	W15/F04	10	9.8	0.2	2.0%	YES	25	23.7	0.1	5.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W16/F04	13	12.8	0.2	1.5%	YES	32.4	30.4	0.2	6.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R14	RESIDENTIAL	UNKNOWN	W17/F04	19.1	19	0.1	0.5%	YES	97.4	97.4	0.0	0.0%	YES	47	10	46	10	2.1%	0.0%	YES
			UNKNOWN	W18/F04	19.9	19.9	0	0.0%	YES												
			UNKNOWN	W19/F04	35.4	35.4	0	0.0%	YES												
F05	R1	RESIDENTIAL	UNKNOWN	W1/F05	23	22.5	0.5	2.2%	YES	95.6	95.6	0.0	0.0%	YES	41	5	38	3	7.3%	40.0%	YES
			UNKNOWN	W2/F05	23.5	23	0.5	2.1%	YES												
			UNKNOWN	W20/F05	30.8	30.8	0	0.0%	YES												
			UNKNOWN	W21/F05	30.8	30.8	0	0.0%	YES												
			UNKNOWN	W22/F05	29.7	29.7	0	0.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F05	24.1	23.6	0.5	2.1%	YES	89.3	87.2	0.1	2.3%	YES		N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX	PR	LOSS	LOSS	MEETS	EX	PR	LOSS	LOSS	MEETS	EX		PR		LOSS %		MEETS CRITERIA	
					%	%		%	CRITERIA		%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL		WINTER
	R3	RESIDENTIAL	BEDROOM	W4/F05	24.5	23.9	0.6	2.4%	YES	93.6	91.7	0.1	2.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F05	24.3	23.7	0.6	2.5%	YES	84.1	82.9	0.1	15%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W6/F05	23.4	22.8	0.6	2.6%	YES	83.1	81.1	0.1	2.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F05	22.1	21.7	0.4	1.8%	YES	89.3	88.4	0.1	10%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F05	20.2	19.8	0.4	2.0%	YES	69.5	68.2	0.1	1.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F05	18.4	18	0.4	2.2%	YES	66.5	65	0.1	2.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F05	16.7	16.2	0.5	3.0%	YES	46.5	44.6	0.1	4.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W11/F05	15.6	15.1	0.5	3.2%	YES	50.5	49.1	0.1	2.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F05	15.9	15.4	0.5	3.1%	YES	75	74.6	0.1	0.5%	YES	28	4	27	4	3.6%	0.0%	YES	
			UNKNOWN	W13/F05	5.9	5.6	0.3	5.1%	YES													
			UNKNOWN	W14/F05	7	6.8	0.2	2.9%	YES													
	R12	RESIDENTIAL	BEDROOM	W15/F05	10.3	10	0.3	2.9%	YES	25.3	23.7	0.2	6.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W16/F05	13.3	13.1	0.2	15%	YES	32.4	30.5	0.2	6.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	UNKNOWN	W17/F05	19.4	19.3	0.1	0.5%	YES	97.4	97.4	0.0	0.0%	YES	48	11	47	11	2.1%	0.0%	YES	
			UNKNOWN	W18/F05	20.3	20.2	0.1	0.5%	YES													
			UNKNOWN	W19/F05	36.5	36.5	0	0.0%	YES													
F06	R1	RESIDENTIAL	UNKNOWN	W1/F06	26.9	26.3	0.6	2.2%	YES	100	100	0.0	0.0%	YES	46	4	45	3	2.2%	25.0%	YES	
			UNKNOWN	W2/F06	27	26.5	0.5	1.9%	YES													
			UNKNOWN	W20/F06	32.5	32.5	0	0.0%	YES													
			UNKNOWN	W21/F06	32.5	32.5	0	0.0%	YES													
FAIRFIELD HOUSE (CONTINUED)																						
			UNKNOWN	W22/F06	32.1	32.1	0	0.0%	YES													
	R2	RESIDENTIAL	BEDROOM	W3/F06	26.9	26.3	0.6	2.2%	YES	91.1	87.7	0.2	3.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R3	RESIDENTIAL	BEDROOM	W4/F06	26.7	26.1	0.6	2.2%	YES	93.8	92.4	0.1	15%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F06	26.3	25.7	0.6	2.3%	YES	88.7	88	0.1	0.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W6/F06	25.6	24.9	0.7	2.7%	YES	88.6	85.8	0.2	3.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F06	24.5	23.9	0.6	2.4%	YES	95.1	94.6	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F06	23	22.4	0.6	2.6%	YES	84.3	81.3	0.2	3.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F06	21.5	20.9	0.6	2.8%	YES	83.8	81.8	0.1	2.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F06	19.9	19.3	0.6	3.0%	YES	70.3	68.3	0.1	2.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W11/F06	18.9	18.4	0.5	2.6%	YES	82.4	80.8	0.1	1.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F06	18.9	18.3	0.6	3.2%	YES	77.2	76.5	0.1	0.8%	YES	31	4	31	4	0.0%	0.0%	YES	
			UNKNOWN	W13/F06	6.1	5.7	0.4	6.6%	YES													
			UNKNOWN	W14/F06	7.2	6.9	0.3	4.2%	YES													
	R12	RESIDENTIAL	BEDROOM	W15/F06	10.5	10.2	0.3	2.9%	YES	25.5	23.9	0.2	6.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER		
	R13	RESIDENTIAL	BEDROOM	W16/F06	13.5	13.3	0.2	15%	YES	32.8	30.5	0.2	6.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	UNKNOWN	W17/F06	19.7	19.5	0.2	10%	YES	97.4	97.4	0.0	0.0%	YES	50	12	49	12	2.0%	0.0%	YES	
			UNKNOWN	W18/F06	20.6	20.5	0.1	0.5%	YES													
			UNKNOWN	W19/F06	37	37	0	0.0%	YES													
F07	R1	RESIDENTIAL	UNKNOWN	W1/F07	30	29.4	0.6	2.0%	YES	100	100	0.0	0.0%	YES	51	7	48	5	5.9%	28.6%	YES	
			UNKNOWN	W2/F07	29.6	29	0.6	2.0%	YES													
			UNKNOWN	W20/F07	33.4	33.4	0	0.0%	YES													
			UNKNOWN	W21/F07	33.5	33.5	0	0.0%	YES													
			UNKNOWN	W22/F07	34.1	34.1	0	0.0%	YES													
	R2	RESIDENTIAL	BEDROOM	W3/F07	29.1	28.4	0.7	2.4%	YES	92	89.4	0.2	2.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R3	RESIDENTIAL	BEDROOM	W4/F07	28.6	27.9	0.7	2.4%	YES	93.8	93.1	0.1	0.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F07	28	27.3	0.7	2.5%	YES	94.3	94.1	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W6/F07	27.3	26.6	0.7	2.6%	YES	90	87.2	0.2	3.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W7/F07	26.7	26	0.7	2.6%	YES	95.1	95	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W8/F07	25.4	24.8	0.6	2.4%	YES	90.8	88.5	0.2	2.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W9/F07	24.3	23.6	0.7	2.9%	YES	94.5	93.7	0.1	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W10/F07	23.2	22.5	0.7	3.0%	YES	89	85.8	0.2	3.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
FAIRFIELD HOUSE (CONTINUED)																						
	R10	RESIDENTIAL	BEDROOM	W11/F07	22.5	21.9	0.6	2.7%	YES	93.2	91.8	0.1	1.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	UNKNOWN	W12/F07	22	21.4	0.6	2.7%	YES	85.7	85.3	0.1	0.5%	YES	36	4	36	4	0.0%	0.0%	YES	
			UNKNOWN	W13/F07	6.3	5.8	0.5	7.9%	YES													
			UNKNOWN	W14/F07	7.4	7.1	0.3	4.1%	YES													
	R12	RESIDENTIAL	BEDROOM	W15/F07	10.6	10.3	0.3	2.8%	YES	25.6	24.1	0.2	6.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W16/F07	13.7	13.5	0.2	15%	YES	32.9	30.6	0.2	7.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	UNKNOWN	W17/F07	19.8	19.7	0.1	0.5%	YES	97.4	97.4	0.0	0.0%	YES	50	12	49	12	2.0%	0.0%	YES	
			UNKNOWN	W18/F07	20.7	20.6	0.1	0.5%	YES													
			UNKNOWN	W19/F07	37.4	37.4	0	0.0%	YES													
F08	R1	RESIDENTIAL	UNKNOWN	W1/F08	31.3	30.7	0.6	1.9%	YES	100	100	0.0	0.0%	YES	52	7	49	5	5.8%	28.6%	YES	
			UNKNOWN	W12/F08	34.3	34.3	0	0.0%	YES													
			UNKNOWN	W13/F08	35	35	0	0.0%	YES													
	R2	RESIDENTIAL	BEDROOM	W2/F08	30.3	29.6	0.7	2.3%	YES	97.4	96.8	0.1	0.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R3	RESIDENTIAL	BEDROOM	W3/F08	29.4	28.7	0.7	2.4%	YES	96.6	96.5	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W4/F08	28.4	27.7	0.7	2.5%	YES	97	95.8	0.3	1.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W5/F08	26.7	26	0.7	2.6%	YES	97.4	96.5	0.2	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W6/F08	24.9	24.3	0.6	2.4%	YES	96.7	95.7	0.2	1.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%	%	%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
	R7	RESIDENTIAL	UNKNOWN	W7/F08	23.3	22.7	0.6	2.6%	YES	91.8	91.2	0.1	0.6%	YES	38	4	36	4	5.3%	0.0%	YES
			UNKNOWN	W8/F08	7	6.6	0.4	5.7%	YES												
	R8 (3)	RESIDENTIAL	UNKNOWN	W9/F08	12.2	11.9	0.3	2.5%	YES	61.8	60.4	0.4	2.3%	YES	34	6	34	6	0.0%	0.0%	YES
	R9	RESIDENTIAL	UNKNOWN	W10/F08	20.5	20.3	0.2	1.0%	YES	97.8	97.8	0.0	0.0%	YES	48	12	48	12	0.0%	0.0%	YES
			UNKNOWN	W11/F08	37.6	37.6	0	0.0%	YES												
LAMBERT HALL																					
B01	R1	RESIDENTIAL	UNKNOWN	W1/B01	4.8	4.7	0.1	2.1%	YES	6.4	6.3	0.0	1.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/B01	4.6	4.6	0	0.0%	YES												
	R2	RESIDENTIAL	UNKNOWN	W3/B01	6.1	6.1	0	0.0%	YES	49.8	49	0.2	1.6%	YES	15	0	15	0	0.0%	0.0%	YES
			UNKNOWN	W4/B01	7.3	7.2	0.1	1.4%	YES												
			UNKNOWN	W5/B01	2.6	2.4	0.2	7.7%	YES												
	R3	RESIDENTIAL	UNKNOWN	W6/B01	2.5	2.3	0.2	8.0%	YES	0	0	0.0	-	YES	11	1	11	1	0.0%	0.0%	YES
			UNKNOWN	W7/B01	2.4	2.2	0.2	8.3%	YES												
LAMBERT HALL (CONTINUED)																					
	R4	RESIDENTIAL	UNKNOWN	W8/B01	3	2.7	0.3	10.0%	YES	2.6	2.6	0.0	0.0%	YES	16	3	16	3	0.0%	0.0%	YES
			UNKNOWN	W9/B01	3.3	3	0.3	9.1%	YES												
	R5	RESIDENTIAL	UNKNOWN	W10/B01	3.7	3.3	0.4	10.8%	YES	7.6	6.9	0.2	9.1%	YES	20	4	20	4	0.0%	0.0%	YES
			UNKNOWN	W11/B01	3.9	3.6	0.3	7.7%	YES												
	R6	RESIDENTIAL	UNKNOWN	W12/B01	4.7	4.3	0.4	8.5%	YES	16.5	15.6	0.2	5.4%	YES	24	6	24	6	0.0%	0.0%	YES
			UNKNOWN	W13/B01	5.2	4.9	0.3	5.8%	YES												
	R7	RESIDENTIAL	UNKNOWN	W14/B01	6.6	6.3	0.3	4.5%	YES	31.4	31.3	0.0	0.5%	YES	27	7	26	7	3.7%	0.0%	YES
			UNKNOWN	W15/B01	7.6	7.4	0.2	2.6%	YES												
	R8	RESIDENTIAL	UNKNOWN	W16/B01	9.9	9.7	0.2	2.0%	YES	51.9	51.9	0.0	0.0%	YES	36	13	36	13	0.0%	0.0%	YES
			UNKNOWN	W17/B01	11.7	11.5	0.2	1.7%	YES												
F00	R1	RESIDENTIAL	UNKNOWN	W1/F00	5.6	5.6	0	0.0%	YES	14	13.9	0.0	0.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W2/F00	5.4	5.4	0	0.0%	YES												
	R2	RESIDENTIAL	UNKNOWN	W3/F00	6.9	6.9	0	0.0%	YES	61	60.7	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN	W4/F00	8.4	8.3	0.1	1.2%	YES												
	R3	RESIDENTIAL	BEDROOM	W5/F00	2.7	2.5	0.2	7.4%	YES	4	2.8	0.1	30.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F00	2.7	2.4	0.3	11.1%	YES	3.3	2.3	0.1	29.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F00	2.6	2.4	0.2	7.7%	YES	3.7	2.4	0.1	36.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F00	3.2	2.9	0.3	9.4%	YES	6.8	4.3	0.2	36.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM	W9/F00	3.5	3.1	0.4	11.4%	YES	5	3.1	0.1	37.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F00	3.9	3.5	0.4	10.3%	YES	9.2	7.4	0.1	19.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA		%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL		WINTER
	R9	RESIDENTIAL	BEDROOM	W11/F00	4.1	3.7	0.4	9.8%	YES	6.2	4.2	0.1	31.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F00	4.8	4.5	0.3	6.2%	YES	13	11.2	0.1	13.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F00	5.4	5.1	0.3	5.6%	YES	7.6	6.2	0.1	17.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F00	6.7	6.4	0.3	4.5%	YES	20.6	18.1	0.2	12.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F00	7.8	7.5	0.3	3.8%	YES	11	10.1	0.1	7.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F00	10.1	9.9	0.2	2.0%	YES	41.5	41.1	0.0	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F00	12	11.7	0.3	2.5%	YES	27.1	26.9	0.0	0.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F01	R1	RESIDENTIAL	UNKNOWN	W1/F01	7	6.9	0.1	1.4%	YES	17.3	17.1	0.0	0.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F01	6.7	6.7	0	0.0%	YES													
	R2	RESIDENTIAL	UNKNOWN	W3/F01	8.2	8.1	0.1	1.2%	YES	62.9	62.5	0.0	0.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F01	9.5	9.4	0.1	1.1%	YES													
LAMBERT HALL (CONTINUED)																						
	R3	RESIDENTIAL	BEDROOM	W5/F01	2.9	2.6	0.3	10.3%	YES	4.9	3.2	0.1	35.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F01	2.9	2.6	0.3	10.3%	YES	4	3	0.1	23.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W7/F01	2.9	2.6	0.3	10.3%	YES	4.6	3.2	0.1	31.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F01	3.1	2.7	0.4	12.9%	YES	4.9	3.6	0.1	26.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F01	3.3	2.8	0.5	15.2%	YES	5.8	4.1	0.1	29.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F01	3.6	3.1	0.5	13.9%	YES	7.9	5.4	0.2	31.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F01	3.8	3.3	0.5	13.2%	YES	6.4	4.2	0.2	33.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F01	4.2	3.7	0.5	11.9%	YES	10.2	8.1	0.2	20.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F01	4.4	3.9	0.5	11.4%	YES	7.3	5.2	0.2	29.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F01	5.1	4.6	0.5	9.8%	YES	14.1	12.2	0.1	13.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F01	5.7	5.2	0.5	8.8%	YES	8.8	6.9	0.1	20.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F01	6.9	6.6	0.3	4.3%	YES	21.2	18.6	0.2	12.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F01	8	7.6	0.4	5.0%	YES	11.6	10.7	0.1	7.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F01	10.3	10.1	0.2	1.9%	YES	41.8	41.5	0.0	0.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F01	12.3	12	0.3	2.4%	YES	28.5	28.5	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R18	RESIDENTIAL	BEDROOM	W20/F01	16.9	16.6	0.3	1.8%	YES	68.7	68.5	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F01	19.7	19.5	0.2	1.0%	YES	53.8	53.7	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F02	R1	RESIDENTIAL	UNKNOWN	W1/F02	8.8	8.8	0	0.0%	YES	21.3	21.1	0.0	0.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F02	8.5	8.5	0	0.0%	YES													
	R2	RESIDENTIAL	UNKNOWN	W3/F02	9.9	9.8	0.1	1.0%	YES	65.6	65.2	0.0	0.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F02	11.1	11	0.1	0.9%	YES													
	R3	RESIDENTIAL	BEDROOM	W5/F02	3	2.7	0.3	10.0%	YES	5.8	2.2	0.3	62.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F02	3.1	2.7	0.4	12.9%	YES	4.7	2.5	0.2	46.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX		PR.		LOSS %		MEETS CRITERIA	
					%	%		%		%	%	SQM	%		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER		
	R5	RESIDENTIAL	BEDROOM	W7/F02	3.1	2.7	0.4	12.9%	YES	5.6	3.4	0.2	39.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F02	3.3	2.9	0.4	12.1%	YES	6	4.1	0.1	30.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F02	3.5	3	0.5	14.3%	YES	6.8	4.8	0.1	29.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F02	3.9	3.3	0.6	15.4%	YES	8.9	6.4	0.2	28.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F02	4.2	3.5	0.7	16.7%	YES	7.7	5.1	0.2	34.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F02	4.5	3.9	0.6	13.3%	YES	11.4	9	0.2	21.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F02	4.7	4.1	0.6	12.8%	YES	8.7	6.2	0.2	29.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F02	5.4	4.8	0.6	11.1%	YES	15.4	13.1	0.2	14.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
LAMBERT HALL (CONTINUED)																						
	R13	RESIDENTIAL	BEDROOM	W15/F02	6	5.4	0.6	10.0%	YES	9.9	7.8	0.2	21.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F02	7.2	6.7	0.5	6.9%	YES	22.7	19.2	0.3	15.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F02	8.2	7.8	0.4	4.9%	YES	11.9	10.8	0.1	9.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F02	10.6	10.2	0.4	3.8%	YES	42	41.7	0.0	0.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F02	12.5	12.2	0.3	2.4%	YES	28.8	28.4	0.0	1.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R18	RESIDENTIAL	BEDROOM	W20/F02	17.1	16.9	0.2	1.2%	YES	68.8	68.4	0.0	0.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F02	20	19.8	0.2	1.0%	YES	53.9	53.7	0.0	0.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F03	R1	RESIDENTIAL	UNKNOWN	W1/F03	11.3	11.3	0	0.0%	YES	23.6	23.3	0.1	10%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F03	11	10.9	0.1	0.9%	YES													
	R2	RESIDENTIAL	UNKNOWN	W3/F03	12.1	12	0.1	0.8%	YES	67.8	67.5	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F03	13.1	13	0.1	0.8%	YES													
	R3	RESIDENTIAL	BEDROOM	W5/F03	3.2	2.9	0.3	9.4%	YES	6.1	4	0.2	34.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F03	3.2	2.9	0.3	9.4%	YES	5.9	3.9	0.1	33.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W7/F03	3.3	2.9	0.4	12.1%	YES	6.4	4.6	0.1	28.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F03	3.6	3.1	0.5	13.9%	YES	8.2	4.6	0.3	44.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F03	3.8	3.2	0.6	15.8%	YES	8.3	5.8	0.2	29.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F03	4.3	3.6	0.7	16.3%	YES	10.8	7.4	0.3	32.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F03	4.6	3.8	0.8	17.4%	YES	9.2	6.4	0.2	30.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F03	4.9	4.2	0.7	14.3%	YES	12.9	10.2	0.2	20.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F03	5.1	4.4	0.7	13.7%	YES	10.2	7.2	0.2	29.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F03	5.8	5.1	0.7	12.1%	YES	16.8	13.7	0.2	18.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F03	6.3	5.7	0.6	9.5%	YES	11.2	8.7	0.2	22.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F03	7.5	7	0.5	6.7%	YES	23.9	19.8	0.3	17.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F03	8.5	8	0.5	5.9%	YES	13	11.8	0.1	9.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F03	10.8	10.4	0.4	3.7%	YES	42.2	41.8	0.0	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F03	12.8	12.4	0.4	3.1%	YES	28.9	28.5	0.0	1.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA		%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL		WINTER
	R18	RESIDENTIAL	BEDROOM	W20/F03	17.4	17.1	0.3	17%	YES	68.9	68.8	0.0	0.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F03	20.3	20	0.3	15%	YES	54	53.8	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F04	R1	RESIDENTIAL	UNKNOWN	W1/F04	14.8	14.8	0	0.0%	YES	30.6	30.3	0.1	0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F04	14.4	14.4	0	0.0%	YES													
	R2	RESIDENTIAL	UNKNOWN	W3/F04	15.1	15	0.1	0.7%	YES	72.9	72.4	0.1	0.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
LAMBERT HALL (CONTINUED)																						
			UNKNOWN	W4/F04	15.9	15.7	0.2	1.3%	YES													
	R3	RESIDENTIAL	BEDROOM	W5/F04	3.5	3.1	0.4	11.4%	YES	7	4.9	0.1	29.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F04	3.5	3	0.5	14.3%	YES	7.5	4.6	0.2	38.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W7/F04	3.5	3.1	0.4	11.4%	YES	7	5.7	0.1	19.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F04	3.9	3.3	0.6	15.4%	YES	10.2	6.1	0.3	40.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F04	4.2	3.5	0.7	16.7%	YES	9.6	7	0.2	27.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F04	4.8	3.9	0.9	18.8%	YES	13.1	9.2	0.3	29.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F04	5.1	4.2	0.9	17.6%	YES	11.4	7.9	0.3	31.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F04	5.4	4.5	0.9	16.7%	YES	15.1	11.5	0.3	23.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F04	5.6	4.7	0.9	16.1%	YES	12.6	8.8	0.3	30.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F04	6.3	5.4	0.9	14.3%	YES	19.4	15.3	0.3	21.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F04	6.8	6	0.8	11.8%	YES	13.3	9.9	0.3	25.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F04	7.8	7.2	0.6	7.7%	YES	25.7	21.4	0.3	16.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F04	8.7	8.2	0.5	5.7%	YES	14.3	12.6	0.1	11.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F04	11	10.6	0.4	3.6%	YES	42.5	42	0.0	1.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F04	13.1	12.7	0.4	3.1%	YES	29	28.7	0.0	1.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R18	RESIDENTIAL	BEDROOM	W20/F04	17.7	17.4	0.3	1.7%	YES	69	68.7	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F04	20.6	20.3	0.3	1.5%	YES	54.3	53.9	0.0	0.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F05	R1	RESIDENTIAL	UNKNOWN	W1/F05	19.4	19.3	0.1	0.5%	YES	45.9	45.6	0.1	0.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F05	18.9	18.9	0	0.0%	YES													
	R2	RESIDENTIAL	UNKNOWN	W3/F05	19	19	0	0.0%	YES	82.5	82.4	0.0	0.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F05	19.3	19.2	0.1	0.5%	YES													
	R3	RESIDENTIAL	BEDROOM	W5/F05	3.7	3.3	0.4	10.8%	YES	7.4	5.3	0.2	28.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F05	3.7	3.2	0.5	13.5%	YES	8.7	5	0.3	42.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W7/F05	3.8	3.3	0.5	13.2%	YES	8	6.4	0.1	20.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F05	4.3	3.5	0.8	18.6%	YES	12.2	7.5	0.3	38.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F05	4.6	3.8	0.8	17.4%	YES	11.6	8.1	0.3	29.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F05	5.4	4.3	1.1	20.4%	NO	16.3	10.7	0.4	34.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F05	5.8	4.6	1.2	20.7%	NO	14	9.2	0.4	34.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX.	PR.	LOSS	LOSS	MEETS CRITERIA	EX.		PR.		LOSS %		MEETS CRITERIA	
					%	%		%		%	%	%	SQM		%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL		WINTER
	R10	RESIDENTIAL	BEDROOM	W12/F05	6.1	4.9	1.2	19.7%	YES	18.1	12.9	0.4	28.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F05	6.3	5.2	1.1	17.5%	YES	15.4	10.2	0.4	33.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
LAMBERT HALL (CONTINUED)																						
	R12	RESIDENTIAL	BEDROOM	W14/F05	6.9	5.8	1.1	15.9%	YES	22.4	16.7	0.4	25.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F05	7.3	6.4	0.9	12.3%	YES	16	11.2	0.4	30.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F05	8.2	7.5	0.7	8.5%	YES	27.9	22.6	0.4	19.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F05	9	8.5	0.5	5.6%	YES	15.6	13.7	0.1	12.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F05	11.3	10.8	0.5	4.4%	YES	42.9	42.2	0.1	1.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F05	13.4	12.9	0.5	3.7%	YES	29.2	28.8	0.0	1.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R18	RESIDENTIAL	BEDROOM	W20/F05	18	17.6	0.4	2.2%	YES	69	68.8	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F05	21	20.6	0.4	1.9%	YES	54.3	53.9	0.0	0.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
F06	R1	RESIDENTIAL	UNKNOWN	W1/F06	24	24	0	0.0%	YES	74	73.8	0.0	0.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W2/F06	23.5	23.4	0.1	0.4%	YES													
	R2	RESIDENTIAL	UNKNOWN	W3/F06	23	22.9	0.1	0.4%	YES	94.8	94.8	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			UNKNOWN	W4/F06	22.8	22.7	0.1	0.4%	YES													
	R3	RESIDENTIAL	BEDROOM	W5/F06	4	3.5	0.5	12.5%	YES	8.2	6.3	0.1	23.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W6/F06	4	3.4	0.6	15.0%	YES	10.4	7.1	0.2	31.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	BEDROOM	W7/F06	4.1	3.5	0.6	14.6%	YES	8.7	7.2	0.1	17.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	BEDROOM	W8/F06	4.6	3.8	0.8	17.4%	YES	14.7	9.8	0.4	33.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	BEDROOM	W9/F06	5.2	4.1	1.1	21.2%	NO	14.3	10.1	0.3	29.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R8	RESIDENTIAL	BEDROOM	W10/F06	6.1	4.8	1.3	21.3%	NO	20.5	13	0.5	36.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F06	6.7	5.2	1.5	22.4%	NO	18.1	11.8	0.5	35.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10	RESIDENTIAL	BEDROOM	W12/F06	6.9	5.5	1.4	20.3%	NO	22.8	15.4	0.5	32.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11	RESIDENTIAL	BEDROOM	W13/F06	7.1	5.7	1.4	19.7%	YES	20.2	12.7	0.5	37.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	BEDROOM	W14/F06	7.6	6.3	1.3	17.1%	YES	27.3	19.5	0.6	28.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R13	RESIDENTIAL	BEDROOM	W15/F06	8	6.8	1.2	15.0%	YES	20.8	13.9	0.5	33.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R14	RESIDENTIAL	BEDROOM	W16/F06	8.7	7.8	0.9	10.3%	YES	31.5	24.7	0.5	21.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R15	RESIDENTIAL	BEDROOM	W17/F06	9.4	8.7	0.7	7.4%	YES	17.7	15.1	0.2	14.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R16	RESIDENTIAL	BEDROOM	W18/F06	11.7	11.1	0.6	5.1%	YES	43.2	42.4	0.1	2.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R17	RESIDENTIAL	BEDROOM	W19/F06	13.7	13.2	0.5	3.6%	YES	29.6	29	0.0	1.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R18	RESIDENTIAL	BEDROOM	W20/F06	18.3	17.9	0.4	2.2%	YES	69.2	68.9	0.0	0.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R19	RESIDENTIAL	BEDROOM	W21/F06	21.3	20.9	0.4	1.9%	YES	54.4	54.3	0.0	0.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA	
STONEBRIDGE HOUSE																						
F00	R1	RESIDENTIAL	BEDROOM	W1/F00	9.1	9	0.1	11%	YES	64.4	64.4	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F00	7.7	7.7	0	0.0%	YES	60.4	60.4	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F00	5.3	5.3	0	0.0%	YES													
			LKD	W4/F00	7.9	7.8	0.1	1.3%	YES													
F01	R1	RESIDENTIAL	BEDROOM	W1/F01	11.5	11.4	0.1	0.9%	YES	78.8	78.8	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F01	9.9	9.9	0	0.0%	YES	75.3	75.3	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F01	8.3	8.3	0	0.0%	YES													
			LKD	W4/F01	7.9	7.8	0.1	1.3%	YES													
			LKD	W5/F01	0.1	0.1	0	0.0%	YES													
			LKD	W6/F01	9.1	9	0.1	11%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F01	14.3	14.2	0.1	0.7%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F01	14.3	14.3	0	0.0%	YES	92.3	92.3	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F01	13.5	13.5	0	0.0%	YES													
			LKD	W10/F01	13.1	13.1	0	0.0%	YES													
			LKD	W11/F01	14.3	14.3	0	0.0%	YES													
			LKD	W12/F01	12.7	12.7	0	0.0%	YES													
F02	R1	RESIDENTIAL	BEDROOM	W1/F02	14.8	14.6	0.2	1.4%	YES	83.1	83.1	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F02	12.6	12.6	0	0.0%	YES	85	85	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F02	10.6	10.6	0	0.0%	YES													
			LKD	W4/F02	10	9.9	0.1	1.0%	YES													
			LKD	W5/F02	0	0	0	-	YES													
			LKD	W6/F02	11.1	10.9	0.2	1.8%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F02	17.3	17.2	0.1	0.6%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F02	17.5	17.4	0.1	0.6%	YES	99.2	99.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F02	16.3	16.3	0	0.0%	YES													
			LKD	W10/F02	15.7	15.7	0	0.0%	YES													
			LKD	W11/F02	17.1	17.1	0	0.0%	YES													
			LKD	W12/F02	15	15	0	0.0%	YES													
F03	R1	RESIDENTIAL	BEDROOM	W1/F03	18.9	18.8	0.1	0.5%	YES	90.7	90.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F03	16.7	16.6	0.1	0.6%	YES	94.7	94.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F03	14.8	14.8	0	0.0%	YES													
STONEBRIDGE HOUSE (CONTINUED)																						
			LKD	W4/F03	14.5	14.3	0.2	1.4%	YES													
			LKD	W5/F03	0.3	0.3	0	0.0%	YES													

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS	
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA	
			LKD	W6/F03	15.3	15.1	0.2	1.3%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F03	20.6	20.4	0.2	1.0%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F03	20.6	20.5	0.1	0.5%	YES	99.2	99.2	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F03	19.5	19.5	0	0.0%	YES													
			LKD	W10/F03	18.7	18.7	0	0.0%	YES													
			LKD	W11/F03	20.4	20.3	0.1	0.5%	YES													
			LKD	W12/F03	17.6	17.6	0	0.0%	YES													
F04	R1	RESIDENTIAL	BEDROOM	W1/F04	22.7	22.5	0.2	0.9%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F04	20.1	20	0.1	0.5%	YES	99.9	99.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F04	18.3	18.3	0	0.0%	YES													
			LKD	W4/F04	17.9	17.7	0.2	1.1%	YES													
			LKD	W5/F04	0.6	0.6	0	0.0%	YES													
			LKD	W6/F04	18.3	18.1	0.2	1.1%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F04	23.1	22.9	0.2	0.9%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F04	23	22.8	0.2	0.9%	YES	99.2	99.1	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F04	22.4	22.2	0.2	0.9%	YES													
			LKD	W10/F04	21.9	21.7	0.2	0.9%	YES													
			LKD	W11/F04	20.7	20.7	0	0.0%	YES													
			LKD	W12/F04	22.5	22.3	0.2	0.9%	YES													
F05	R1	RESIDENTIAL	BEDROOM	W1/F05	19.7	19.7	0	0.0%	YES	99.9	99.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F05	14.8	14.8	0	0.0%	YES	99.9	99.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F05	15.2	15.2	0	0.0%	YES													
			LKD	W4/F05	14.4	14.4	0	0.0%	YES													
			LKD	W5/F05	1.4	1.4	0	0.0%	YES													
			LKD	W6/F05	12.5	12.5	0	0.0%	YES													
	R3	RESIDENTIAL	BEDROOM	W7/F05	18.3	18.2	0.1	0.5%	YES	100	100	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	LKD	W8/F05	16.8	16.8	0	0.0%	YES	98.9	98.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W9/F05	15.3	15.2	0.1	0.7%	YES													
			LKD	W10/F05	14	14	0	0.0%	YES													
STONEBRIDGE HOUSE (CONTINUED)																						
			LKD	W11/F05	12.9	12.9	0	0.0%	YES													
			LKD	W12/F05	1.5	1.5	0	0.0%	YES													
F06	R1	RESIDENTIAL	BEDROOM	W1/F06	4.3	4.3	0	0.0%	YES	96.7	96.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R2	RESIDENTIAL	LKD	W2/F06	4.2	4.2	0	0.0%	YES	98.7	98.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			LKD	W3/F06	7.1	7.1	0	0.0%	YES													

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	VSC (WINDOW)					NSL					APSH (ROOM)						
					EX.	PR.	LOSS	LOSS	MEETS	EX.	PR.	LOSS	LOSS	MEETS	EX.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
			LKD	W4/F06	7.1	7.1	0	0.0%	YES												
			LKD	W5/F06	4.2	4.2	0	0.0%	YES												
	R3	RESIDENTIAL	BEDROOM	W6/F06	4.2	4.2	0	0.0%	YES	96.7	96.7	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	LKD	W7/F06	4.1	4.1	0	0.0%	YES	98.1	98	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			LKD	W8/F06	6.8	6.7	0.1	15%	YES												
			LKD	W9/F06	6.7	6.7	0	0.0%	YES												
			LKD	W10/F06	6.4	6.4	0	0.0%	YES												
			LKD	W11/F06	0	0	0	-	YES												

WAREHOUSE ONE																					
B01	R1	RESIDENTIAL	UNKNOWN	W1/B01	5.8	5.7	0.1	1.7%	YES	15	14.8	0.0	0.8%	YES	12	0	12	0	0.0%	0.0%	YES
			UNKNOWN	W2/B01	5.9	5.8	0.1	1.7%	YES												
			UNKNOWN	W3/B01	6	5.9	0.1	1.7%	YES												
	R2	RESIDENTIAL	UNKNOWN	W4/B01	5.6	5.4	0.2	3.6%	YES	15.7	15.7	0.0	0.0%	YES	8	0	8	0	0.0%	0.0%	YES
			UNKNOWN	W5/B01	5.6	5.4	0.2	3.6%	YES												
F00	R1	RESIDENTIAL	UNKNOWN	W1/F00	10	9.9	0.1	1.0%	YES	40.6	40.5	0.0	0.1%	YES	20	0	20	0	0.0%	0.0%	YES
			UNKNOWN	W2/F00	7.1	6.9	0.2	2.8%	YES												
			UNKNOWN	W3/F00	7.3	7	0.3	4.1%	YES												
			UNKNOWN	W4/F00	7.4	7.2	0.2	2.7%	YES												
			UNKNOWN	W5/F00	7.5	7.3	0.2	2.7%	YES												
			UNKNOWN	W6/F00	7.6	7.3	0.3	3.9%	YES												
	R2	RESIDENTIAL	UNKNOWN	W7/F00	6.6	6.4	0.2	3.0%	YES	22	22	0.0	0.1%	YES	13	0	13	0	0.0%	0.0%	YES
			UNKNOWN	W8/F00	6.7	6.5	0.2	3.0%	YES												
	R3	RESIDENTIAL	UNKNOWN	W9/F00	6.5	6.4	0.1	1.5%	YES	16.4	16.3	0.0	0.6%	YES	9	0	9	0	0.0%	0.0%	YES
			UNKNOWN	W10/F00	6.3	6.1	0.2	3.2%	YES												
F01	R1	RESIDENTIAL	UNKNOWN	W1/F01	7.4	7.2	0.2	2.7%	YES	38.3	38	0.1	0.8%	YES	24	0	21	0	12.5%	0.0%	YES
WAREHOUSE ONE (CONTINUED)																					
			UNKNOWN	W10/F01	8.8	8.3	0.5	5.7%	YES												
			UNKNOWN	W11/F01	8.3	7.8	0.5	6.0%	YES												
	R2	RESIDENTIAL	UNKNOWN	W2/F01	12.5	12.4	0.1	0.8%	YES	47.6	47.3	0.1	0.7%	YES	30	1	29	1	3.3%	0.0%	YES
			UNKNOWN	W3/F01	9.5	8.9	0.6	6.3%	YES												
			UNKNOWN	W4/F01	9.7	9.1	0.6	6.2%	YES												
			UNKNOWN	W5/F01	9.9	9.3	0.6	6.1%	YES												
			UNKNOWN	W6/F01	10	9.4	0.6	6.0%	YES												
			UNKNOWN	W7/F01	10	9.4	0.6	6.0%	YES												

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	EX. %	PR. %	LOSS	LOSS %	MEETS CRITERIA	EX. %	PR. %	LOSS SQM	LOSS %	MEETS CRITERIA	EX.		PR.		LOSS %		MEETS CRITERIA
															ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
	R3	RESIDENTIAL	UNKNOWN	W8/F01	9	8.5	0.5	5.6%	YES	36.3	35.9	0.1	10%	YES	25	0	24	0	4.0%	0.0%	YES
F02			UNKNOWN	W9/F01	9	8.5	0.5	5.6%	YES												
	R1	RESIDENTIAL	UNKNOWN	W1/F02	10.7	10.5	0.2	19%	YES	60.8	60.4	0.1	0.6%	YES	32	1	29	1	9.4%	0.0%	YES
			UNKNOWN	W10/F02	11.3	10.6	0.7	6.2%	YES												
			UNKNOWN	W11/F02	11.1	10.3	0.8	7.2%	YES												
	R2	RESIDENTIAL	UNKNOWN	W2/F02	16.6	16.5	0.1	0.6%	YES	71.9	70	0.6	2.6%	YES	41	3	39	3	4.9%	0.0%	YES
			UNKNOWN	W3/F02	12.1	11.2	0.9	7.4%	YES												
			UNKNOWN	W4/F02	12.4	11.4	1	8.1%	YES												
			UNKNOWN	W5/F02	12.5	11.6	0.9	7.2%	YES												
			UNKNOWN	W6/F02	12.6	11.7	0.9	7.1%	YES												
			UNKNOWN	W7/F02	12.7	11.8	0.9	7.1%	YES												
	R3	RESIDENTIAL	UNKNOWN	W8/F02	11.4	10.7	0.7	6.1%	YES	57.3	56.3	0.3	1.8%	YES	33	1	32	1	3.0%	0.0%	YES
			UNKNOWN	W9/F02	11.5	10.7	0.8	7.0%	YES												
F03	R1	RESIDENTIAL	UNKNOWN	W1/F03	15.6	15.3	0.3	19%	YES	98.1	94.4	1.4	3.8%	YES	43	6	40	5	7.0%	16.7%	YES
			UNKNOWN	W8/F03	14.5	13.4	1.1	7.6%	YES												
			UNKNOWN	W9/F03	14.5	13.4	1.1	7.6%	YES												
	R2	RESIDENTIAL	UNKNOWN	W2/F03	14	13	1	7.1%	YES	55	54.8	0.0	0.3%	YES	44	5	42	4	4.5%	20.0%	YES
			UNKNOWN	W3/F03	14.2	13.2	1	7.0%	YES												
			UNKNOWN	W4/F03	14.4	13.3	1.1	7.6%	YES												
			UNKNOWN	W5/F03	14.5	13.4	1.1	7.6%	YES												
			UNKNOWN	W1/F04	22.5	22.4	0.1	0.4%	YES												
	R3	RESIDENTIAL	UNKNOWN	W6/F03	14.4	13.3	1.1	7.6%	YES	91.6	88.7	0.8	3.1%	YES	40	4	39	4	2.5%	0.0%	YES
			UNKNOWN	W7/F03	14.3	13.3	1	7.0%	YES												
WAREHOUSE ONE (CONTINUED)																					
F04	R1	RESIDENTIAL	UNKNOWN	W2/F04	16.7	15.4	1.3	7.8%	YES	57.5	47.5	3.9	17.4%	YES	49	8	45	7	8.2%	12.5%	YES
			UNKNOWN	W3/F04	17	15.6	1.4	8.2%	YES												
	R2	RESIDENTIAL	UNKNOWN	W4/F04	17.5	16	1.5	8.6%	YES	54.2	41.7	3.3	22.9%	NO	48	8	43	6	10.4%	25.0%	YES






NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL1

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
B01	R1	RESIDENTIAL	UNKNOWN	29.6	15	14.8	0.0	0.8
B01	R2	RESIDENTIAL	UNKNOWN	26.9	15.7	15.7	0.0	0
F00	R1	RESIDENTIAL	UNKNOWN	29.6	40.6	40.5	0.0	0.1
F00	R2	RESIDENTIAL	UNKNOWN	26.9	22	22	0.0	0.1
F00	R3	RESIDENTIAL	UNKNOWN	38.8	16.4	16.3	0.0	0.6
F01	R1	RESIDENTIAL	UNKNOWN	38.8	38.3	38	0.1	0.8
F01	R2	RESIDENTIAL	UNKNOWN	29.6	47.6	47.3	0.1	0.7





NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL2

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
F01	R3	RESIDENTIAL	UNKNOWN	26.9	36.3	35.9	0.1	1
F02	R1	RESIDENTIAL	UNKNOWN	38.8	60.8	60.4	0.1	0.6
F02	R2	RESIDENTIAL	UNKNOWN	29.6	71.9	70	0.6	2.6
F02	R3	RESIDENTIAL	UNKNOWN	26.9	57.3	56.3	0.3	1.8
F03	R1	RESIDENTIAL	UNKNOWN	38.8	98.1	94.4	1.4	3.8
F03	R2	RESIDENTIAL	UNKNOWN	29.6	55	54.8	0.0	0.3





NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL2

KEY:




- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
F01	R3	RESIDENTIAL	UNKNOWN	26.9	36.3	35.9	0.1	1
F02	R1	RESIDENTIAL	UNKNOWN	38.8	60.8	60.4	0.1	0.6
F02	R2	RESIDENTIAL	UNKNOWN	29.6	71.9	70	0.6	2.6
F02	R3	RESIDENTIAL	UNKNOWN	26.9	57.3	56.3	0.3	1.8
F03	R1	RESIDENTIAL	UNKNOWN	38.8	98.1	94.4	1.4	3.8
F03	R2	RESIDENTIAL	UNKNOWN	29.6	55	54.8	0.0	0.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL3




KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
F03	R3	RESIDENTIAL	UNKNOWN	26.9	91.6	88.7	0.8	3.1
F04	R1	RESIDENTIAL	UNKNOWN	38.9	57.5	47.5	3.9	17.4
F04	R2	RESIDENTIAL	UNKNOWN	26.8	54.2	41.7	3.3	22.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: WAREHOUSE ONE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL3

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
WAREHOUSE ONE								
F03	R3	RESIDENTIAL	UNKNOWN	26.9	91.6	88.7	0.8	3.1
F04	R1	RESIDENTIAL	UNKNOWN	38.9	57.5	47.5	3.9	17.4
F04	R2	RESIDENTIAL	UNKNOWN	26.8	54.2	41.7	3.3	22.9



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LONDON ROAD FIRE STATION
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL4

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LONDON ROAD FIRE STATION								
F01	R11	HOTEL	BEDROOM	23.3	86.7	86.7	0.0	0
F01	R12	HOTEL	BEDROOM	18.2	88.2	87.9	0.1	0.3
F01	R13	HOTEL	BEDROOM	17.1	96.1	96.1	0.0	0
F02	R10	HOTEL	BEDROOM	18.0	81.3	80.5	0.1	1
F02	R11	HOTEL	BEDROOM	17.7	82.2	82.2	0.0	0
F02	R12	HOTEL	BEDROOM	21.0	86.2	86.2	0.0	0
F02	R13	HOTEL	BEDROOM	13.9	96.8	96.8	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LONDON ROAD FIRE STATION
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL4

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LONDON ROAD FIRE STATION								
F01	R11	HOTEL	BEDROOM	23.3	86.7	86.7	0.0	0
F01	R12	HOTEL	BEDROOM	18.2	88.2	87.9	0.1	0.3
F01	R13	HOTEL	BEDROOM	17.1	96.1	96.1	0.0	0
F02	R10	HOTEL	BEDROOM	18.0	81.3	80.5	0.1	1
F02	R11	HOTEL	BEDROOM	17.7	82.2	82.2	0.0	0
F02	R12	HOTEL	BEDROOM	21.0	86.2	86.2	0.0	0
F02	R13	HOTEL	BEDROOM	13.9	96.8	96.8	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LONDON ROAD FIRE STATION
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL5

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LONDON ROAD FIRE STATION								
F03	R10	HOTEL	BEDROOM	18.0	83.7	83.5	0.0	0.2
F03	R11	HOTEL	BEDROOM	17.7	92.2	90	0.4	2.4
F03	R12	HOTEL	BEDROOM	21.0	69.5	67.6	0.4	2.8
F03	R13	HOTEL	BEDROOM	13.9	68.7	66.9	0.2	2.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LONDON ROAD FIRE STATION
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL5

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LONDON ROAD FIRE STATION								
F03	R10	HOTEL	BEDROOM	18.0	83.7	83.5	0.0	0.2
F03	R11	HOTEL	BEDROOM	17.7	92.2	90	0.4	2.4
F03	R12	HOTEL	BEDROOM	21.0	69.5	67.6	0.4	2.8
F03	R13	HOTEL	BEDROOM	13.9	68.7	66.9	0.2	2.6

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL6

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F00

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F00	R1	RESIDENTIAL	UNKNOWN	76.2	63.2	63.1	0.1	0.2
F00	R2	RESIDENTIAL	UNKNOWN	26.5	22.7	21.7	0.3	4.6
F00	R3	RESIDENTIAL	UNKNOWN	14.7	71.1	70.6	0.1	0.8
F00	R4	RESIDENTIAL	UNKNOWN	16.7	58.5	56.8	0.3	2.9
F00	R5	RESIDENTIAL	UNKNOWN	50.9	80	80	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL6

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F00

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F00	R1	RESIDENTIAL	UNKNOWN	76.2	63.2	63.1	0.1	0.2
F00	R2	RESIDENTIAL	UNKNOWN	26.5	22.7	21.7	0.3	4.6
F00	R3	RESIDENTIAL	UNKNOWN	14.7	71.1	70.6	0.1	0.8
F00	R4	RESIDENTIAL	UNKNOWN	16.7	58.5	56.8	0.3	2.9
F00	R5	RESIDENTIAL	UNKNOWN	50.9	80	80	0.0	0


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL7

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R1	RESIDENTIAL	UNKNOWN	34.4	62.8	62.8	0.0	0
F01	R2	RESIDENTIAL	BEDROOM	6.8	42.5	42.1	0.0	0.8
F01	R3	RESIDENTIAL	BEDROOM	7.3	41.9	41.9	0.0	0
F01	R4	RESIDENTIAL	BEDROOM	10.2	29	29	0.0	0
F01	R5	RESIDENTIAL	BEDROOM	7.3	40	40	0.0	0


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL7

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R1	RESIDENTIAL	UNKNOWN	34.4	62.8	62.8	0.0	0
F01	R2	RESIDENTIAL	BEDROOM	6.8	42.5	42.1	0.0	0.8
F01	R3	RESIDENTIAL	BEDROOM	7.3	41.9	41.9	0.0	0
F01	R4	RESIDENTIAL	BEDROOM	10.2	29	29	0.0	0
F01	R5	RESIDENTIAL	BEDROOM	7.3	40	40	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL8

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R6	RESIDENTIAL	BEDROOM	6.8	42.1	42.1	0.0	0
F01	R7	RESIDENTIAL	BEDROOM	6.8	41	41	0.0	0
F01	R8	RESIDENTIAL	BEDROOM	6.9	35.9	35.9	0.0	0
F01	R9	RESIDENTIAL	BEDROOM	6.9	26.3	24.6	0.1	6.5
F01	R10	RESIDENTIAL	BEDROOM	7.4	23.7	21.3	0.2	10

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL8

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R6	RESIDENTIAL	BEDROOM	6.8	42.1	42.1	0.0	0
F01	R7	RESIDENTIAL	BEDROOM	6.8	41	41	0.0	0
F01	R8	RESIDENTIAL	BEDROOM	6.9	35.9	35.9	0.0	0
F01	R9	RESIDENTIAL	BEDROOM	6.9	26.3	24.6	0.1	6.5
F01	R10	RESIDENTIAL	BEDROOM	7.4	23.7	21.3	0.2	10

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL9

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R11	RESIDENTIAL	UNKNOWN	15.8	68.6	68.5	0.0	0.2
F01	R12	RESIDENTIAL	BEDROOM	10.5	24.4	23.3	0.1	4.6
F01	R13	RESIDENTIAL	BEDROOM	10.5	31.1	29.7	0.1	4.6
F01	R14	RESIDENTIAL	UNKNOWN	20.9	87.6	87.6	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL9

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F01	R11	RESIDENTIAL	UNKNOWN	15.8	68.6	68.5	0.0	0.2
F01	R12	RESIDENTIAL	BEDROOM	10.5	24.4	23.3	0.1	4.6
F01	R13	RESIDENTIAL	BEDROOM	10.5	31.1	29.7	0.1	4.6
F01	R14	RESIDENTIAL	UNKNOWN	20.9	87.6	87.6	0.0	0


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL10

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R1	RESIDENTIAL	UNKNOWN	34.4	71.4	71.4	0.0	0
F02	R2	RESIDENTIAL	BEDROOM	6.8	57.5	57	0.0	0.9
F02	R3	RESIDENTIAL	BEDROOM	7.3	57.3	57.1	0.0	0.4
F02	R4	RESIDENTIAL	BEDROOM	10.2	40.9	40.9	0.0	0
F02	R5	RESIDENTIAL	BEDROOM	7.3	55.7	55.7	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL10

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R1	RESIDENTIAL	UNKNOWN	34.4	71.4	71.4	0.0	0
F02	R2	RESIDENTIAL	BEDROOM	6.8	57.5	57	0.0	0.9
F02	R3	RESIDENTIAL	BEDROOM	7.3	57.3	57.1	0.0	0.4
F02	R4	RESIDENTIAL	BEDROOM	10.2	40.9	40.9	0.0	0
F02	R5	RESIDENTIAL	BEDROOM	7.3	55.7	55.7	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL11

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R6	RESIDENTIAL	BEDROOM	6.8	60.3	60.3	0.0	0
F02	R7	RESIDENTIAL	BEDROOM	6.8	51.2	51.2	0.0	0
F02	R8	RESIDENTIAL	BEDROOM	6.9	47.4	47.4	0.0	0.1
F02	R9	RESIDENTIAL	BEDROOM	6.9	32.1	30.4	0.1	5.2
F02	R10	RESIDENTIAL	BEDROOM	7.4	33	29.9	0.2	9.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL11

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R6	RESIDENTIAL	BEDROOM	6.8	60.3	60.3	0.0	0
F02	R7	RESIDENTIAL	BEDROOM	6.8	51.2	51.2	0.0	0
F02	R8	RESIDENTIAL	BEDROOM	6.9	47.4	47.4	0.0	0.1
F02	R9	RESIDENTIAL	BEDROOM	6.9	32.1	30.4	0.1	5.2
F02	R10	RESIDENTIAL	BEDROOM	7.4	33	29.9	0.2	9.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL12

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R11	RESIDENTIAL	UNKNOWN	15.8	72	71.7	0.0	0.4
F02	R12	RESIDENTIAL	BEDROOM	10.5	24.8	23.5	0.1	5.2
F02	R13	RESIDENTIAL	BEDROOM	10.5	31.9	30.2	0.2	5.5
F02	R14	RESIDENTIAL	UNKNOWN	20.9	93.6	93.6	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL12

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F02	R11	RESIDENTIAL	UNKNOWN	15.8	72	71.7	0.0	0.4
F02	R12	RESIDENTIAL	BEDROOM	10.5	24.8	23.5	0.1	5.2
F02	R13	RESIDENTIAL	BEDROOM	10.5	31.9	30.2	0.2	5.5
F02	R14	RESIDENTIAL	UNKNOWN	20.9	93.6	93.6	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL13

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R1	RESIDENTIAL	UNKNOWN	34.4	82.8	82.7	0.0	0
F03	R2	RESIDENTIAL	BEDROOM	6.8	70.5	68.7	0.1	2.4
F03	R3	RESIDENTIAL	BEDROOM	7.3	72.6	71.7	0.1	1.2
F03	R4	RESIDENTIAL	BEDROOM	10.2	54.5	54.4	0.0	0.1
F03	R5	RESIDENTIAL	BEDROOM	7.3	69.8	69.8	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL13

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID





F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R1	RESIDENTIAL	UNKNOWN	34.4	82.8	82.7	0.0	0
F03	R2	RESIDENTIAL	BEDROOM	6.8	70.5	68.7	0.1	2.4
F03	R3	RESIDENTIAL	BEDROOM	7.3	72.6	71.7	0.1	1.2
F03	R4	RESIDENTIAL	BEDROOM	10.2	54.5	54.4	0.0	0.1
F03	R5	RESIDENTIAL	BEDROOM	7.3	69.8	69.8	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL14

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID





F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R6	RESIDENTIAL	BEDROOM	6.8	77.5	77.5	0.0	0
F03	R7	RESIDENTIAL	BEDROOM	6.8	60.9	60.9	0.0	0
F03	R8	RESIDENTIAL	BEDROOM	6.9	55.3	55.3	0.0	0
F03	R9	RESIDENTIAL	BEDROOM	6.9	34.2	33.5	0.0	2.1
F03	R10	RESIDENTIAL	BEDROOM	7.4	38.1	34.7	0.3	9.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL14

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R6	RESIDENTIAL	BEDROOM	6.8	77.5	77.5	0.0	0
F03	R7	RESIDENTIAL	BEDROOM	6.8	60.9	60.9	0.0	0
F03	R8	RESIDENTIAL	BEDROOM	6.9	55.3	55.3	0.0	0
F03	R9	RESIDENTIAL	BEDROOM	6.9	34.2	33.5	0.0	2.1
F03	R10	RESIDENTIAL	BEDROOM	7.4	38.1	34.7	0.3	9.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL15

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R11	RESIDENTIAL	UNKNOWN	15.8	73.3	73.1	0.0	0.2
F03	R12	RESIDENTIAL	BEDROOM	10.5	24.9	23.6	0.1	5.3
F03	R13	RESIDENTIAL	BEDROOM	10.5	32.3	30.3	0.2	6.1
F03	R14	RESIDENTIAL	UNKNOWN	20.9	94.2	94.2	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL15

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F03	R11	RESIDENTIAL	UNKNOWN	15.8	73.3	73.1	0.0	0.2
F03	R12	RESIDENTIAL	BEDROOM	10.5	24.9	23.6	0.1	5.3
F03	R13	RESIDENTIAL	BEDROOM	10.5	32.3	30.3	0.2	6.1
F03	R14	RESIDENTIAL	UNKNOWN	20.9	94.2	94.2	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL16

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R1	RESIDENTIAL	UNKNOWN	34.4	88.6	88.6	0.0	0
F04	R2	RESIDENTIAL	BEDROOM	6.8	79.1	77.8	0.1	1.6
F04	R3	RESIDENTIAL	BEDROOM	7.3	83.3	82.1	0.1	1.4
F04	R4	RESIDENTIAL	BEDROOM	10.2	67.1	66.6	0.0	0.7
F04	R5	RESIDENTIAL	BEDROOM	7.3	75	74.8	0.0	0.3

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL16

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R1	RESIDENTIAL	UNKNOWN	34.4	88.6	88.6	0.0	0
F04	R2	RESIDENTIAL	BEDROOM	6.8	79.1	77.8	0.1	1.6
F04	R3	RESIDENTIAL	BEDROOM	7.3	83.3	82.1	0.1	1.4
F04	R4	RESIDENTIAL	BEDROOM	10.2	67.1	66.6	0.0	0.7
F04	R5	RESIDENTIAL	BEDROOM	7.3	75	74.8	0.0	0.3

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL17

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R6	RESIDENTIAL	BEDROOM	6.8	82	82	0.0	0
F04	R7	RESIDENTIAL	BEDROOM	6.8	63.4	63.3	0.0	0.2
F04	R8	RESIDENTIAL	BEDROOM	6.9	59.3	58.5	0.1	1.3
F04	R9	RESIDENTIAL	BEDROOM	6.9	38.8	36.4	0.2	6.2
F04	R10	RESIDENTIAL	BEDROOM	7.4	40	38.1	0.1	4.8


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL17

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID





F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R6	RESIDENTIAL	BEDROOM	6.8	82	82	0.0	0
F04	R7	RESIDENTIAL	BEDROOM	6.8	63.4	63.3	0.0	0.2
F04	R8	RESIDENTIAL	BEDROOM	6.9	59.3	58.5	0.1	1.3
F04	R9	RESIDENTIAL	BEDROOM	6.9	38.8	36.4	0.2	6.2
F04	R10	RESIDENTIAL	BEDROOM	7.4	40	38.1	0.1	4.8

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL18

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R11	RESIDENTIAL	UNKNOWN	15.8	73.9	73.5	0.1	0.5
F04	R12	RESIDENTIAL	BEDROOM	10.5	25	23.7	0.1	5.3
F04	R13	RESIDENTIAL	BEDROOM	10.5	32.4	30.4	0.2	6.1
F04	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL18

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F04	R11	RESIDENTIAL	UNKNOWN	15.8	73.9	73.5	0.1	0.5
F04	R12	RESIDENTIAL	BEDROOM	10.5	25	23.7	0.1	5.3
F04	R13	RESIDENTIAL	BEDROOM	10.5	32.4	30.4	0.2	6.1
F04	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL19

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R1	RESIDENTIAL	UNKNOWN	34.4	95.6	95.6	0.0	0
F05	R2	RESIDENTIAL	BEDROOM	6.8	89.3	87.2	0.1	2.3
F05	R3	RESIDENTIAL	BEDROOM	7.3	93.6	91.7	0.1	2
F05	R4	RESIDENTIAL	BEDROOM	10.2	84.1	82.9	0.1	1.5
F05	R5	RESIDENTIAL	BEDROOM	7.3	83.1	81.1	0.1	2.4


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL19

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R1	RESIDENTIAL	UNKNOWN	34.4	95.6	95.6	0.0	0
F05	R2	RESIDENTIAL	BEDROOM	6.8	89.3	87.2	0.1	2.3
F05	R3	RESIDENTIAL	BEDROOM	7.3	93.6	91.7	0.1	2
F05	R4	RESIDENTIAL	BEDROOM	10.2	84.1	82.9	0.1	1.5
F05	R5	RESIDENTIAL	BEDROOM	7.3	83.1	81.1	0.1	2.4

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL20

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R6	RESIDENTIAL	BEDROOM	6.8	89.3	88.4	0.1	1
F05	R7	RESIDENTIAL	BEDROOM	6.8	69.5	68.2	0.1	1.9
F05	R8	RESIDENTIAL	BEDROOM	6.9	66.5	65	0.1	2.3
F05	R9	RESIDENTIAL	BEDROOM	6.9	46.5	44.6	0.1	4.1
F05	R10	RESIDENTIAL	BEDROOM	7.4	50.5	49.1	0.1	2.9

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL20

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R6	RESIDENTIAL	BEDROOM	6.8	89.3	88.4	0.1	1
F05	R7	RESIDENTIAL	BEDROOM	6.8	69.5	68.2	0.1	1.9
F05	R8	RESIDENTIAL	BEDROOM	6.9	66.5	65	0.1	2.3
F05	R9	RESIDENTIAL	BEDROOM	6.9	46.5	44.6	0.1	4.1
F05	R10	RESIDENTIAL	BEDROOM	7.4	50.5	49.1	0.1	2.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL21

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R11	RESIDENTIAL	UNKNOWN	15.8	75	74.6	0.1	0.5
F05	R12	RESIDENTIAL	BEDROOM	10.5	25.3	23.7	0.2	6.3
F05	R13	RESIDENTIAL	BEDROOM	10.5	32.4	30.5	0.2	6.1
F05	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL21

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F05	R11	RESIDENTIAL	UNKNOWN	15.8	75	74.6	0.1	0.5
F05	R12	RESIDENTIAL	BEDROOM	10.5	25.3	23.7	0.2	6.3
F05	R13	RESIDENTIAL	BEDROOM	10.5	32.4	30.5	0.2	6.1
F05	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL22

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F06	R2	RESIDENTIAL	BEDROOM	6.8	91.1	87.7	0.2	3.7
F06	R3	RESIDENTIAL	BEDROOM	7.3	93.8	92.4	0.1	1.5
F06	R4	RESIDENTIAL	BEDROOM	10.2	88.7	88	0.1	0.8
F06	R5	RESIDENTIAL	BEDROOM	7.3	88.6	85.8	0.2	3.2

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL22

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F06	R2	RESIDENTIAL	BEDROOM	6.8	91.1	87.7	0.2	3.7
F06	R3	RESIDENTIAL	BEDROOM	7.3	93.8	92.4	0.1	1.5
F06	R4	RESIDENTIAL	BEDROOM	10.2	88.7	88	0.1	0.8
F06	R5	RESIDENTIAL	BEDROOM	7.3	88.6	85.8	0.2	3.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL23

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R6	RESIDENTIAL	BEDROOM	6.8	95.1	94.6	0.0	0.4
F06	R7	RESIDENTIAL	BEDROOM	6.8	84.3	81.3	0.2	3.6
F06	R8	RESIDENTIAL	BEDROOM	6.9	83.8	81.8	0.1	2.3
F06	R9	RESIDENTIAL	BEDROOM	6.9	70.3	68.3	0.1	2.8
F06	R10	RESIDENTIAL	BEDROOM	7.4	82.4	80.8	0.1	1.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL23

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R6	RESIDENTIAL	BEDROOM	6.8	95.1	94.6	0.0	0.4
F06	R7	RESIDENTIAL	BEDROOM	6.8	84.3	81.3	0.2	3.6
F06	R8	RESIDENTIAL	BEDROOM	6.9	83.8	81.8	0.1	2.3
F06	R9	RESIDENTIAL	BEDROOM	6.9	70.3	68.3	0.1	2.8
F06	R10	RESIDENTIAL	BEDROOM	7.4	82.4	80.8	0.1	1.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL24

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R11	RESIDENTIAL	UNKNOWN	15.8	77.2	76.5	0.1	0.8
F06	R12	RESIDENTIAL	BEDROOM	10.5	25.5	23.9	0.2	6.3
F06	R13	RESIDENTIAL	BEDROOM	10.5	32.8	30.5	0.2	6.9
F06	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL24

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F06	R11	RESIDENTIAL	UNKNOWN	15.8	77.2	76.5	0.1	0.8
F06	R12	RESIDENTIAL	BEDROOM	10.5	25.5	23.9	0.2	6.3
F06	R13	RESIDENTIAL	BEDROOM	10.5	32.8	30.5	0.2	6.9
F06	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL25

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F07	R2	RESIDENTIAL	BEDROOM	6.8	92	89.4	0.2	2.7
F07	R3	RESIDENTIAL	BEDROOM	7.3	93.8	93.1	0.1	0.8
F07	R4	RESIDENTIAL	BEDROOM	10.2	94.3	94.1	0.0	0.3
F07	R5	RESIDENTIAL	BEDROOM	7.3	90	87.2	0.2	3.1

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL25

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F07	R2	RESIDENTIAL	BEDROOM	6.8	92	89.4	0.2	2.7
F07	R3	RESIDENTIAL	BEDROOM	7.3	93.8	93.1	0.1	0.8
F07	R4	RESIDENTIAL	BEDROOM	10.2	94.3	94.1	0.0	0.3
F07	R5	RESIDENTIAL	BEDROOM	7.3	90	87.2	0.2	3.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL26

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R6	RESIDENTIAL	BEDROOM	6.8	95.1	95	0.0	0.1
F07	R7	RESIDENTIAL	BEDROOM	6.8	90.8	88.5	0.2	2.5
F07	R8	RESIDENTIAL	BEDROOM	6.9	94.5	93.7	0.1	0.9
F07	R9	RESIDENTIAL	BEDROOM	6.9	89	85.8	0.2	3.7
F07	R10	RESIDENTIAL	BEDROOM	7.4	93.2	91.8	0.1	1.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL26

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R6	RESIDENTIAL	BEDROOM	6.8	95.1	95	0.0	0.1
F07	R7	RESIDENTIAL	BEDROOM	6.8	90.8	88.5	0.2	2.5
F07	R8	RESIDENTIAL	BEDROOM	6.9	94.5	93.7	0.1	0.9
F07	R9	RESIDENTIAL	BEDROOM	6.9	89	85.8	0.2	3.7
F07	R10	RESIDENTIAL	BEDROOM	7.4	93.2	91.8	0.1	1.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL27

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R11	RESIDENTIAL	UNKNOWN	15.8	85.7	85.3	0.1	0.5
F07	R12	RESIDENTIAL	BEDROOM	10.5	25.6	24.1	0.2	6
F07	R13	RESIDENTIAL	BEDROOM	10.5	32.9	30.6	0.2	7.1
F07	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL27

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F07

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F07	R11	RESIDENTIAL	UNKNOWN	15.8	85.7	85.3	0.1	0.5
F07	R12	RESIDENTIAL	BEDROOM	10.5	25.6	24.1	0.2	6
F07	R13	RESIDENTIAL	BEDROOM	10.5	32.9	30.6	0.2	7.1
F07	R14	RESIDENTIAL	UNKNOWN	20.9	97.4	97.4	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL28

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F08

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F08	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F08	R2	RESIDENTIAL	BEDROOM	23.1	97.4	96.8	0.1	0.6
F08	R3	RESIDENTIAL	BEDROOM	10.2	96.6	96.5	0.0	0
F08	R4	RESIDENTIAL	BEDROOM	23.1	97	95.8	0.3	1.2
F08	R5	RESIDENTIAL	BEDROOM	22.4	97.4	96.5	0.2	0.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL28

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F08

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F08	R1	RESIDENTIAL	UNKNOWN	34.4	100	100	0.0	0
F08	R2	RESIDENTIAL	BEDROOM	23.1	97.4	96.8	0.1	0.6
F08	R3	RESIDENTIAL	BEDROOM	10.2	96.6	96.5	0.0	0
F08	R4	RESIDENTIAL	BEDROOM	23.1	97	95.8	0.3	1.2
F08	R5	RESIDENTIAL	BEDROOM	22.4	97.4	96.5	0.2	0.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL29

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F08

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F08	R6	RESIDENTIAL	BEDROOM	23.3	96.7	95.7	0.2	1
F08	R7	RESIDENTIAL	UNKNOWN	15.8	91.8	91.2	0.1	0.6
F08	R8	RESIDENTIAL	UNKNOWN	29.9	61.8	60.4	0.4	2.3
F08	R9	RESIDENTIAL	UNKNOWN	20.9	97.8	97.8	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: FAIRFIELD HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL29

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F08



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
FAIRFIELD HOUSE								
F08	R6	RESIDENTIAL	BEDROOM	23.3	96.7	95.7	0.2	1
F08	R7	RESIDENTIAL	UNKNOWN	15.8	91.8	91.2	0.1	0.6
F08	R8	RESIDENTIAL	UNKNOWN	29.9	61.8	60.4	0.4	2.3
F08	R9	RESIDENTIAL	UNKNOWN	20.9	97.8	97.8	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL30

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



B01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
B01	R1	RESIDENTIAL	UNKNOWN	19.3	6.4	6.3	0.0	1.7
B01	R2	RESIDENTIAL	UNKNOWN	22.5	49.8	49	0.2	1.6
B01	R3	RESIDENTIAL	UNKNOWN	22.4	0	0	0.0	0
B01	R4	RESIDENTIAL	UNKNOWN	22.3	2.6	2.6	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL30

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



B01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
B01	R1	RESIDENTIAL	UNKNOWN	19.3	6.4	6.3	0.0	1.7
B01	R2	RESIDENTIAL	UNKNOWN	22.5	49.8	49	0.2	1.6
B01	R3	RESIDENTIAL	UNKNOWN	22.4	0	0	0.0	0
B01	R4	RESIDENTIAL	UNKNOWN	22.3	2.6	2.6	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL31

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



B01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
B01	R5	RESIDENTIAL	UNKNOWN	22.6	7.6	6.9	0.2	9.1
B01	R6	RESIDENTIAL	UNKNOWN	22.5	16.5	15.6	0.2	5.4
B01	R7	RESIDENTIAL	UNKNOWN	22.5	31.4	31.3	0.0	0.5
B01	R8	RESIDENTIAL	UNKNOWN	23.2	51.9	51.9	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL31

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



B01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
B01	R5	RESIDENTIAL	UNKNOWN	22.6	7.6	6.9	0.2	9.1
B01	R6	RESIDENTIAL	UNKNOWN	22.5	16.5	15.6	0.2	5.4
B01	R7	RESIDENTIAL	UNKNOWN	22.5	31.4	31.3	0.0	0.5
B01	R8	RESIDENTIAL	UNKNOWN	23.2	51.9	51.9	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL32

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID





FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R1	RESIDENTIAL	UNKNOWN	21.7	14	13.9	0.0	0.7
F00	R2	RESIDENTIAL	UNKNOWN	13.1	61	60.7	0.0	0.4
F00	R3	RESIDENTIAL	BEDROOM	7.3	4	2.8	0.1	30.9
F00	R4	RESIDENTIAL	BEDROOM	7.3	3.3	2.3	0.1	29.4
F00	R5	RESIDENTIAL	BEDROOM	7.3	3.7	2.4	0.1	36.7

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL32

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F00


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R1	RESIDENTIAL	UNKNOWN	21.7	14	13.9	0.0	0.7
F00	R2	RESIDENTIAL	UNKNOWN	13.1	61	60.7	0.0	0.4
F00	R3	RESIDENTIAL	BEDROOM	7.3	4	2.8	0.1	30.9
F00	R4	RESIDENTIAL	BEDROOM	7.3	3.3	2.3	0.1	29.4
F00	R5	RESIDENTIAL	BEDROOM	7.3	3.7	2.4	0.1	36.7

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL33

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F00


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R6	RESIDENTIAL	BEDROOM	7.3	6.8	4.3	0.2	36
F00	R7	RESIDENTIAL	BEDROOM	7.3	5	3.1	0.1	37.5
F00	R8	RESIDENTIAL	BEDROOM	7.3	9.2	7.4	0.1	19.5
F00	R9	RESIDENTIAL	BEDROOM	7.3	6.2	4.2	0.1	31.8
F00	R10	RESIDENTIAL	BEDROOM	7.3	13	11.2	0.1	13.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL33

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F00

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R6	RESIDENTIAL	BEDROOM	7.3	6.8	4.3	0.2	36
F00	R7	RESIDENTIAL	BEDROOM	7.3	5	3.1	0.1	37.5
F00	R8	RESIDENTIAL	BEDROOM	7.3	9.2	7.4	0.1	19.5
F00	R9	RESIDENTIAL	BEDROOM	7.3	6.2	4.2	0.1	31.8
F00	R10	RESIDENTIAL	BEDROOM	7.3	13	11.2	0.1	13.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL34

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F00

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R11	RESIDENTIAL	BEDROOM	7.3	7.6	6.2	0.1	17.6
F00	R12	RESIDENTIAL	BEDROOM	7.3	20.6	18.1	0.2	12.4
F00	R13	RESIDENTIAL	BEDROOM	7.3	11	10.1	0.1	7.7
F00	R14	RESIDENTIAL	BEDROOM	7.3	41.5	41.1	0.0	0.9
F00	R15	RESIDENTIAL	BEDROOM	7.7	27.1	26.9	0.0	0.8

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL34

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F00


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F00	R11	RESIDENTIAL	BEDROOM	7.3	7.6	6.2	0.1	17.6
F00	R12	RESIDENTIAL	BEDROOM	7.3	20.6	18.1	0.2	12.4
F00	R13	RESIDENTIAL	BEDROOM	7.3	11	10.1	0.1	7.7
F00	R14	RESIDENTIAL	BEDROOM	7.3	41.5	41.1	0.0	0.9
F00	R15	RESIDENTIAL	BEDROOM	7.7	27.1	26.9	0.0	0.8

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL35

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R1	RESIDENTIAL	UNKNOWN	21.7	17.3	17.1	0.0	0.8
F01	R2	RESIDENTIAL	UNKNOWN	13.1	62.9	62.5	0.0	0.5
F01	R3	RESIDENTIAL	BEDROOM	7.3	4.9	3.2	0.1	35.8
F01	R4	RESIDENTIAL	BEDROOM	7.3	4	3	0.1	23.8
F01	R5	RESIDENTIAL	BEDROOM	7.3	4.6	3.2	0.1	31


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL35

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R1	RESIDENTIAL	UNKNOWN	21.7	17.3	17.1	0.0	0.8
F01	R2	RESIDENTIAL	UNKNOWN	13.1	62.9	62.5	0.0	0.5
F01	R3	RESIDENTIAL	BEDROOM	7.3	4.9	3.2	0.1	35.8
F01	R4	RESIDENTIAL	BEDROOM	7.3	4	3	0.1	23.8
F01	R5	RESIDENTIAL	BEDROOM	7.3	4.6	3.2	0.1	31

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL36

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R6	RESIDENTIAL	BEDROOM	7.3	4.9	3.6	0.1	26.2
F01	R7	RESIDENTIAL	BEDROOM	7.3	5.8	4.1	0.1	29.3
F01	R8	RESIDENTIAL	BEDROOM	7.3	7.9	5.4	0.2	31.1
F01	R9	RESIDENTIAL	BEDROOM	7.3	6.4	4.2	0.2	33.5
F01	R10	RESIDENTIAL	BEDROOM	7.3	10.2	8.1	0.2	20.4

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL36

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R6	RESIDENTIAL	BEDROOM	7.3	4.9	3.6	0.1	26.2
F01	R7	RESIDENTIAL	BEDROOM	7.3	5.8	4.1	0.1	29.3
F01	R8	RESIDENTIAL	BEDROOM	7.3	7.9	5.4	0.2	31.1
F01	R9	RESIDENTIAL	BEDROOM	7.3	6.4	4.2	0.2	33.5
F01	R10	RESIDENTIAL	BEDROOM	7.3	10.2	8.1	0.2	20.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL37

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R11	RESIDENTIAL	BEDROOM	7.3	7.3	5.2	0.2	29.3
F01	R12	RESIDENTIAL	BEDROOM	7.3	14.1	12.2	0.1	13
F01	R13	RESIDENTIAL	BEDROOM	7.3	8.8	6.9	0.1	20.8
F01	R14	RESIDENTIAL	BEDROOM	7.3	21.2	18.6	0.2	12.3
F01	R15	RESIDENTIAL	BEDROOM	7.3	11.6	10.7	0.1	7.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL37

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R11	RESIDENTIAL	BEDROOM	7.3	7.3	5.2	0.2	29.3
F01	R12	RESIDENTIAL	BEDROOM	7.3	14.1	12.2	0.1	13
F01	R13	RESIDENTIAL	BEDROOM	7.3	8.8	6.9	0.1	20.8
F01	R14	RESIDENTIAL	BEDROOM	7.3	21.2	18.6	0.2	12.3
F01	R15	RESIDENTIAL	BEDROOM	7.3	11.6	10.7	0.1	7.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL38

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F01

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R16	RESIDENTIAL	BEDROOM	7.3	41.8	41.5	0.0	0.7
F01	R17	RESIDENTIAL	BEDROOM	7.4	28.5	28.5	0.0	0.3
F01	R18	RESIDENTIAL	BEDROOM	7.3	68.7	68.5	0.0	0.3
F01	R19	RESIDENTIAL	BEDROOM	7.7	53.8	53.7	0.0	0.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL38

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F01


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F01	R16	RESIDENTIAL	BEDROOM	7.3	41.8	41.5	0.0	0.7
F01	R17	RESIDENTIAL	BEDROOM	7.4	28.5	28.5	0.0	0.3
F01	R18	RESIDENTIAL	BEDROOM	7.3	68.7	68.5	0.0	0.3
F01	R19	RESIDENTIAL	BEDROOM	7.7	53.8	53.7	0.0	0.1

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL39

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F02



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R1	RESIDENTIAL	UNKNOWN	21.7	21.3	21.1	0.0	0.7
F02	R2	RESIDENTIAL	UNKNOWN	13.1	65.6	65.2	0.0	0.5
F02	R3	RESIDENTIAL	BEDROOM	7.3	5.8	2.2	0.3	62.7
F02	R4	RESIDENTIAL	BEDROOM	7.3	4.7	2.5	0.2	46.5
F02	R5	RESIDENTIAL	BEDROOM	7.3	5.6	3.4	0.2	39.8

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL39

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F02


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R1	RESIDENTIAL	UNKNOWN	21.7	21.3	21.1	0.0	0.7
F02	R2	RESIDENTIAL	UNKNOWN	13.1	65.6	65.2	0.0	0.5
F02	R3	RESIDENTIAL	BEDROOM	7.3	5.8	2.2	0.3	62.7
F02	R4	RESIDENTIAL	BEDROOM	7.3	4.7	2.5	0.2	46.5
F02	R5	RESIDENTIAL	BEDROOM	7.3	5.6	3.4	0.2	39.8

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL40

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F02


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R6	RESIDENTIAL	BEDROOM	7.3	6	4.1	0.1	30.7
F02	R7	RESIDENTIAL	BEDROOM	7.3	6.8	4.8	0.1	29.4
F02	R8	RESIDENTIAL	BEDROOM	7.3	8.9	6.4	0.2	28.4
F02	R9	RESIDENTIAL	BEDROOM	7.3	7.7	5.1	0.2	34
F02	R10	RESIDENTIAL	BEDROOM	7.3	11.4	9	0.2	21.2

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL40

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R6	RESIDENTIAL	BEDROOM	7.3	6	4.1	0.1	30.7
F02	R7	RESIDENTIAL	BEDROOM	7.3	6.8	4.8	0.1	29.4
F02	R8	RESIDENTIAL	BEDROOM	7.3	8.9	6.4	0.2	28.4
F02	R9	RESIDENTIAL	BEDROOM	7.3	7.7	5.1	0.2	34
F02	R10	RESIDENTIAL	BEDROOM	7.3	11.4	9	0.2	21.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL41

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R11	RESIDENTIAL	BEDROOM	7.3	8.7	6.2	0.2	29.3
F02	R12	RESIDENTIAL	BEDROOM	7.3	15.4	13.1	0.2	14.7
F02	R13	RESIDENTIAL	BEDROOM	7.3	9.9	7.8	0.2	21.5
F02	R14	RESIDENTIAL	BEDROOM	7.3	22.7	19.2	0.3	15.5
F02	R15	RESIDENTIAL	BEDROOM	7.3	11.9	10.8	0.1	9.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL41

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R11	RESIDENTIAL	BEDROOM	7.3	8.7	6.2	0.2	29.3
F02	R12	RESIDENTIAL	BEDROOM	7.3	15.4	13.1	0.2	14.7
F02	R13	RESIDENTIAL	BEDROOM	7.3	9.9	7.8	0.2	21.5
F02	R14	RESIDENTIAL	BEDROOM	7.3	22.7	19.2	0.3	15.5
F02	R15	RESIDENTIAL	BEDROOM	7.3	11.9	10.8	0.1	9.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL42

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID





F02

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R16	RESIDENTIAL	BEDROOM	7.3	42	41.7	0.0	0.7
F02	R17	RESIDENTIAL	BEDROOM	7.4	28.8	28.4	0.0	1.4
F02	R18	RESIDENTIAL	BEDROOM	7.3	68.8	68.4	0.0	0.6
F02	R19	RESIDENTIAL	BEDROOM	7.7	53.9	53.7	0.0	0.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL42

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F02


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F02	R16	RESIDENTIAL	BEDROOM	7.3	42	41.7	0.0	0.7
F02	R17	RESIDENTIAL	BEDROOM	7.4	28.8	28.4	0.0	1.4
F02	R18	RESIDENTIAL	BEDROOM	7.3	68.8	68.4	0.0	0.6
F02	R19	RESIDENTIAL	BEDROOM	7.7	53.9	53.7	0.0	0.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL43

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F03


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R1	RESIDENTIAL	UNKNOWN	21.7	23.6	23.3	0.1	1
F03	R2	RESIDENTIAL	UNKNOWN	13.1	67.8	67.5	0.0	0.4
F03	R3	RESIDENTIAL	BEDROOM	7.3	6.1	4	0.2	34.8
F03	R4	RESIDENTIAL	BEDROOM	7.3	5.9	3.9	0.1	33.2
F03	R5	RESIDENTIAL	BEDROOM	7.3	6.4	4.6	0.1	28.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL43

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R1	RESIDENTIAL	UNKNOWN	21.7	23.6	23.3	0.1	1
F03	R2	RESIDENTIAL	UNKNOWN	13.1	67.8	67.5	0.0	0.4
F03	R3	RESIDENTIAL	BEDROOM	7.3	6.1	4	0.2	34.8
F03	R4	RESIDENTIAL	BEDROOM	7.3	5.9	3.9	0.1	33.2
F03	R5	RESIDENTIAL	BEDROOM	7.3	6.4	4.6	0.1	28.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL44

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R6	RESIDENTIAL	BEDROOM	7.3	8.2	4.6	0.3	44.4
F03	R7	RESIDENTIAL	BEDROOM	7.3	8.3	5.8	0.2	29.5
F03	R8	RESIDENTIAL	BEDROOM	7.3	10.8	7.4	0.3	32.2
F03	R9	RESIDENTIAL	BEDROOM	7.3	9.2	6.4	0.2	30.8
F03	R10	RESIDENTIAL	BEDROOM	7.3	12.9	10.2	0.2	20.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL44

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R6	RESIDENTIAL	BEDROOM	7.3	8.2	4.6	0.3	44.4
F03	R7	RESIDENTIAL	BEDROOM	7.3	8.3	5.8	0.2	29.5
F03	R8	RESIDENTIAL	BEDROOM	7.3	10.8	7.4	0.3	32.2
F03	R9	RESIDENTIAL	BEDROOM	7.3	9.2	6.4	0.2	30.8
F03	R10	RESIDENTIAL	BEDROOM	7.3	12.9	10.2	0.2	20.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL45

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R11	RESIDENTIAL	BEDROOM	7.3	10.2	7.2	0.2	29.2
F03	R12	RESIDENTIAL	BEDROOM	7.3	16.8	13.7	0.2	18.2
F03	R13	RESIDENTIAL	BEDROOM	7.3	11.2	8.7	0.2	22.2
F03	R14	RESIDENTIAL	BEDROOM	7.3	23.9	19.8	0.3	17.3
F03	R15	RESIDENTIAL	BEDROOM	7.3	13	11.8	0.1	9.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL45

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R11	RESIDENTIAL	BEDROOM	7.3	10.2	7.2	0.2	29.2
F03	R12	RESIDENTIAL	BEDROOM	7.3	16.8	13.7	0.2	18.2
F03	R13	RESIDENTIAL	BEDROOM	7.3	11.2	8.7	0.2	22.2
F03	R14	RESIDENTIAL	BEDROOM	7.3	23.9	19.8	0.3	17.3
F03	R15	RESIDENTIAL	BEDROOM	7.3	13	11.8	0.1	9.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL46

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F03

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R16	RESIDENTIAL	BEDROOM	7.3	42.2	41.8	0.0	0.9
F03	R17	RESIDENTIAL	BEDROOM	7.4	28.9	28.5	0.0	1.7
F03	R18	RESIDENTIAL	BEDROOM	7.3	68.9	68.8	0.0	0.2
F03	R19	RESIDENTIAL	BEDROOM	7.7	54	53.8	0.0	0.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL46

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F03


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F03	R16	RESIDENTIAL	BEDROOM	7.3	42.2	41.8	0.0	0.9
F03	R17	RESIDENTIAL	BEDROOM	7.4	28.9	28.5	0.0	1.7
F03	R18	RESIDENTIAL	BEDROOM	7.3	68.9	68.8	0.0	0.2
F03	R19	RESIDENTIAL	BEDROOM	7.7	54	53.8	0.0	0.4

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL47

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F04


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R1	RESIDENTIAL	UNKNOWN	21.7	30.6	30.3	0.1	0.9
F04	R2	RESIDENTIAL	UNKNOWN	13.1	72.9	72.4	0.1	0.6
F04	R3	RESIDENTIAL	BEDROOM	7.3	7	4.9	0.1	29.1
F04	R4	RESIDENTIAL	BEDROOM	7.3	7.5	4.6	0.2	38.8
F04	R5	RESIDENTIAL	BEDROOM	7.3	7	5.7	0.1	19.5

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL47

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R1	RESIDENTIAL	UNKNOWN	21.7	30.6	30.3	0.1	0.9
F04	R2	RESIDENTIAL	UNKNOWN	13.1	72.9	72.4	0.1	0.6
F04	R3	RESIDENTIAL	BEDROOM	7.3	7	4.9	0.1	29.1
F04	R4	RESIDENTIAL	BEDROOM	7.3	7.5	4.6	0.2	38.8
F04	R5	RESIDENTIAL	BEDROOM	7.3	7	5.7	0.1	19.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL48

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R6	RESIDENTIAL	BEDROOM	7.3	10.2	6.1	0.3	40.2
F04	R7	RESIDENTIAL	BEDROOM	7.3	9.6	7	0.2	27.4
F04	R8	RESIDENTIAL	BEDROOM	7.3	13.1	9.2	0.3	29.7
F04	R9	RESIDENTIAL	BEDROOM	7.3	11.4	7.9	0.3	31.3
F04	R10	RESIDENTIAL	BEDROOM	7.3	15.1	11.5	0.3	23.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL48

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R6	RESIDENTIAL	BEDROOM	7.3	10.2	6.1	0.3	40.2
F04	R7	RESIDENTIAL	BEDROOM	7.3	9.6	7	0.2	27.4
F04	R8	RESIDENTIAL	BEDROOM	7.3	13.1	9.2	0.3	29.7
F04	R9	RESIDENTIAL	BEDROOM	7.3	11.4	7.9	0.3	31.3
F04	R10	RESIDENTIAL	BEDROOM	7.3	15.1	11.5	0.3	23.4

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL49

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R11	RESIDENTIAL	BEDROOM	7.3	12.6	8.8	0.3	30.6
F04	R12	RESIDENTIAL	BEDROOM	7.3	19.4	15.3	0.3	21.1
F04	R13	RESIDENTIAL	BEDROOM	7.3	13.3	9.9	0.3	25.7
F04	R14	RESIDENTIAL	BEDROOM	7.3	25.7	21.4	0.3	16.9
F04	R15	RESIDENTIAL	BEDROOM	7.3	14.3	12.6	0.1	11.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL49

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R11	RESIDENTIAL	BEDROOM	7.3	12.6	8.8	0.3	30.6
F04	R12	RESIDENTIAL	BEDROOM	7.3	19.4	15.3	0.3	21.1
F04	R13	RESIDENTIAL	BEDROOM	7.3	13.3	9.9	0.3	25.7
F04	R14	RESIDENTIAL	BEDROOM	7.3	25.7	21.4	0.3	16.9
F04	R15	RESIDENTIAL	BEDROOM	7.3	14.3	12.6	0.1	11.5

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL50

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F04

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R16	RESIDENTIAL	BEDROOM	7.3	42.5	42	0.0	1.1
F04	R17	RESIDENTIAL	BEDROOM	7.4	29	28.7	0.0	1.3
F04	R18	RESIDENTIAL	BEDROOM	7.3	69	68.7	0.0	0.4
F04	R19	RESIDENTIAL	BEDROOM	7.7	54.3	53.9	0.0	0.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL50

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F04


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F04	R16	RESIDENTIAL	BEDROOM	7.3	42.5	42	0.0	1.1
F04	R17	RESIDENTIAL	BEDROOM	7.4	29	28.7	0.0	1.3
F04	R18	RESIDENTIAL	BEDROOM	7.3	69	68.7	0.0	0.4
F04	R19	RESIDENTIAL	BEDROOM	7.7	54.3	53.9	0.0	0.6

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL51

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID



F05


FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R1	RESIDENTIAL	UNKNOWN	21.7	45.9	45.6	0.1	0.6
F05	R2	RESIDENTIAL	UNKNOWN	13.1	82.5	82.4	0.0	0.1
F05	R3	RESIDENTIAL	BEDROOM	7.3	7.4	5.3	0.2	28.1
F05	R4	RESIDENTIAL	BEDROOM	7.3	8.7	5	0.3	42.6
F05	R5	RESIDENTIAL	BEDROOM	7.3	8	6.4	0.1	20.9

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL51

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R1	RESIDENTIAL	UNKNOWN	21.7	45.9	45.6	0.1	0.6
F05	R2	RESIDENTIAL	UNKNOWN	13.1	82.5	82.4	0.0	0.1
F05	R3	RESIDENTIAL	BEDROOM	7.3	7.4	5.3	0.2	28.1
F05	R4	RESIDENTIAL	BEDROOM	7.3	8.7	5	0.3	42.6
F05	R5	RESIDENTIAL	BEDROOM	7.3	8	6.4	0.1	20.9

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL52

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R6	RESIDENTIAL	BEDROOM	7.3	12.2	7.5	0.3	38.9
F05	R7	RESIDENTIAL	BEDROOM	7.3	11.6	8.1	0.3	29.8
F05	R8	RESIDENTIAL	BEDROOM	7.3	16.3	10.7	0.4	34.5
F05	R9	RESIDENTIAL	BEDROOM	7.3	14	9.2	0.4	34.7
F05	R10	RESIDENTIAL	BEDROOM	7.3	18.1	12.9	0.4	28.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL52

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R6	RESIDENTIAL	BEDROOM	7.3	12.2	7.5	0.3	38.9
F05	R7	RESIDENTIAL	BEDROOM	7.3	11.6	8.1	0.3	29.8
F05	R8	RESIDENTIAL	BEDROOM	7.3	16.3	10.7	0.4	34.5
F05	R9	RESIDENTIAL	BEDROOM	7.3	14	9.2	0.4	34.7
F05	R10	RESIDENTIAL	BEDROOM	7.3	18.1	12.9	0.4	28.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL53

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R11	RESIDENTIAL	BEDROOM	7.3	15.4	10.2	0.4	33.9
F05	R12	RESIDENTIAL	BEDROOM	7.3	22.4	16.7	0.4	25.3
F05	R13	RESIDENTIAL	BEDROOM	7.3	16	11.2	0.4	30.3
F05	R14	RESIDENTIAL	BEDROOM	7.3	27.9	22.6	0.4	19.1
F05	R15	RESIDENTIAL	BEDROOM	7.3	15.6	13.7	0.1	12.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL53

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R11	RESIDENTIAL	BEDROOM	7.3	15.4	10.2	0.4	33.9
F05	R12	RESIDENTIAL	BEDROOM	7.3	22.4	16.7	0.4	25.3
F05	R13	RESIDENTIAL	BEDROOM	7.3	16	11.2	0.4	30.3
F05	R14	RESIDENTIAL	BEDROOM	7.3	27.9	22.6	0.4	19.1
F05	R15	RESIDENTIAL	BEDROOM	7.3	15.6	13.7	0.1	12.3

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL54

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R16	RESIDENTIAL	BEDROOM	7.3	42.9	42.2	0.1	1.8
F05	R17	RESIDENTIAL	BEDROOM	7.4	29.2	28.8	0.0	1.4
F05	R18	RESIDENTIAL	BEDROOM	7.3	69	68.8	0.0	0.3
F05	R19	RESIDENTIAL	BEDROOM	7.7	54.3	53.9	0.0	0.7

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL54

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F05

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F05	R16	RESIDENTIAL	BEDROOM	7.3	42.9	42.2	0.1	1.8
F05	R17	RESIDENTIAL	BEDROOM	7.4	29.2	28.8	0.0	1.4
F05	R18	RESIDENTIAL	BEDROOM	7.3	69	68.8	0.0	0.3
F05	R19	RESIDENTIAL	BEDROOM	7.7	54.3	53.9	0.0	0.7


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL55

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R1	RESIDENTIAL	UNKNOWN	21.7	74	73.8	0.0	0.3
F06	R2	RESIDENTIAL	UNKNOWN	13.1	94.8	94.8	0.0	0
F06	R3	RESIDENTIAL	BEDROOM	7.3	8.2	6.3	0.1	23
F06	R4	RESIDENTIAL	BEDROOM	7.3	10.4	7.1	0.2	31.4
F06	R5	RESIDENTIAL	BEDROOM	7.3	8.7	7.2	0.1	17.1


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL55

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R1	RESIDENTIAL	UNKNOWN	21.7	74	73.8	0.0	0.3
F06	R2	RESIDENTIAL	UNKNOWN	13.1	94.8	94.8	0.0	0
F06	R3	RESIDENTIAL	BEDROOM	7.3	8.2	6.3	0.1	23
F06	R4	RESIDENTIAL	BEDROOM	7.3	10.4	7.1	0.2	31.4
F06	R5	RESIDENTIAL	BEDROOM	7.3	8.7	7.2	0.1	17.1

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL56

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R6	RESIDENTIAL	BEDROOM	7.3	14.7	9.8	0.4	33.2
F06	R7	RESIDENTIAL	BEDROOM	7.3	14.3	10.1	0.3	29.4
F06	R8	RESIDENTIAL	BEDROOM	7.3	20.5	13	0.5	36.5
F06	R9	RESIDENTIAL	BEDROOM	7.3	18.1	11.8	0.5	35.1
F06	R10	RESIDENTIAL	BEDROOM	7.3	22.8	15.4	0.5	32.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL56

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R6	RESIDENTIAL	BEDROOM	7.3	14.7	9.8	0.4	33.2
F06	R7	RESIDENTIAL	BEDROOM	7.3	14.3	10.1	0.3	29.4
F06	R8	RESIDENTIAL	BEDROOM	7.3	20.5	13	0.5	36.5
F06	R9	RESIDENTIAL	BEDROOM	7.3	18.1	11.8	0.5	35.1
F06	R10	RESIDENTIAL	BEDROOM	7.3	22.8	15.4	0.5	32.6

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL57

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R11	RESIDENTIAL	BEDROOM	7.3	20.2	12.7	0.5	37.1
F06	R12	RESIDENTIAL	BEDROOM	7.3	27.3	19.5	0.6	28.5
F06	R13	RESIDENTIAL	BEDROOM	7.3	20.8	13.9	0.5	33.1
F06	R14	RESIDENTIAL	BEDROOM	7.3	31.5	24.7	0.5	21.7
F06	R15	RESIDENTIAL	BEDROOM	7.3	17.7	15.1	0.2	14.8

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL57

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R11	RESIDENTIAL	BEDROOM	7.3	20.2	12.7	0.5	37.1
F06	R12	RESIDENTIAL	BEDROOM	7.3	27.3	19.5	0.6	28.5
F06	R13	RESIDENTIAL	BEDROOM	7.3	20.8	13.9	0.5	33.1
F06	R14	RESIDENTIAL	BEDROOM	7.3	31.5	24.7	0.5	21.7
F06	R15	RESIDENTIAL	BEDROOM	7.3	17.7	15.1	0.2	14.8

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL58

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R16	RESIDENTIAL	BEDROOM	7.3	43.2	42.4	0.1	2
F06	R17	RESIDENTIAL	BEDROOM	7.4	29.6	29	0.0	1.9
F06	R18	RESIDENTIAL	BEDROOM	7.3	69.2	68.9	0.0	0.4
F06	R19	RESIDENTIAL	BEDROOM	7.7	54.4	54.3	0.0	0.2

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: LAMBERT HALL
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL58

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
LAMBERT HALL								
F06	R16	RESIDENTIAL	BEDROOM	7.3	43.2	42.4	0.1	2
F06	R17	RESIDENTIAL	BEDROOM	7.4	29.6	29	0.0	1.9
F06	R18	RESIDENTIAL	BEDROOM	7.3	69.2	68.9	0.0	0.4
F06	R19	RESIDENTIAL	BEDROOM	7.7	54.4	54.3	0.0	0.2



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL59

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F00	R1	RESIDENTIAL	BEDROOM	14.8	64.4	64.4	0.0	0
F00	R2	RESIDENTIAL	LKD	19.1	60.4	60.4	0.0	0
F01	R1	RESIDENTIAL	BEDROOM	14.8	78.8	78.8	0.0	0
F01	R2	RESIDENTIAL	LKD	19.1	75.3	75.3	0.0	0
F01	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F01	R4	RESIDENTIAL	LKD	22.9	92.3	92.3	0.0	0
F02	R1	RESIDENTIAL	BEDROOM	14.8	83.1	83.1	0.0	0
F02	R2	RESIDENTIAL	LKD	19.1	85	85	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL59

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F00	R1	RESIDENTIAL	BEDROOM	14.8	64.4	64.4	0.0	0
F00	R2	RESIDENTIAL	LKD	19.1	60.4	60.4	0.0	0
F01	R1	RESIDENTIAL	BEDROOM	14.8	78.8	78.8	0.0	0
F01	R2	RESIDENTIAL	LKD	19.1	75.3	75.3	0.0	0
F01	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F01	R4	RESIDENTIAL	LKD	22.9	92.3	92.3	0.0	0
F02	R1	RESIDENTIAL	BEDROOM	14.8	83.1	83.1	0.0	0
F02	R2	RESIDENTIAL	LKD	19.1	85	85	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL60

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F02	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F02	R4	RESIDENTIAL	LKD	22.9	99.2	99.2	0.0	0
F03	R1	RESIDENTIAL	BEDROOM	14.8	90.7	90.7	0.0	0
F03	R2	RESIDENTIAL	LKD	19.1	94.7	94.7	0.0	0
F03	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F03	R4	RESIDENTIAL	LKD	22.9	99.2	99.2	0.0	0
F04	R1	RESIDENTIAL	BEDROOM	14.8	100	100	0.0	0
F04	R2	RESIDENTIAL	LKD	19.1	99.9	99.9	0.0	0



NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL60

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F02	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F02	R4	RESIDENTIAL	LKD	22.9	99.2	99.2	0.0	0
F03	R1	RESIDENTIAL	BEDROOM	14.8	90.7	90.7	0.0	0
F03	R2	RESIDENTIAL	LKD	19.1	94.7	94.7	0.0	0
F03	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F03	R4	RESIDENTIAL	LKD	22.9	99.2	99.2	0.0	0
F04	R1	RESIDENTIAL	BEDROOM	14.8	100	100	0.0	0
F04	R2	RESIDENTIAL	LKD	19.1	99.9	99.9	0.0	0


NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL61

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F04	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F04	R4	RESIDENTIAL	LKD	22.9	99.2	99.1	0.0	0
F05	R1	RESIDENTIAL	BEDROOM	14.8	99.9	99.9	0.0	0
F05	R2	RESIDENTIAL	LKD	19.1	99.9	99.9	0.0	0
F05	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F05	R4	RESIDENTIAL	LKD	22.9	98.9	98.9	0.0	0

NSL CONTOURS



PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL61

KEY:
 GAIN
 LOSS
 MAINTAINED LIT AREA
 1 METRE GRID




FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F04	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F04	R4	RESIDENTIAL	LKD	22.9	99.2	99.1	0.0	0
F05	R1	RESIDENTIAL	BEDROOM	14.8	99.9	99.9	0.0	0
F05	R2	RESIDENTIAL	LKD	19.1	99.9	99.9	0.0	0
F05	R3	RESIDENTIAL	BEDROOM	15.2	100	100	0.0	0
F05	R4	RESIDENTIAL	LKD	22.9	98.9	98.9	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL62

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID




F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F06	R1	RESIDENTIAL	BEDROOM	14.8	96.7	96.7	0.0	0
F06	R2	RESIDENTIAL	LKD	19.1	98.7	98.7	0.0	0
F06	R3	RESIDENTIAL	BEDROOM	15.2	96.7	96.7	0.0	0
F06	R4	RESIDENTIAL	LKD	22.9	98.1	98	0.0	0

PROJECT: 0298 - ECHO STREET, MANCHESTER
 REPORT TITLE: CONSENTED VS. PROPOSED
 ADDRESS: STONEBRIDGE HOUSE
 DATE: 16/03/2023
 SCHEME IR: IR016
 DRAWING No.: 0298-REL06-IS03-NSL62

KEY:

- GAIN
- LOSS
- MAINTAINED LIT AREA
- 1 METRE GRID



F06

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM AREA-sqm	EXISTING %	PROPOSED %	LOSS-sqm	LOSS %
STONEBRIDGE HOUSE								
F06	R1	RESIDENTIAL	BEDROOM	14.8	96.7	96.7	0.0	0
F06	R2	RESIDENTIAL	LKD	19.1	98.7	98.7	0.0	0
F06	R3	RESIDENTIAL	BEDROOM	15.2	96.7	96.7	0.0	0
F06	R4	RESIDENTIAL	LKD	22.9	98.1	98	0.0	0