

Hammerstone Road

Based on information provided the site consumption will be 650kWh per annum.

The assumption is the energy will be used evenly throughout the year and that 90% of the consumption will be utilised during the day. The generation Vs usage will be reviewed based on daytime consumption of 585kW per annum.

Month	Day time	Night time	Total
Jan	48,750	5,417	54,167
Feb	48,750	5,417	54,167
Mar	48,750	5,417	54,167
Apr	48,750	5,417	54,167
May	48,750	5,417	54,167
Jun	48,750	5,417	54,167
Jul	48,750	5,417	54,167
Aug	48,750	5,417	54,167
Sep	48,750	5,417	54,167
Oct	48,750	5,417	54,167
Nov	48,750	5,417	54,167
Dec	48,750	5,417	54,167
Total	585,000	65,000	650,000
	90%	10%	

Generation Vs Consumption

The system will generate 750,571kWh per annum, 80% of energy consumption will be self generated during the daytime based on this system size.

