


RISK ASSESSMENT

Risk Assessment Reference: 027 PORTABLE ELECTRICAL EQUIPMENT					Assessor: Andy Palmer		Area/Location: Main workshop + site work		
Persons Exposed:		No of Employees: 10+		No of Contractors: 0		No of Public/Visitors: 0		Total No exposed: 10+	
Hazard	Risk	Risk Rating			Control Measures to Reduce Risk	Residual Risk			
		Probability	Severity	Risk		Probability	Severity	Risk	
Misuse of equipment or poorly maintained equipment	Injury to the eyes and other parts of the body	3	3	9	All portable electrical equipment is subject to an inspection, testing and maintenance regime. Tools must have been subject to a portable appliance test and be in good working order prior to being used. All equipment found to be defective, will be switched off and removed from site immediately. All operatives using portable electrical equipment must be trained and competent. Eye protection and ear defenders must be worn. Persons in close proximity to the work area must also adopt the relevant PPE. All equipment used on site must be 110volt or less. All works involving electrical equipment must be monitored by the supervisor in order to ensure safe use.	1	3	3	
Signed by: 					Date carried out: 31/01/2022				
Additional control measures to reduce risks to lowest level possible					Action Plan		Completed		
					By	Date	By	Date	