


**THIS DRAWING SHALL BE PRINTED IN COLOUR
TO FULLY UNDERSTAND CONCEPTUAL
REQUIREMENTS SHOWN WITHIN**



INDICATIVE RADIATOR LOCATION ON FIRST FLOOR



NEW MIHS KENTWELL TRV

CONNECT NEW Ø15 LTHW HTG FLOW AND RETURN BRANCHES TO EXISTING AT HIGH LEVEL

EXISTING Ø15 LTHW HTG FLOW AND RETURN PIPES AT HIGH LEVEL



PROPOSED LOCATION OF NEW RADIATOR IN CORRIDOR.
NEW Ø15 LTHW HTG SUPPLY AND RETURN PIPES TO RISE
FROM BELOW TO SERVE NEW RADIATOR.
NEW RADIATOR TO BE FLOOR STANDING SIMILAR TO EXISTING
RADIATORS.

NOTES

1. EXISTING HEATING FLOW AND RETURN PIPEWORK TO BE ISOLATED AND DRAINED BEFORE NEW PIPEWORK IS INSTALLED.

TENDER

ORMOND BUILDING COUNCIL CHAMBER

230543-CPW-XX-XX-DR-M-121002 S0 T0

Linked Files: