

REPORT TITLE:

Dixons Manchester Academy, Greenbrow Rd, Manchester, M23 2SX.–

Acoustic Survey.

CLIENT DETAILS:

Arcadis

DATE:

29th April 2022

REPORT REFERENCE:

PC-22-0086-RP1

PREPARED BY:

Joan-Carles Blanco BSc (Hons) MIOA

CHECKED/AUTHORISED BY:

Martin Jones BSc (Hons) MIOA

Contents

1	Introduction	3
2	Environmental Methodology	4
2.1	Perception	4
2.2	Legislation and Policy	5
2.2.1	National Planning Policy Framework and the Noise Policy Statement for England	5
2.2.2	Acoustic design of schools: performance standards	6
2.2.3	Acoustics of Schools: a design guide.....	10
2.2.4	British Standard BS4142: 2014 +A1:2019, <i>Methods for rating and assessing industrial and commercial sound</i>	11
3	Noise Survey Details.....	13
4	Noise from mechanical plant	18
5	Indoor ambient noise levels.....	19
6	Conclusions	20
	Appendix 1 – ANC Membership	21

Document Status and Revision Schedule

Issue/Revision	Description/Comments	Date	Prepared by	Approved by
-	Checked & Authorised	06/01/22	JCB	MJ

1 Introduction

Pace Consult Limited was commissioned by Arcadis to undertake a noise survey and assessment of the existing noise sources affecting the existing and proposed school buildings at Dixons Manchester Academy, Greenbrow Rd, Manchester, M23 2SX.

This report assesses the noise impact of the dominant noise sources affecting the existing and proposed school buildings.

This report also provides a noise limiting criteria against the noise emission from mechanical services if this ventilation strategy is considered.

This report has been prepared in accordance with national standards such as BB93 (February 2015 edition), and BS4142: 2014, *Method for Rating Industrial Noise affecting Mixed Residential and Industrial Areas*.

The prevalent noise sources affecting the existing and proposed school is sporadic traffic noise from Greenbrow Rd, Clay Ln, and aircraft noise.

The measurements results show that the existing and proposed school buildings have the potential to be natural ventilated via openable windows as the noise levels from the existing noise sources are considered low.

2 Environmental Methodology

2.1 Perception

Noise is defined as unwanted sound. Human ears are able to respond to sound over the frequency range of about 20 Hz to 20 kHz and over the audible range of 0 dB (the threshold of perception) to 140 dB (the threshold of pain). The ear does not respond equally to different frequencies of the same magnitude and is more responsive to mid-frequencies than to lower or higher frequencies. To quantify noise in a manner that approximates to the response of the human ear, a weighting mechanism is used. This reduces the importance of lower and higher frequencies, in a similar manner to the human ear. To help understand the range of noise levels which may be encountered, an indication of the level of some common sounds on the dB(A) scale is given in the table below.

Common Sounds on the dB(A) Scale	
dB(A)	Description
140	Threshold of pain
120	Jet take off at 50 metres
100	Maximum noise levels on an underground platform
80	Kerbside of a busy urban street
60	Busy general office
40	Residential area at night
20	Background in a TV and recording studio
0	Threshold of hearing

Furthermore, the perception of noise may be determined by a number of other factors, both acoustic and non-acoustic. In general, the impact of noise depends upon its level, the margin by which it exceeds the background level, its character and its variation over a given period of time.

In addition, the time of day and other acoustic features such as tonality may be important, as may the disposition of the affected individual receptor. Any assessment of noise should give due consideration to all of these factors when assessing the significance of a noise source.

The most widely used weighting mechanism that corresponds to the response of the human ear is the A-weighting scale. This is widely used for environmental noise measurement, and the levels are denoted as dB(A) or L_{Aeq} , L_{A90} , etc., according to the parameter being measured.

The decibel scale is logarithmic rather than linear, and hence a 3 dB increase in sound level represents a doubling of the sound energy present. Judgement of sound is subjective, but as a general guide a 10 dB(A) increase can be taken to represent a doubling of loudness, whilst an increase in the order of 3 dB(A) of a steady source is generally regarded as the minimum difference needed to perceive a change.

2.2 Legislation and Policy

2.2.1 National Planning Policy Framework and the Noise Policy Statement for England

National Planning Policy Framework and the Noise Policy Statement for England

The National Planning Policy Framework (NPPF) sets out the general requirements for gaining planning permission. Comments regarding noise found within the document are as follows.

S15. Para 174

Planning policies and decisions should contribute to and enhance the natural and local environment by:

e) preventing new and existing development from contributing to, being put at unacceptable risk from, or being adversely affected by, unacceptable levels of soil, air, water or noise pollution or land instability.

Para 185

185. Planning policies and decisions should also ensure that new development is appropriate for its location taking into account the likely effects (including cumulative effects) of pollution on health, living conditions and the natural environment, as well as the potential sensitivity of the site or the wider area to impacts that could arise from the development. In doing so they should:

a) mitigate and reduce to a minimum potential adverse impacts resulting from noise from new development – and avoid noise giving rise to significant adverse impacts on health and the quality of life;

b) identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.

The NPPF references the Noise Policy Statement for England (NPSE) which in turn references two concepts used by the World Health Organisation (WHO) which can be used to ascertain relevant noise levels for individual sites. The concepts are LOAEL (Lowest Observed Adverse Effect Level) and SOAEL (Significant Observed Adverse Effect Level).

The NPPF then gives three aims to adhere to:

Aim 1 – Avoid significant adverse impacts on health and quality of life from environmental, neighbour and neighbourhood noise within the context of Government policy on sustainable development.

Aim 2 – Mitigate and minimise adverse impacts on health and quality of life from environmental, neighbour and neighbourhood noise within the context of Government policy on sustainable development.

Aim 3 – Where possible, contribute to the improvement of health and quality of life through the effective management and control of environmental, neighbour and neighbourhood noise within the context of Government policy on sustainable development.

To avoid 'significant adverse impacts on health and quality of life', by creating a situation where the impact of noise lies below the SOAEL we will refer to BB93.

2.2.2 Acoustic design of schools: performance standards

The objective is to provide suitable indoor ambient noise levels (IANL) for

- a) clear communication of speech between teacher and student
- b) clear communication between students
- c) learning and study activities

The IANL includes noise contributions from:

- external sources outside the school premises (including, but not limited to, noise from road, rail and air traffic, industrial and commercial premises)
- building services (eg, ventilation systems, plant, drainage etc). If a room is naturally ventilated, the IANL is calculated and measured with ventilators or windows open as required to provide ventilation as described in section 1.1.3. If a room is mechanically ventilated or cooled, the plant should be assumed to be running at its normal operating duty.

The IANL excludes noise contributions from:

- teaching activities within the school premises, including noise from staff, students and equipment within the building or in the playground (noise transmitted from adjacent spaces is addressed by the airborne and impact sound insulation requirements)
- equipment used in the space (eg machine tools, CadCam machines, dust and fume extract equipment, compressors, computers, projectors, fume cupboards) as these noise sources are considered as operational noise, see 0.3.8
- rain noise - however, Building Regulation submissions should demonstrate that lightweight roofs and roof glazing have been designed to provide suitable control of rain noise reverberant sound pressure level in a space (calculated using laboratory test data with 'heavy' rain noise excitation as defined in BS EN ISO 140-18).

Levels during heavy rain should not be more than 25 dB above the appropriate indoor ambient noise level given in table 1 (for refurbishments, this applies only to new roofing elements and not to repairs to existing roofs). Table 1 specifies upper limits for indoor ambient noise levels in terms of $L_{Aeq,30mins}$ during normal teaching hours. Values for refurbishment are also the minimum acceptable standards for alternative performance standards in new buildings.

Table 1: noise activity and sensitivity levels and upper limits for indoor ambient noise level		
Type of room	Upper limit for the indoor ambient noise level $L_{Aeq,30mins}$ dB	
	New build	Refurbishment
Nursery school rooms		
Primary school: classroom, class base, general teaching area, small group room	35	40
Secondary school: classroom, general teaching area, seminar room, tutorial room, language laboratory		
Open plan: Teaching area Resource/breakout area	40	45
Primary music room	35	40
Secondary music classroom Small and large practice/group room1 Performance/recital room	35	40
Ensemble room Recording studio	30	35
Control room - for recording Control room - not for recording	35	40
Lecture room	35	40
Teaching space intended specifically for students with special hearing and communication needs	30	35
SEN calming room	35	35
Study room (individual study, withdrawal, remedial work, teacher preparation)	40	45
Libraries: Quiet study area Resource area	40 40	45 45
Science laboratory	40	45

Type of room	Upper limit for the indoor ambient noise level L _{Aeq} ,30mins dB	
	New build	Refurbishment
Design and technology: Resistant materials, CAD/CAM area	40	45
Electronics/control, textiles, food, graphics, design/resource area, ICT room, art	40	45
Drama studio, assembly hall, multi-purpose hall (drama, PE, audio/visual presentations, assembly, occasional music)	35	40
Atrium, circulation space not intended for teaching and learning	45	50
Sports hall Dance studio Gymnasium/Activity studio	40	45
Swimming pool	50	55
Meeting room, Interviewing/counselling room, video conference room	40	45
Dining room	45	50
Administration and ancillary spaces: Kitchen Office, medical room, staff room Corridor, stairwell, coats and locker area Changing area Toilet	 50 40 45 50 50	 55 45 55 55 55

In order to protect students from regular discrete noise events, eg, aircraft or trains, indoor ambient noise levels should not exceed 60 dB L_{A1}, 30mins. This is achieved by default for spaces with IANLs up to 40 dB L_{Aeq}, 30min, but requires assessment in spaces with higher IANL limits, eg, 45 and 50 dB.

Noise from building services under normal conditions should meet the limits for indoor ambient noise levels (IANL) given in table 1. The table 2 of BB93 recommends the IANL according to different type of ventilation.

Table 2. Summary of ventilation condition, system type and associated IANL tolerance.		
Condition	Ventilation system	Noise level limit
Normal - ventilation for normal teaching and learning activities	Mechanical (1)	Table 1 value
	Natural (2)	Table 1 value + 5 dB (4)
	Hybrid (2)	Mechanical system noise: Table 1 value
		Total noise level: Table 1 value + 5 dB
Summertime (5) - ventilation under local control of teacher to prevent overheating – allowable during the hottest 200 hrs of the year	Mechanical	Table 1 value + 5 dB (4)
	Natural or Hybrid	≤55 dB
Intermittent boost (6) – ventilation under local control of teacher for dilution of fumes during practical activities as in practical spaces for science, art, food technology and design and technology	Mechanical	Table 1 value + 5 dB (4)
	Natural	≤55 dB

Notes: **1** The normal condition for a ventilation system with purely mechanical air supply is defined as when the system is operating to limit the daily average carbon dioxide concentration to no more than 1,000ppm with the maximum concentration not exceeding 1,500ppm for more than 20 consecutive minutes on any day during normal school operating hours. This would normally equate to a minimum ventilation rate of approximately 8l/s per person. Mechanical ventilation in this context refers to systems (or parts of systems) that use mechanical fans to mix or drive the air including those in mechanical, hybrid, mixed mode and natural ventilation systems and in fan convector heaters.

2 The normal condition for a ventilation system in natural or hybrid mode is defined as when the system is operating to limit the daily average carbon dioxide concentration to no more than 1,500ppm with the maximum concentration not exceeding 2,000ppm for more than 20 consecutive minutes on any day. This would normally equate to a minimum ventilation rate of approximately 5l/s per person. For hybrid systems, the mechanical noise excluding external noise break in, should meet the IANL figure in table 1.

4 The +5 dB does not apply to teaching and learning spaces where the Table 1 IANL is greater than or equal to 45 dB.

5 Natural, mechanical or hybrid ventilation systems may be used to improve thermal comfort in summer at the expense of higher indoor ambient noise levels. The normal ventilation IANL can be exceeded during the hottest 200 hours in peak summertime conditions and the design should show that IANLs, defined in table 3 can be met under these conditions as well as under normal operation. The ventilation must be under the local control of the teacher so that the noise level can be reduced to normal levels when needed. This does not apply to classrooms intended specifically for students with special hearing and communication needs, or to speech therapy rooms.

6 The noise level from locally controlled intermittent boost mechanical ventilation may exceed the IANL by up to 5 dB.

2.2.3 Acoustics of Schools: a design guide.

This guideline has been produced by the Institute of Acoustics and the Association of Noise Consultants to provide supporting guidance and recommendations on the acoustic design of new and refurbished schools. It replaces the guidance previously published in the 2003 edition of Building Bulletin 93: Acoustic Design of Schools.

Chapter 2 of this guideline includes recommendations for maximum external sound levels on playing fields, recreational areas and areas used for outdoor teaching. Guidance is also given on the design of roofs and the external façade, on ventilation strategies to reduce the ingress of external noise, and on the control of noise from equipment.

Section 2.2 includes recommendations for external noise levels outside school buildings. Although Requirement E4 does not apply to external noise, the following recommendations are considered good practice for providing suitable acoustic conditions outside school buildings. For new schools, 60 dB $L_{Aeq,30min}$ should be regarded as an upper limit for external noise at the boundary of external areas used for formal and informal outdoor teaching and recreation. It may be possible to meet the specified indoor ambient noise levels on sites where external noise levels are as high as 70 dB $L_{Aeq,30min}$ but this will require considerable building envelope sound insulation, or screening. Playgrounds, outdoor recreation areas and playing fields are generally considered to be of relatively low sensitivity to noise. Indeed, playing fields may be used as buffer zones to separate school buildings from busy roads where necessary. However, where used for teaching, for example sports lessons, outdoor ambient noise levels have a significant impact on communication in an environment which is already acoustically less favourable than most classrooms.

Noise levels in unoccupied playgrounds, playing fields and other outdoor areas should not exceed 55 dB $L_{Aeq,30min}$ and there should be at least one area suitable for outdoor teaching activities where noise levels are below 50 dB $L_{Aeq,30min}$. If this is not possible, due to a lack of suitably quiet sites, acoustic screening should be used to reduce noise levels in these areas as much as practicable, and an assessment of noise levels and options for reducing these should be carried out. Noise levels can be reduced by up to 10 dBA at positions near an acoustic screen.

2.2.4 British Standard BS4142: 2014 +A1:2019, *Methods for rating and assessing industrial and commercial sound*

This standard sets out a methodology for the assessment of whether noise from factories, industrial premises or fixed installations and sources of an industrial/commercial nature.

The procedure contained in BS4142 for assessing the likelihood of complaints is to compare the measured or predicted noise level from the source in question, the 'specific noise level', at the assessment position with the correct background noise level for the worst case time of operation.

Where the noise contains a 'distinguishable, discreet, continuous note (whine, hiss, screech, hum etc.) or if there are distinct impulses in the noise (bangs, clicks or clatters), or if the noise is irregular enough to attract attention' then a range of correction factors can be added to the specific noise level as appropriate to obtain the 'rating level'.

As this is a prescriptive report prior to plant installation, overall rating noise levels will be specified for the new installation. Compliance with the rating value will be necessary to provide evidence that significant adverse impact has been avoided as required by the NPSE.

To assess the likelihood of complaints, the measured background noise level is subtracted from the rating noise level. BS4142 states:

The significance of sound of an industrial and/or commercial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs. An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessment and arriving at decisions, therefore, it is essential to place the sound in context.

Obtain an initial estimate of the impact of the specific sound by subtracting the measured background sound level (See Clause 8) from the rating level (see Clause 9) and consider the following.

- a) Typically the greater the difference, the greater the magnitude of the impact.
- b) A difference of around +10dB or more is likely to be an indication of a significant adverse impact, depending on the context.

c) A difference of around 5dB is likely to be an indication of an adverse impact, depending on the context.

d) The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.

Where the initial estimate of the impact needs to be modified due to the context, take all pertinent factors into consideration, including the following.

1) The absolute level of sound. For a given difference between the rating level and the background sound level, the magnitude of the overall impact might be greater for an acoustic environment where the residual sound level is high than for an acoustic environment where the residual sound level is low.

Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night.

Where residual sound levels are very high, the residual sound might itself result in adverse impacts or significant adverse impacts, and the margin by which the rating level exceeds the background might simply be an indication of the extent to which the specific sound source is likely to make those impacts worse.

2) The character and level of the residual sound compared to the character and level of the specific sound. Consider whether it would be beneficial to compare the frequency spectrum and temporal variation of the specific sound with that of the ambient or residual sound, to assess the degree to which the specific sound source is likely to be distinguishable and will represent an incongruous sound by comparison to the acoustic environment that would occur in the absence of the specific sound. Any sound parameters, sampling periods and averaging time periods used to undertake character comparisons should reflect the way in which sound of an industrial and/or commercial nature is likely to be perceived and how people react to it.

3) The sensitivity of the receptor and whether dwellings or other premises used for residential purposes will already incorporate design measures that secure good internal and/or outdoor acoustic conditions, such as: i) Façade sound insulation treatment, ii)

Ventilation and/or cooling that will reduce the need to have windows open so as to provide rapid or purge ventilation; and Acoustic screening.

3 Noise Survey Details

The noise survey was carried out on site on Wednesday 27th and Thursday 28th April 2022. The survey locations (MP) are indicated on the image below.



Figure 1. Noise measurement location.

The noise survey locations are considered representative of the noise levels affecting all school boundaries, and therefore, the measured noise levels at each location are suitable to provide the require noise information for the feasibility study of the project.

The noise levels at the measurement positions (MP2, and MP3) are representative of the existing background affecting the nearest residential dwellings which have the potential to be affected by the operation of the school.

The nearest noise sensitive receptors have been identified at Copenhurst Cl, and Clay Lane.

The survey was carried out at a height of 1.5 metres above local ground and 3 m from any reflective surface in accordance with the principles of BS 7445:2003 Parts 1-3, '*Description and Measurement of Environmental Noise*'.

In order to evaluate the weather conditions three weather check measurements were undertaken on site (beginning, during, and at the end of the measurement period). During the weather checks, it was noted that the climatic conditions were stable. During the visits the sky was clouded.

Table 3: Weather conditions				
	°C	Wind speed m/s	Relative Humidity %	Wind direction
1 st visit (16:00) Wednesday	13.4	1.0	63	S
2 nd visit (09:00) Thursday	12.6	1.2	60	SE
3 rd visit (13:00) Thursday	14.3	0.8	58	S

The weather conditions were measured using a Pocket weather tracker KESTREL 4500.

The survey location is explained in detail below.

MP1 (Unattended noise monitoring). The sound level meter was tripod mounted at 1.5 m above the ground floor levels, and 3 metres from any reflective surface.

This position is representative of the main noise source affecting the southern boundaries of the existing school.

MP2 (Unattended noise monitoring). The sound level meter was tripod mounted at 1.5 m above the ground floor levels, and 3 metres from any reflective surface.

This position is representative of the main noise source affecting the western boundary of the existing school.

MP3 (Unattended noise monitoring). The sound level meter was tripod mounted at 1.5 m above the ground floor levels, and 3 metres from any reflective surface.

This position is representative of the main noise source affecting the northern boundary of the school where the new school building is proposed.

All measurements were made with a calibrated precision grade sound level meters Svantek 971 (Serial no 34937, 34931 and 34927) which achieves the requirements of BS EN 61672: 2003.

The sound level meter was calibrated before and after the measurement period using a Norsonic 1251 calibrator Serial number 32199, no significant drift had occurred.

The table below shows the measured data.

Table 4. Noise measurements at MP1.

Position	Time period	L _{Aeq,5 min} dB (Log average)	L _{A90, 5 min} dB Lowest measured	L _{A1} dB Percentile 95%
MP1	07:00-16:00	52	41	63
	16:00-23:00	52	44	65
	23:00-07:00	46	35	61

Table 5. Noise measurements at MP2.

Position	Time period	L _{Aeq,15 min} dB (Log average)	L _{A90, 15 min} dB Lowest measured	L _{A1} dB Percentile 95%
MP2	07:00-16:00	49	34	61
	16:00-23:00	48	37	58
	23:00-07:00	45	28	61

Table 6. Noise measurements at MP3.

Position	Time period	L _{Aeq,15 min} dB (Log average)	L _{A90, 15 min} dB Lowest measured	L _{A1} dB Percentile 95%
MP3	07:00-16:00	42	35	53
	16:00-23:00	42	34	53
	23:00-07:00	38	28	53

The noise measurements included in the above tables excluded the noise contribution from pupils as recommended by BB93.

The figure below shows the measured sound levels during the entire noise survey MP1.




Figure 2. Measured sound levels. MP1

The figure below shows the measured sound levels during the entire noise survey MP2.




Figure 3. Measured sound levels. MP2

The figure below shows the measured sound levels during the entire noise survey MP3.




Figure 4. Measured sound levels. MP3

4 Noise from mechanical plant

The noise impact of items of plant and fixed installation has been determined in accordance with BS4142: 2014.

Noise levels generated by mechanical plant and experienced by local receptors depends upon several variables, the most significant of which are:

- the noise generated by plant on site, generally expressed as sound power levels (SWL);
- the distance between the noise source and the receptor;
- the attenuation due to ground absorption, atmospheric and barrier effects; and
- the periods of operation of the plant on the site, known as its “on-time”.

The proposed plant should be assessed in accordance with the guidance contained within British Standard BS4142: 2014.

Based on the above criteria, the plant limit is set up in the below table to equal the lowest L_{A90} background noise measurement recorded during the daytime period of the survey.

Table 5: Summary of the recommended Noise Rating Level dB	
Period	Recommended Rating Noise Level $L_{A,T}$ (dB)
Northern Boundary	34
Western Boundary	37

Note: Where the noise contains a ‘distinguishable, discreet, continuous note (whine, hiss, screech, hum etc.) or if there are distinct impulses in the noise (bangs, clicks, clatters or humps), or if the noise is irregular enough to attract attention’ then a correction of up to 6 dB is added to the specific noise level to obtain the ‘rating level’.

There are a number of measures that can be introduced to control noise from the mechanical and fixed plant installation associated with the proposed development. Consideration should be given to reducing noise at point of generation (e.g. by selecting quiet plant) or containment of noise generated (e.g. by insulating buildings which house machinery and/or providing purpose-built barriers around the site).

Generally, measures should be proportionate and reasonable and may include practical engineering solutions, site layout and procedural matters. In general plant noise levels should be limited such that any noise impact would be negligible.

5 Indoor ambient noise levels.

Internal noise levels within the existing and proposed new building are based on the requirements specified in table 1 of BB93 February 2015.

The existing noise climate has been assessed across three different areas along the school boundaries.

The sound levels affecting the boundaries of the school are considered low, and therefore, and therefore, natural ventilation via openable windows is recommended.

Building envelope existing school building.

The external facade appears to be typical blockwork construction with internal lining, this type of construction provides a minimum sound reduction of R_w 50 dB. The existing windows are double glazed, which provide a minimum sound reduction of R_w 30 dB. The windows have incorporated trickle vents, based on the thickness of the existing windows, the trickle vent can achieve a minimum sound reduction of $D_{n,e,w}$ 15 dB. Therefore, based on the existing construction the existing school building envelope are considered adequate to meet the internal noise criteria recommended by BB93.

The L_{A1} noise levels based on the above acoustic recommendations are expected to be below the recommended levels of 60 L_{A1} dB.

Building envelope proposed school building.

It is understood that a new building is proposed to the northern area of the school boundary. As the noise levels affecting this area are low, the recommended building envelope should include light weight roof (minimum sound rating of R_w 45 dB), typical cavity wall construction and thermal windows.

External study and recreational areas.

Regarding external noise levels BB93 recommends that for new schools, 60 dB $L_{Aeq,30min}$ should be regarded as an upper limit for external noise at the boundary of external areas used for formal and informal outdoor teaching and recreation.

Based on the above recommendation, the external outdoor teaching and recreation areas meet the recommended external noise criteria.

6 Conclusions

The measured noise levels affecting the existing school building, and the northern boundary of the school where the new school building is proposed are low, and therefore natural ventilation via openable windows is possible.

Plant noise limiting criteria has been proposed based on the lowest measured sound levels which are representative of the levels at the nearest noise sensitive receptor.

Appendix 1 – ANC Membership

The author is a corporate member of the Institute of Acoustics (IOA) which satisfies the experience and qualification requirements for a 'suitably qualified acoustician'. Pace Consult are also full member of the Association of Noise Consultants.

