

DRAWINGS SHALL BE READ IN CONJUNCTION WITH THE FOLLOWING BEFORE WORK COMMENCES:

- THE CDM DESIGN ISSUES REGISTER
- THE RISK SERIES OF DRAWINGS
- THE PROJECT CDM RISK REGISTER

1. All dimensions to be checked on site by the contractor, such dimensions to be his responsibility.
2. Some area measurements are pending safe site access.
3. Building interior is yet to be surveyed. All internal dimensions are indicative.

Please refer to key for further information

P02



A fire escape window's openable area should be less than 1100mm from the floor and should open without obstruction to at least 0.33m² and at least 450mm high or 450mm wide. If one of the dimensions is at the 450mm minimum then the other dimension will need to be at least 734mm to achieve 0.33m².

