



APPENDIX B:

ENVIRONMENTAL STATEMENT
ADDENDUM TO DAYLIGHT,
SUNLIGHT AND
OVERSHADOWING



Jackson's Row Development Ltd

ST MICHAEL'S, JACKSON'S ROW

Environmental Statement Addendum to Daylight,
Sunlight and Overshadowing Chapter





Jackson's Row Development Ltd

ST MICHAEL'S, JACKSON'S ROW

Environmental Statement Addendum to Daylight, Sunlight
and Overshadowing Chapter

TYPE OF DOCUMENT (VERSION) PUBLIC

PROJECT NO. 70101665

OUR REF. NO. 70101665-DSO

DATE: JULY 2023



Jackson's Row Development Ltd

ST MICHAEL'S, JACKSON'S ROW

Environmental Statement Addendum to Daylight, Sunlight
and Overshadowing Chapter

WSP

8 First Street
Manchester
M15 4RP

Phone: +44 161 200 5000

WSP.com

QUALITY CONTROL

Issue/revision	First issue	Revision 1	Revision 2	Revision 3
Remarks	2023 Issue	2023 Issue Rev 1	2023 Issue Rev 2	2019 Issue Final
Date	01 August 2023			
Prepared by	Hamza Alhalabi			
Signature				
Checked by	Camilo Diaz			
Signature				
Authorised by	Camilo Diaz			
Signature				
Project number	70101665			
Report number	70101665-001			
File reference	Environmental Statement Addendum Volume 1			

CONTENTS

1	DAYLIGHT, SUNLIGHT AND OVERSHADOWING	1
1.1	INTRODUCTION	1
1.2	LEGISLATIVE FRAMEWORK AND GUIDANCE	1
1.3	CONSULTATION, SCOPE, METHODOLOGY AND SIGNIFICANCE CRITERIA	2
1.4	BASELINE CONDITIONS	2
1.5	ASSESSMENT OF EFFECTS, MITIGATION AND RESIDUAL EFFECTS	2
1.6	LIMITATIONS AND ASSUMPTIONS	7
1.7	SUMMARY	7
1.8	REFERENCES	7

TABLES

Table 1-1: Summary of Daylight Assessment Results	3
Table 1-2: Summary of Sunlight Assessment Results	5
Table 1-3: Results of Overshadowing Analysis for Open Spaces	6
Table 1-4: Results of Overshadowing Analysis for Open Spaces within the Proposed Scheme	7

FIGURES

Figure 1-1: View of the Proposed Model – south-west	2
Figure 1-2: Overshadowing sensitive receptors within the Proposed Scheme	6

APPENDICES

APPENDIX 1.1	
--------------	--



EXTERNAL DAYLIGHT AND SUNLIGHT RECEPTORS

APPENDIX 1.2

DETAILED EXTERNAL DAYLIGHT AND SUNLIGHT RESULTS

APPENDIX 1.4

INTERNAL OVERSHADOWING RESULTS

APPENDIX 1.6

EXTERNAL OVERSHADOWING ANALYSIS

1 DAYLIGHT, SUNLIGHT AND OVERSHADOWING

1.1 INTRODUCTION

The following additional paragraph has been added to the end of this section:

This chapter assesses the proposed amendments to the daylight, sunlight, and overshadowing assessment presented in the 2019 ES Addendum Volume 1. The proposed amendments alter the massing of the development, in particular the size and shape of the tower. Therefore, a reassessment has been undertaken to quantify the impacts of the proposed amendments on the daylight and sunlight of the existing surrounding properties. Additionally, an overshadowing assessment has been carried out to identify any potential overshadowing impacts to the amenity spaces within the proposed development.

1.2 LEGISLATIVE FRAMEWORK AND GUIDANCE

The following additional paragraph has been added to this section:

NATIONAL PLANNING POLICY FRAMEWORK

- 1.2.24. National Planning Policy Framework (Ref. 1) refers to daylight, sunlight and overshadowing in para 123 (c) of section 11. Making Effective Use of Land:

“123. Where there is an existing or anticipated shortage of land for meeting identified housing needs, it is especially important that planning policies and decisions avoid homes being built at low densities and ensure that developments make optimal use of the potential of each site. In these circumstances:

(c) local planning authorities should refuse applications which they consider fail to make efficient use of land, taking into account the policies in this Framework. In this context, when considering applications for housing, authorities should take a flexible approach in applying policies or guidance relating to daylight and sunlight, where they would otherwise inhibit making efficient use of a site (as long as the resulting scheme would provide acceptable living standards).”

- 1.2.25. Most Local Authorities in the UK recognise the guidelines set out in the BRE Guide Site Layout Planning for Daylight and Sunlight, A Guide to Good Practice (Ref. 2) as the most appropriate method for daylight, sunlight and overshadowing assessments.

LOCAL PLANNING POLICY

No update.

GUIDANCE

An updated version of the BRE guide was published in 2022. However, there is no changes in regard to the external impact assessments, and therefore this should not affect the methodology and criteria followed in 2019 ES Addendum.

- 1.2.26. Paragraph 11.2.8. has been superseded to the following:

Site Layout Planning for Daylight and Sunlight, A Guide to Good Practice

The BRE Guide: Site Layout Planning for Daylight and Sunlight, A Guide to Good Practice (Ref. 2) is recognised as the most appropriate method for daylight, sunlight and overshadowing assessments. These guidelines were first published in 1991 and superseded the 1971 Department of the Environment Document Sunlight and Daylight. The latest edition was published in 2022.

1.3 CONSULTATION, SCOPE, METHODOLOGY AND SIGNIFICANCE CRITERIA

No update.



1.4 BASELINE CONDITIONS

No update.

1.5 ASSESSMENT OF EFFECTS, MITIGATION AND RESIDUAL EFFECTS

1.5.1. Figure 11-3 has been superseded to the following image:

Figure 1-1: View of the Proposed Model – south-west



1.5.2. With regards to daylight, the results of the re-assessment indicated that the proposed amendments to the design are unlikely to significantly affect the results of the 2019 daylight assessment in terms of the impact of the proposed development on to the existing sensitive receptors. The total adversely affected windows changed from 28.4% in 2019 to 29.8% with the current design as shown in Table 11.7.

1.5.3. Based on the updated results, Table 11.7 has been superseded as follows:

Table 1-1: Summary of Daylight Assessment Results

Ref	Receptors	Windows	Windows Above BRE Criteria		Magnitude of Change by Window						Overall Magnitude of Change by Receptor	Sensitivity	Effect
					Below BRE (Small)		Below BRE (Medium)		Below BRE (Large)				
			No.	%	No.	%	No.	%	No.	%			
1	Elliot House	67	16	23.9	15	22.4	12	17.9	24	35.8	Large	Medium	Moderate to Major Negative
2	The Old Nags Head	15	0	0	0	0	0	0	15	100	Large	High	Major Negative
3	19 Jackson's Row	1	0	0	0	0	0	0	1	100	Large	Medium	Moderate to Major Negative
4	Croxley House	23	0	0	0	0	0	0	23	100	Large	Medium	Moderate to Major Negative
5	Lloyds House	95	2	2.1	2	2.1	0	0	91	95.8	Large	Medium	Moderate to Major Negative
6	St John's House	72	56	77.8	16	22.2	0	0	0	0	Small	Medium	Minor Negative
7	Sovereign House	58	13	22.4	22	37.9	21	36.2	2	3.4	Large	Medium	Moderate to Major Negative
8	The Rising Sun	3	0	0	0	0	3	100	0	0	Large	Medium	Moderate to Major Negative
9	Queens Court	30	19	63.3	9	30	1	3.3	1	3.3	Medium	Medium	Moderate Negative
10	Alexandra Buildings	40	39	97.5	1	2.5	0	0	0	0	Negligible	Medium	Negligible
11	Queens House	16	9	56.2	1	6.2	5	31.2	1	6.2	Large	Medium	Moderate to Major Negative
12	Heron House	120	109	90.8	10	8.3	1	0.8	0	0	Small	Med/High	Minor Negative
13	Brazennose House	323	323	100	0	0	0	0	0	0	Negligible	Medium	Negligible
14	Centurion house	72	72	100	0	0	0	0	0	0	Negligible	Medium	Negligible
15	1 Central Street	18	0	0	1	5.6	6	33.3	11	61.1	Large	Medium	Moderate to Major Negative
16	6 Mount St.	2	0	0	0	0	2	100	0	0	Large	High	Major Negative
17	75 Southmill St	59	43	72.9	7	11.9	5	8.5	4	6.8	Small	Medium	Minor Negative
18	Television House	9	3	33.3	4	44.4	2	22.2	0	0	Large	Medium	Moderate to Major Negative
19	37 Peter Street	48	8	16.7	3	6.2	4	8.3	33	68.8	Large	Medium	Moderate to Major Negative
20	11-13 Bootle Street	13	0	0	0	0	0	0	13	100	Large	Medium	Moderate to Major Negative
21	Marron Place Building	60	0	0	0	0	0	0	60	100	Large	Medium	Moderate to Major

													Negative
22	Albert Hall	30	0	0	0	0	0	0	30	100	Large	Low	Minor to Moderate Negative
23	23 St Peter	8	0	0	0	0	0	0	8	100	Large	High	Major Negative
24	2 Bootle St/Jerusalem Place	51	17	33.3	15	29.4	12	23.5	7	13.7	Large	Med/High	Moderate to Major Negative
25	Theatre Royal	14	14	100	0	0	0	0	0	0	Negligible	Low	Negligible
26	Radison Blu Edwardian Manchester	86	80	93	6	7	0	0	0	0	Negligible	Medium	Negligible
27	44 Peter Street	27	13	48.1	14	51.9	0	0	0	0	Large	Medium	Moderate to Major Negative
28	Fourth Church Of Christ Scientists	14	10	71.4	4	28.6	0	0	0	0	Small	Medium	Minor Negative
29	De Kuyper	10	8	80	2	20	0	0	0	0	Medium	Medium	Moderate Negative
30	Great Northern Tower	64	64	100	0	0	0	0	0	0	Negligible	High	Negligible
31	Oddfellows House	45	19	42.2	26	57.8	0	0	0	0	Large	Medium	Moderate to Major Negative
32	2 Oddfellows House	64	57	89.1	7	10.9	0	0	0	0	Small	Medium	Minor Negative
33	1 Scott Street	45	44	97.8	0	0	0	0	1	2.2	Negligible	Medium	Negligible
34	123 Deansgate (FB)	204	204	100	0	0	0	0	0	0	Negligible	Medium	Negligible
35	Scottish House (FB)	86	86	100	0	0	0	0	0	0	Negligible	Medium	Negligible
Total		1892	1328	70.2	165	8.7	74	3.9	325	17.2			

1.5.4. Paragraph 11.5.5 has been superseded as follows:

The effect of the Proposed Scheme has been identified to be large for 17.2% of total windows assessed (i.e.1892), medium for 3.9%, small for 8.7% and finally negligible for the remaining 70.2% of receptors.

1.5.5. With regards to sunlight, the results of the re-assessment indicated that the proposed amendments to the design are unlikely to significantly affect the results of the 2019 sunlight assessment in terms of the impact of the proposed development on to the existing sensitive receptors. The total adversely affected south facing windows changed from 17.7% in 2019 to 18.2% with the current design (Table 11.8).

1.5.6. Based on the updated results, Table 11.8 has been superseded as follows:

Table 1-2: Summary of Sunlight Assessment Results

Ref	Receptors	Windows	Windows Above BRE Criteria		Magnitude of Change by Window						Overall Magnitude of Change by Receptor	Sensitivity	Effect
					Below BRE (Small)		Below BRE (Medium)		Below BRE (Large)				
			No.	%	No.	%	No.	%	No.	%			
1	Elliot House (Chamber of Commerce)	67	5	7.5	6	9	0	0	56	83.6	Large	Medium	Moderate to Major Negative
2	The Old Nags Head	15	0	0	0	0	0	0	15	100	Large	High	Major Negative
3	19 Jackson's row	1	0	0	0	0	0	0	1	100	Large	Medium	Moderate to Major Negative
4	Croxley House	23	0	0	0	0	0	0	23	100	Large	Medium	Moderate to Major Negative
5	Lloyds House	95	16	16.8	1	1.1	0	0	78	82.1	Large	Medium	Moderate to Major Negative
6	St John's House	72	53	73.6	1	1.4	4	5.6	14	19.4	Medium	Medium	Moderate Negative
7	Sovereign House	58	37	63.8	0	0	4	6.9	17	29.3	Medium	Medium	Moderate Negative
8	The Rising Sun	3	0	0	0	0	0	0	3	100	Large	Medium	Moderate to Major Negative
9	Queens Court	30	17	56.7	0	0	2	6.7	11	36.7	Large	Medium	Moderate to Major Negative
10	Alexandra Buildings	40	40	100	0	0	0	0	0	0	Negligible	Medium	Negligible
11	Queens House	16	16	100	0	0	0	0	0	0	Negligible	Medium	Negligible
12	Heron House	120	119	99.2	0	0	0	0	1	0.8	Negligible	Medium	Negligible
13	Brazennose House	323	323	100	0	0	0	0	0	0	Negligible	Medium	Negligible
14	Centurion house	72	72	100	0	0	0	0	0	0	Negligible	Medium	Negligible
15	2 Bootle St/Jerusalem Place	24	24	100	0	0	0	0	0	0	Negligible	Medium	Negligible
16	Theatre Royal	2	2	100	0	0	0	0	0	0	Negligible	Medium	Negligible
17	Oddfellows House	45	45	100	0	0	0	0	0	0	Negligible	Medium	Negligible
18	Oddfellows House	64	64	100	0	0	0	0	0	0	Negligible	Medium	Negligible
19	1 Scott Street	45	42	93.3	3	6.7	0	0	0	0	Negligible	Medium	Negligible
20	123 Deansgate	204	204	100	0	0	0	0	0	0	Negligible	Medium	Negligible
Total		1319	1079	81.8	11	0.8	10	0.8	219	16.6			

1.5.7. Paragraph 11.5.13 has been superseded as follows:

In terms of sunlight and daylight, the effect of the Proposed Scheme on surrounding buildings is considered of moderate significance. The impact of the Proposed Scheme on the sunlight levels is considered to be large for 16.6% of all windows facing 90° of due south (i.e.1319), medium for 0.8%, small for 0.8% and negligible for the remaining 81.8%

1.5.8. The results of the overshadowing to all surrounding open amenity spaces remain largely unchanged. Table 11.9 has been superseded as follows:

Table 1-3: Results of Overshadowing Analysis for Open Spaces

Square Name	Ground Area Receiving >2hr sunlight		Ratio
	Baseline	Proposed	
A- Albert Square	91.1%	90.7%	1.0
B- Lincoln Square	58.9%	56.8%	1.0
C - Deansgate Square	93.7%	87.3%	0.9
D- Great Northern	45.4%	45.4%	1.0

1.5.9. The results of the reassessment of overshadowing to the open amenity spaces within the Proposed Development shows that, taking into account the changes to the massing, the results are equivalent to those provided in the 2019 addendum.

1.5.10. Figure 11.5 has been superseded by the following image:

Figure 1-2: Overshadowing sensitive receptors within the Proposed Scheme




Table 1-4: Results of Overshadowing Analysis for Open Spaces within the Proposed Scheme

Receptor	Description	Sensitivity	Ground Area Receiving >2hr sunlight	Ratio
1	Amenity Space Block A - South	High	65.05	Above
2	Amenity Space Block A – North	High	61.11	Above
3	Amenity Space External Terrace	High	71.89	Above
4	Amenity Space External Terrace	High	62.77	Above
5	Amenity Space External Terrace	High	58.05	Above
6	Amenity Space - Block B	High	51.28	Above
7	Ground Level	High	68.01	Above

1.6 LIMITATIONS AND ASSUMPTIONS

No update.

1.7 SUMMARY

No update.

1.8 REFERENCES

1.8.24. The following additional reference has been added to the beginning of this section:

Ref. 1: Ministry of Housing, Communities & Local Government, National Planning Policy Framework, 27 March 2012


1.8.25. Ref 11.3 has been superseded by the following:

Ref. 2: Littlefair, P.J. (2022) Site Layout and Planning for Daylight and Sunlight: a guide to good practice. BRE Construction Research Communications, Garston, UK. 2022 edition.



Appendix 1.1


EXTERNAL DAYLIGHT AND SUNLIGHT RECEPTORS




Overshadowing sensitive receptors within the Proposed Scheme




1 – Elliot House




2 – The Old Nags Head (Pub)




3 - 19 Jackson's Row (offices)




4 - Croxley House (Office+Nightclub)




5 - Loyds House (Offices, Restaurant, Offices)




6 - St John's House (Offices)




7 - Sovereign House (offices)



8 - The Rising Sun (pub)



9- Queens Court (offices)




10- Alexandra Buildings (Offices + Commercial GL)





11 - Queens House (Offices+Commercial)





12 - Heron House (Manchester City Council, Restaurants, maybe some residential)




13 - Brazennose House (Commerical+Offices)






14 - Centurion house (offices + commercial)



15 - 1 Central Street (Offices)




16 - 6 Mount Street (religious building 'Friends Meeting House')




17 - 75 Southmill St (Offices)




18 - Television House (Offices)




19 - 37 Peter Street (Offices)




20 - 11-13 Bootle Street




21 - Marron Place Building (office)




22 - Albert hall




23 - 23 St Peter (covered windows)




24 - 2 Bootle St/Jerusalem Place (offices, Residential)



25 - Theatre Royal (Unused Theatre, NightClub)



26- Radison Blu Edwardian Manchester (Hotel)



27 - 44 Peter Street (Offices)




28 -Fourth Church of Christ Scientists




29 - Greath Northern Tower (Residential)




30 - De Kuyper (Commercial)



31 - Oddfellows House (offices)




32 - Oddfellows House (offices)




33 - 1 Scott Street (Offices, Commercial)



34 – 123 Deansgate (Offices, Commercial)




35 – Scottish House (Offices, Commercial)



Appendix 1.2

DETAILED EXTERNAL DAYLIGHT AND SUNLIGHT RESULTS



Detailed Daylight Results

Receptor	Window s No	Baseline (%)	Propos ed (%)	Ratio of Impact	BRE Compla nce	Magnitude of Impact
Elliot House (Chamber of Commerce)	0	16	14	0.88	Above	Negligible
	1	15	12	0.8	Above	Negligible
	2	13	10	0.77	Below	Low
	3	12	10	0.83	Above	Negligible
	4	11	9	0.82	Above	Negligible
	5	11	8	0.73	Below	Low
	6	11	8	0.73	Below	Low
	7	10	7	0.7	Below	Low
	8	10	7	0.7	Below	Low
	9	10	6	0.6	Below	Medium
	10	10	7	0.7	Below	Low
	11	10	6	0.6	Below	Medium
	12	11	6	0.55	Below	High
	13	11	6	0.55	Below	High
	14	11	6	0.55	Below	High
	15	11	6	0.55	Below	High
	16	13	5	0.38	Below	High
	17	14	6	0.43	Below	High
	18	15	6	0.4	Below	High
	19	16	6	0.38	Below	High
	20	18	6	0.33	Below	High
	21	18	6	0.33	Below	High
	22	21	19	0.9	Above	Negligible
	23	20	16	0.8	Above	Negligible
	24	18	15	0.83	Above	Negligible
	25	17	14	0.82	Above	Negligible
	26	16	13	0.81	Above	Negligible
	27	15	12	0.8	Above	Negligible

	28	15	12	0.8	Above	Negligible
	29	15	11	0.73	Below	Low
	30	15	10	0.67	Below	Medium
	31	15	10	0.67	Below	Medium
	32	14	10	0.71	Below	Low
	33	15	10	0.67	Below	Medium
	34	16	10	0.62	Below	Medium
	35	16	10	0.62	Below	Medium
	36	17	9	0.53	Below	High
	37	17	10	0.59	Below	High
	38	18	9	0.5	Below	High
	39	19	9	0.47	Below	High
	40	21	9	0.43	Below	High
	41	22	9	0.41	Below	High
	42	24	8	0.33	Below	High
	43	25	9	0.36	Below	High
	44	29	26	0.9	Above	Negligible
	45	28	23	0.82	Above	Negligible
	46	27	24	0.89	Above	Negligible
	47	26	22	0.85	Above	Negligible
	48	26	20	0.77	Below	Low
	49	25	20	0.8	Above	Negligible
	50	24	18	0.75	Below	Low
	51	23	18	0.78	Below	Low
	52	23	17	0.74	Below	Low
	53	23	17	0.74	Below	Low
	54	23	16	0.7	Below	Low
	55	23	17	0.74	Below	Low
	56	24	16	0.67	Below	Medium
	57	24	16	0.67	Below	Medium
	58	24	16	0.67	Below	Medium

	59	24	15	0.62	Below	Medium
	60	25	15	0.6	Below	Medium
	61	26	15	0.58	Below	High
	62	27	15	0.56	Below	High
	63	28	15	0.54	Below	High
	64	29	15	0.52	Below	High
	65	30	14	0.47	Below	High
	66	31	14	0.45	Below	High
The Old Nags Head (Pub)	0	19	4	0.21	Below	High
	1	19	3	0.16	Below	High
	2	18	3	0.17	Below	High
	3	19	3	0.16	Below	High
	4	18	3	0.17	Below	High
	5	17	2	0.12	Below	High
	6	24	7	0.29	Below	High
	7	25	5	0.2	Below	High
	8	26	4	0.15	Below	High
	9	26	4	0.15	Below	High
	10	26	3	0.12	Below	High
	11	25	3	0.12	Below	High
	12	31	7	0.23	Below	High
	13	32	5	0.16	Below	High
	14	33	3	0.09	Below	High
19 Jackson's row (office)	0	23	2	0.09	Below	High
Croxley House (offices+Nightclub)	0	26	1	0.04	Below	High
	1	27	1	0.04	Below	High
	2	26	1	0.04	Below	High
	3	32	2	0.06	Below	High
	4	33	2	0.06	Below	High
	5	34	2	0.06	Below	High
	6	35	2	0.06	Below	High

	7	39	3	0.08	Below	High
	8	39	3	0.08	Below	High
	9	39	2	0.05	Below	High
	10	39	2	0.05	Below	High
	11	42	4	0.1	Below	High
	12	41	3	0.07	Below	High
	13	42	3	0.07	Below	High
	14	42	4	0.1	Below	High
	15	43	5	0.12	Below	High
	16	43	5	0.12	Below	High
	17	44	5	0.11	Below	High
	18	43	4	0.09	Below	High
	19	44	4	0.09	Below	High
	20	43	4	0.09	Below	High
	21	44	4	0.09	Below	High
	22	45	8	0.18	Below	High
Loyds House (Offices, Restaurant, Offices)	0	38	2	0.05	Below	High
	1	35	2	0.06	Below	High
	2	34	2	0.06	Below	High
	3	33	2	0.06	Below	High
	4	32	1	0.03	Below	High
	5	31	2	0.06	Below	High
	6	32	2	0.06	Below	High
	7	32	2	0.06	Below	High
	8	31	2	0.06	Below	High
	9	30	2	0.07	Below	High
	10	29	2	0.07	Below	High
	11	27	2	0.07	Below	High
	12	25	2	0.08	Below	High
	13	23	3	0.13	Below	High
	14	21	3	0.14	Below	High

	15	19	4	0.21	Below	High
	16	23	6	0.26	Below	High
	17	19	6	0.32	Below	High
	18	18	7	0.39	Below	High
	19	19	10	0.53	Below	High
	20	17	16	0.94	Above	Negligible
	21	40	2	0.05	Below	High
	22	40	2	0.05	Below	High
	23	40	2	0.05	Below	High
	24	40	2	0.05	Below	High
	25	40	2	0.05	Below	High
	26	40	2	0.05	Below	High
	27	40	2	0.05	Below	High
	28	40	2	0.05	Below	High
	29	40	2	0.05	Below	High
	30	39	2	0.05	Below	High
	31	40	3	0.08	Below	High
	32	38	3	0.08	Below	High
	33	39	3	0.08	Below	High
	34	38	3	0.08	Below	High
	35	37	3	0.08	Below	High
	36	38	4	0.11	Below	High
	37	35	5	0.14	Below	High
	38	35	6	0.17	Below	High
	39	32	8	0.25	Below	High
	40	31	8	0.26	Below	High
	41	29	10	0.34	Below	High
	42	29	11	0.38	Below	High
	43	24	19	0.79	Below	Low
	44	41	2	0.05	Below	High
	45	42	2	0.05	Below	High

	46	42	3	0.07	Below	High
	47	41	3	0.07	Below	High
	48	41	3	0.07	Below	High
	49	42	3	0.07	Below	High
	50	42	3	0.07	Below	High
	51	42	3	0.07	Below	High
	52	41	2	0.05	Below	High
	53	42	3	0.07	Below	High
	54	42	3	0.07	Below	High
	55	42	3	0.07	Below	High
	56	42	3	0.07	Below	High
	57	41	3	0.07	Below	High
	58	41	4	0.1	Below	High
	59	41	4	0.1	Below	High
	60	41	5	0.12	Below	High
	61	41	6	0.15	Below	High
	62	41	8	0.2	Below	High
	63	40	9	0.22	Below	High
	64	40	10	0.25	Below	High
	65	39	12	0.31	Below	High
	66	39	14	0.36	Below	High
	67	39	15	0.38	Below	High
	68	32	24	0.75	Below	Low
	69	43	4	0.09	Below	High
	70	44	4	0.09	Below	High
	71	44	4	0.09	Below	High
	72	43	4	0.09	Below	High
	73	44	4	0.09	Below	High
	74	43	4	0.09	Below	High
	75	44	4	0.09	Below	High
	76	43	4	0.09	Below	High

	77	43	4	0.09	Below	High
	78	43	4	0.09	Below	High
	79	44	3	0.07	Below	High
	80	43	4	0.09	Below	High
	81	43	4	0.09	Below	High
	82	43	4	0.09	Below	High
	83	43	5	0.12	Below	High
	84	43	5	0.12	Below	High
	85	43	6	0.14	Below	High
	86	43	6	0.14	Below	High
	87	43	8	0.19	Below	High
	88	42	9	0.21	Below	High
	89	43	11	0.26	Below	High
	90	42	13	0.31	Below	High
	91	42	14	0.33	Below	High
	92	42	16	0.38	Below	High
	93	42	19	0.45	Below	High
	94	38	32	0.84	Above	Negligible
St John's House (offices+Cafe GF)	0	15	13	0.87	Above	Negligible
	1	15	12	0.8	Above	Negligible
	2	14	12	0.86	Above	Negligible
	3	14	12	0.86	Above	Negligible
	4	13	12	0.92	Above	Negligible
	5	13	12	0.92	Above	Negligible
	6	13	12	0.92	Above	Negligible
	7	17	13	0.76	Below	Low
	8	18	14	0.78	Below	Low
	9	18	14	0.78	Below	Low
	10	19	15	0.79	Below	Low
	11	20	15	0.75	Below	Low
	12	21	17	0.81	Above	Negligible

	13	20	17	0.85	Above	Negligible
	14	20	16	0.8	Above	Negligible
	15	19	16	0.84	Above	Negligible
	16	19	16	0.84	Above	Negligible
	17	19	16	0.84	Above	Negligible
	18	19	16	0.84	Above	Negligible
	19	22	17	0.77	Below	Low
	20	23	18	0.78	Below	Low
	21	24	19	0.79	Below	Low
	22	26	20	0.77	Below	Low
	23	26	20	0.77	Below	Low
	24	28	24	0.86	Above	Negligible
	25	29	23	0.79	Below	Low
	26	28	23	0.82	Above	Negligible
	27	28	23	0.82	Above	Negligible
	28	28	23	0.82	Above	Negligible
	29	28	23	0.82	Above	Negligible
	30	28	23	0.82	Above	Negligible
	31	29	22	0.76	Below	Low
	32	31	23	0.74	Below	Low
	33	32	25	0.78	Below	Low
	34	32	25	0.78	Below	Low
	35	33	25	0.76	Below	Low
	36	40	33	0.82	Above	Negligible
	37	40	33	0.82	Above	Negligible
	38	40	33	0.82	Above	Negligible
	39	41	33	0.8	Above	Negligible
	40	40	33	0.82	Above	Negligible
	41	40	33	0.82	Above	Negligible
	42	40	32	0.8	Above	Negligible
	43	36	28	0.78	Above	Negligible

	44	37	28	0.76	Above	Negligible
	45	38	29	0.76	Above	Negligible
	46	38	30	0.79	Above	Negligible
	47	39	30	0.77	Above	Negligible
	48	44	37	0.84	Above	Negligible
	49	44	37	0.84	Above	Negligible
	50	44	37	0.84	Above	Negligible
	51	44	36	0.82	Above	Negligible
	52	45	36	0.8	Above	Negligible
	53	44	36	0.82	Above	Negligible
	54	45	36	0.8	Above	Negligible
	55	39	31	0.79	Above	Negligible
	56	41	32	0.78	Above	Negligible
	57	41	33	0.8	Above	Negligible
	58	42	32	0.76	Above	Negligible
	59	42	32	0.76	Above	Negligible
	60	46	38	0.83	Above	Negligible
	61	46	38	0.83	Above	Negligible
	62	46	38	0.83	Above	Negligible
	63	46	37	0.8	Above	Negligible
	64	46	37	0.8	Above	Negligible
	65	46	37	0.8	Above	Negligible
	66	46	37	0.8	Above	Negligible
	67	42	33	0.79	Above	Negligible
	68	43	34	0.79	Above	Negligible
	69	44	34	0.77	Above	Negligible
	70	44	35	0.8	Above	Negligible
	71	44	35	0.8	Above	Negligible
Sovereign House (offices)	0	13	7	0.54	Below	High
	1	15	9	0.6	Below	Medium
	2	17	11	0.65	Below	Medium

	3	17	11	0.65	Below	Medium
	4	17	10	0.59	Below	High
	5	14	10	0.71	Below	Low
	6	22	17	0.77	Below	Low
	7	23	17	0.74	Below	Low
	8	23	18	0.78	Below	Low
	9	16	10	0.62	Below	Medium
	10	19	12	0.63	Below	Medium
	11	21	14	0.67	Below	Medium
	12	21	14	0.67	Below	Medium
	13	20	12	0.6	Below	Medium
	14	18	12	0.67	Below	Medium
	15	22	15	0.68	Below	Medium
	16	23	15	0.65	Below	Medium
	17	22	15	0.68	Below	Medium
	18	28	21	0.75	Below	Low
	19	30	22	0.73	Below	Low
	20	30	22	0.73	Below	Low
	21	19	12	0.63	Below	Medium
	22	22	14	0.64	Below	Medium
	23	24	18	0.75	Below	Low
	24	25	18	0.72	Below	Low
	25	23	17	0.74	Below	Low
	26	20	15	0.75	Below	Low
	27	31	21	0.68	Below	Medium
	28	29	20	0.69	Below	Medium
	29	29	20	0.69	Below	Medium
	30	34	26	0.76	Below	Low
	31	36	28	0.78	Above	Negligible
	32	36	28	0.78	Above	Negligible
	33	21	14	0.67	Below	Medium

	34	26	18	0.69	Below	Medium
	35	30	22	0.73	Below	Low
	36	30	22	0.73	Below	Low
	37	28	19	0.68	Below	Medium
	38	24	17	0.71	Below	Low
	39	38	30	0.79	Above	Negligible
	40	40	31	0.78	Above	Negligible
	41	40	30	0.75	Above	Negligible
	42	25	17	0.68	Below	Medium
	43	29	22	0.76	Below	Low
	44	34	26	0.76	Below	Low
	45	36	28	0.78	Above	Negligible
	46	36	27	0.75	Above	Negligible
	47	31	23	0.74	Below	Low
	48	35	26	0.74	Below	Low
	49	35	25	0.71	Below	Low
	50	34	24	0.71	Below	Low
	51	42	32	0.76	Above	Negligible
	52	42	33	0.79	Above	Negligible
	53	32	24	0.75	Below	Low
	54	40	32	0.8	Above	Negligible
	55	41	32	0.78	Above	Negligible
	56	41	33	0.8	Above	Negligible
	57	41	33	0.8	Above	Negligible
The Rising Sun (pub)	0	16	10	0.62	Below	Medium
	1	20	12	0.6	Below	Medium
	2	19	12	0.63	Below	Medium
Queens Court (offices)	0	9	5	0.56	Below	High
	1	12	8	0.67	Below	Medium
	2	13	10	0.77	Below	Low
	3	12	10	0.83	Above	Negligible

	4	10	8	0.8	Above	Negligible
	5	9	8	0.89	Above	Negligible
	6	20	14	0.7	Below	Low
	7	20	14	0.7	Below	Low
	8	16	13	0.81	Above	Negligible
	9	15	12	0.8	Above	Negligible
	10	12	10	0.83	Above	Negligible
	11	11	9	0.82	Above	Negligible
	12	24	17	0.71	Below	Low
	13	24	17	0.71	Below	Low
	14	20	16	0.8	Above	Negligible
	15	19	16	0.84	Above	Negligible
	16	15	13	0.87	Above	Negligible
	17	14	11	0.79	Below	Low
	18	29	21	0.72	Below	Low
	19	29	21	0.72	Below	Low
	20	26	21	0.81	Above	Negligible
	21	24	20	0.83	Above	Negligible
	22	20	16	0.8	Above	Negligible
	23	17	14	0.82	Above	Negligible
	24	36	27	0.75	Above	Negligible
	25	35	27	0.77	Above	Negligible
	26	33	27	0.82	Above	Negligible
	27	32	26	0.81	Above	Negligible
	28	29	23	0.79	Below	Low
	29	24	20	0.83	Above	Negligible
Alexandra Buildings (Offices + Commercial GL)	0	8	8	1	Above	Negligible
	1	7	7	1	Above	Negligible
	2	8	7	0.88	Above	Negligible
	3	7	7	1	Above	Negligible

	4	6	7	1.17	Above	Negligible
	5	7	6	0.86	Above	Negligible
	6	6	7	1.17	Above	Negligible
	7	7	6	0.86	Above	Negligible
	8	7	6	0.86	Above	Negligible
	9	7	7	1	Above	Negligible
	10	10	9	0.9	Above	Negligible
	11	9	9	1	Above	Negligible
	12	9	9	1	Above	Negligible
	13	10	9	0.9	Above	Negligible
	14	10	9	0.9	Above	Negligible
	15	9	9	1	Above	Negligible
	16	9	8	0.89	Above	Negligible
	17	9	8	0.89	Above	Negligible
	18	9	8	0.89	Above	Negligible
	19	9	9	1	Above	Negligible
	20	13	12	0.92	Above	Negligible
	21	12	12	1	Above	Negligible
	22	13	12	0.92	Above	Negligible
	23	13	12	0.92	Above	Negligible
	24	13	12	0.92	Above	Negligible
	25	13	11	0.85	Above	Negligible
	26	13	11	0.85	Above	Negligible
	27	13	12	0.92	Above	Negligible
	28	13	12	0.92	Above	Negligible
	29	14	11	0.79	Below	Low
	30	18	16	0.89	Above	Negligible
	31	18	16	0.89	Above	Negligible
	32	18	16	0.89	Above	Negligible
	33	18	16	0.89	Above	Negligible
	34	19	16	0.84	Above	Negligible

	35	19	17	0.89	Above	Negligible
	36	19	18	0.95	Above	Negligible
	37	19	17	0.89	Above	Negligible
	38	20	17	0.85	Above	Negligible
	39	20	17	0.85	Above	Negligible
Queens House (Offices+Commercial)	0	6	6	1	Above	Negligible
	1	8	7	0.88	Above	Negligible
	2	7	6	0.86	Above	Negligible
	3	10	9	0.9	Above	Negligible
	4	9	8	0.89	Above	Negligible
	5	14	12	0.86	Above	Negligible
	6	13	12	0.92	Above	Negligible
	7	20	17	0.85	Above	Negligible
	8	19	16	0.84	Above	Negligible
	9	29	21	0.72	Below	Low
	10	39	25	0.64	Below	Medium
	11	40	25	0.62	Below	Medium
	12	40	24	0.6	Below	Medium
	13	41	24	0.59	Below	High
	14	40	24	0.6	Below	Medium
	15	40	25	0.62	Below	Medium
Heron House (Manchester City Council, Restaurants, maybe some residential)	0	6	7	1.17	Above	Negligible
	1	7	6	0.86	Above	Negligible
	2	7	6	0.86	Above	Negligible
	3	7	6	0.86	Above	Negligible
	4	8	8	1	Above	Negligible
	5	8	7	0.88	Above	Negligible
	6	8	7	0.88	Above	Negligible
	7	8	8	1	Above	Negligible
	8	9	8	0.89	Above	Negligible

	9	9	8	0.89	Above	Negligible
	10	10	10	1	Above	Negligible
	11	11	11	1	Above	Negligible
	12	12	11	0.92	Above	Negligible
	13	13	12	0.92	Above	Negligible
	14	14	13	0.93	Above	Negligible
	15	9	8	0.89	Above	Negligible
	16	9	8	0.89	Above	Negligible
	17	9	8	0.89	Above	Negligible
	18	9	8	0.89	Above	Negligible
	19	10	9	0.9	Above	Negligible
	20	10	9	0.9	Above	Negligible
	21	10	9	0.9	Above	Negligible
	22	10	9	0.9	Above	Negligible
	23	10	9	0.9	Above	Negligible
	24	11	9	0.82	Above	Negligible
	25	11	9	0.82	Above	Negligible
	26	11	10	0.91	Above	Negligible
	27	12	11	0.92	Above	Negligible
	28	12	10	0.83	Above	Negligible
	29	13	11	0.85	Above	Negligible
	30	13	12	0.92	Above	Negligible
	31	14	12	0.86	Above	Negligible
	32	14	14	1	Above	Negligible
	33	15	14	0.93	Above	Negligible
	34	16	15	0.94	Above	Negligible
	35	18	17	0.94	Above	Negligible
	36	13	11	0.85	Above	Negligible
	37	13	11	0.85	Above	Negligible
	38	13	12	0.92	Above	Negligible
	39	13	11	0.85	Above	Negligible

	40	14	12	0.86	Above	Negligible
	41	14	12	0.86	Above	Negligible
	42	14	12	0.86	Above	Negligible
	43	14	13	0.93	Above	Negligible
	44	14	12	0.86	Above	Negligible
	45	15	12	0.8	Above	Negligible
	46	15	13	0.87	Above	Negligible
	47	16	13	0.81	Above	Negligible
	48	16	14	0.88	Above	Negligible
	49	17	15	0.88	Above	Negligible
	50	17	15	0.88	Above	Negligible
	51	17	16	0.94	Above	Negligible
	52	18	17	0.94	Above	Negligible
	53	19	17	0.89	Above	Negligible
	54	20	18	0.9	Above	Negligible
	55	22	19	0.86	Above	Negligible
	56	23	21	0.91	Above	Negligible
	57	19	16	0.84	Above	Negligible
	58	19	16	0.84	Above	Negligible
	59	19	16	0.84	Above	Negligible
	60	20	17	0.85	Above	Negligible
	61	20	17	0.85	Above	Negligible
	62	21	18	0.86	Above	Negligible
	63	21	18	0.86	Above	Negligible
	64	21	18	0.86	Above	Negligible
	65	21	18	0.86	Above	Negligible
	66	21	19	0.9	Above	Negligible
	67	21	19	0.9	Above	Negligible
	68	22	20	0.91	Above	Negligible
	69	22	20	0.91	Above	Negligible
	70	23	20	0.87	Above	Negligible

	71	23	21	0.91	Above	Negligible
	72	24	21	0.88	Above	Negligible
	73	25	22	0.88	Above	Negligible
	74	26	23	0.88	Above	Negligible
	75	26	24	0.92	Above	Negligible
	76	28	25	0.89	Above	Negligible
	77	29	26	0.9	Above	Negligible
	78	29	22	0.76	Below	Low
	79	30	22	0.73	Below	Low
	80	30	21	0.7	Below	Low
	81	30	22	0.73	Below	Low
	82	30	23	0.77	Below	Low
	83	30	23	0.77	Below	Low
	84	31	23	0.74	Below	Low
	85	31	24	0.77	Below	Low
	86	31	24	0.77	Below	Low
	87	31	24	0.77	Below	Low
	88	31	25	0.81	Above	Negligible
	89	31	25	0.81	Above	Negligible
	90	32	26	0.81	Above	Negligible
	91	32	27	0.84	Above	Negligible
	92	32	27	0.84	Above	Negligible
	93	33	27	0.82	Above	Negligible
	94	33	28	0.85	Above	Negligible
	95	34	29	0.85	Above	Negligible
	96	34	29	0.85	Above	Negligible
	97	35	31	0.89	Above	Negligible
	98	36	31	0.86	Above	Negligible
	99	43	27	0.63	Above	Negligible
	100	42	26	0.62	Below	Medium
	101	43	27	0.63	Above	Negligible

	102	42	28	0.67	Above	Negligible
	103	42	28	0.67	Above	Negligible
	104	43	28	0.65	Above	Negligible
	105	42	29	0.69	Above	Negligible
	106	43	30	0.7	Above	Negligible
	107	42	29	0.69	Above	Negligible
	108	43	30	0.7	Above	Negligible
	109	42	30	0.71	Above	Negligible
	110	43	31	0.72	Above	Negligible
	111	43	32	0.74	Above	Negligible
	112	43	33	0.77	Above	Negligible
	113	42	33	0.79	Above	Negligible
	114	42	33	0.79	Above	Negligible
	115	42	34	0.81	Above	Negligible
	116	42	34	0.81	Above	Negligible
	117	42	34	0.81	Above	Negligible
	118	42	36	0.86	Above	Negligible
	119	42	35	0.83	Above	Negligible
Brazennose House (Commerical+Offices)	0	20	17	0.85	Above	Negligible
	1	21	20	0.95	Above	Negligible
	2	25	22	0.88	Above	Negligible
	3	23	22	0.96	Above	Negligible
	4	26	23	0.88	Above	Negligible
	5	25	22	0.88	Above	Negligible
	6	23	21	0.91	Above	Negligible
	7	21	18	0.86	Above	Negligible
	8	18	16	0.89	Above	Negligible
	9	13	13	1	Above	Negligible
	10	10	10	1	Above	Negligible
	11	20	17	0.85	Above	Negligible
	12	21	17	0.81	Above	Negligible

	13	21	18	0.86	Above	Negligible
	14	22	18	0.82	Above	Negligible
	15	23	19	0.83	Above	Negligible
	16	23	21	0.91	Above	Negligible
	17	24	21	0.88	Above	Negligible
	18	24	22	0.92	Above	Negligible
	19	25	21	0.84	Above	Negligible
	20	26	22	0.85	Above	Negligible
	21	26	24	0.92	Above	Negligible
	22	26	23	0.88	Above	Negligible
	23	27	24	0.89	Above	Negligible
	24	27	24	0.89	Above	Negligible
	25	28	24	0.86	Above	Negligible
	26	26	24	0.92	Above	Negligible
	27	26	23	0.88	Above	Negligible
	28	28	26	0.93	Above	Negligible
	29	28	25	0.89	Above	Negligible
	30	28	26	0.93	Above	Negligible
	31	29	26	0.9	Above	Negligible
	32	28	25	0.89	Above	Negligible
	33	28	26	0.93	Above	Negligible
	34	29	26	0.9	Above	Negligible
	35	28	26	0.93	Above	Negligible
	36	28	25	0.89	Above	Negligible
	37	28	25	0.89	Above	Negligible
	38	27	25	0.93	Above	Negligible
	39	27	25	0.93	Above	Negligible
	40	27	24	0.89	Above	Negligible
	41	27	24	0.89	Above	Negligible
	42	27	24	0.89	Above	Negligible
	43	26	23	0.88	Above	Negligible

	44	26	24	0.92	Above	Negligible
	45	26	23	0.88	Above	Negligible
	46	23	21	0.91	Above	Negligible
	47	23	21	0.91	Above	Negligible
	48	22	20	0.91	Above	Negligible
	49	21	19	0.9	Above	Negligible
	50	20	17	0.85	Above	Negligible
	51	19	17	0.89	Above	Negligible
	52	18	16	0.89	Above	Negligible
	53	17	15	0.88	Above	Negligible
	54	17	15	0.88	Above	Negligible
	55	15	14	0.93	Above	Negligible
	56	15	14	0.93	Above	Negligible
	57	14	14	1	Above	Negligible
	58	13	13	1	Above	Negligible
	59	13	13	1	Above	Negligible
	60	12	13	1.08	Above	Negligible
	61	12	12	1	Above	Negligible
	62	11	11	1	Above	Negligible
	63	22	18	0.82	Above	Negligible
	64	23	19	0.83	Above	Negligible
	65	23	19	0.83	Above	Negligible
	66	23	21	0.91	Above	Negligible
	67	26	22	0.85	Above	Negligible
	68	26	22	0.85	Above	Negligible
	69	26	23	0.88	Above	Negligible
	70	27	24	0.89	Above	Negligible
	71	27	24	0.89	Above	Negligible
	72	29	24	0.83	Above	Negligible
	73	29	25	0.86	Above	Negligible
	74	29	26	0.9	Above	Negligible

	75	30	26	0.87	Above	Negligible
	76	30	26	0.87	Above	Negligible
	77	30	27	0.9	Above	Negligible
	78	29	25	0.86	Above	Negligible
	79	29	25	0.86	Above	Negligible
	80	32	28	0.88	Above	Negligible
	81	31	28	0.9	Above	Negligible
	82	32	28	0.88	Above	Negligible
	83	32	29	0.91	Above	Negligible
	84	31	29	0.94	Above	Negligible
	85	32	28	0.88	Above	Negligible
	86	31	28	0.9	Above	Negligible
	87	31	28	0.9	Above	Negligible
	88	31	28	0.9	Above	Negligible
	89	31	28	0.9	Above	Negligible
	90	31	29	0.94	Above	Negligible
	91	31	28	0.9	Above	Negligible
	92	31	28	0.9	Above	Negligible
	93	31	28	0.9	Above	Negligible
	94	30	27	0.9	Above	Negligible
	95	30	27	0.9	Above	Negligible
	96	30	26	0.87	Above	Negligible
	97	29	26	0.9	Above	Negligible
	98	27	23	0.85	Above	Negligible
	99	26	23	0.88	Above	Negligible
	100	25	22	0.88	Above	Negligible
	101	24	22	0.92	Above	Negligible
	102	24	20	0.83	Above	Negligible
	103	22	21	0.95	Above	Negligible
	104	21	19	0.9	Above	Negligible
	105	21	18	0.86	Above	Negligible

	106	20	17	0.85	Above	Negligible
	107	18	17	0.94	Above	Negligible
	108	18	17	0.94	Above	Negligible
	109	17	17	1	Above	Negligible
	110	16	16	1	Above	Negligible
	111	16	16	1	Above	Negligible
	112	16	16	1	Above	Negligible
	113	15	15	1	Above	Negligible
	114	14	14	1	Above	Negligible
	115	23	20	0.87	Above	Negligible
	116	25	20	0.8	Above	Negligible
	117	25	21	0.84	Above	Negligible
	118	26	23	0.88	Above	Negligible
	119	28	23	0.82	Above	Negligible
	120	28	24	0.86	Above	Negligible
	121	29	24	0.83	Above	Negligible
	122	30	25	0.83	Above	Negligible
	123	30	26	0.87	Above	Negligible
	124	31	26	0.84	Above	Negligible
	125	32	26	0.81	Above	Negligible
	126	33	28	0.85	Above	Negligible
	127	32	28	0.88	Above	Negligible
	128	33	28	0.85	Above	Negligible
	129	34	28	0.82	Above	Negligible
	130	32	28	0.88	Above	Negligible
	131	32	27	0.84	Above	Negligible
	132	35	30	0.86	Above	Negligible
	133	35	30	0.86	Above	Negligible
	134	35	31	0.89	Above	Negligible
	135	35	31	0.89	Above	Negligible
	136	35	31	0.89	Above	Negligible

	137	35	30	0.86	Above	Negligible
	138	35	31	0.89	Above	Negligible
	139	35	31	0.89	Above	Negligible
	140	35	31	0.89	Above	Negligible
	141	34	30	0.88	Above	Negligible
	142	35	30	0.86	Above	Negligible
	143	34	30	0.88	Above	Negligible
	144	34	30	0.88	Above	Negligible
	145	34	30	0.88	Above	Negligible
	146	34	30	0.88	Above	Negligible
	147	34	30	0.88	Above	Negligible
	148	33	30	0.91	Above	Negligible
	149	33	30	0.91	Above	Negligible
	150	31	27	0.87	Above	Negligible
	151	29	27	0.93	Above	Negligible
	152	29	26	0.9	Above	Negligible
	153	28	25	0.89	Above	Negligible
	154	28	24	0.86	Above	Negligible
	155	26	24	0.92	Above	Negligible
	156	25	23	0.92	Above	Negligible
	157	24	21	0.88	Above	Negligible
	158	23	21	0.91	Above	Negligible
	159	22	21	0.95	Above	Negligible
	160	21	20	0.95	Above	Negligible
	161	21	21	1	Above	Negligible
	162	21	21	1	Above	Negligible
	163	20	19	0.95	Above	Negligible
	164	20	19	0.95	Above	Negligible
	165	19	19	1	Above	Negligible
	166	18	18	1	Above	Negligible
	167	25	21	0.84	Above	Negligible

	168	26	22	0.85	Above	Negligible
	169	27	23	0.85	Above	Negligible
	170	28	23	0.82	Above	Negligible
	171	29	24	0.83	Above	Negligible
	172	30	25	0.83	Above	Negligible
	173	31	26	0.84	Above	Negligible
	174	32	27	0.84	Above	Negligible
	175	33	28	0.85	Above	Negligible
	176	33	28	0.85	Above	Negligible
	177	34	29	0.85	Above	Negligible
	178	35	29	0.83	Above	Negligible
	179	35	30	0.86	Above	Negligible
	180	36	30	0.83	Above	Negligible
	181	36	31	0.86	Above	Negligible
	182	35	30	0.86	Above	Negligible
	183	35	30	0.86	Above	Negligible
	184	38	33	0.87	Above	Negligible
	185	38	33	0.87	Above	Negligible
	186	39	33	0.85	Above	Negligible
	187	38	33	0.87	Above	Negligible
	188	38	34	0.89	Above	Negligible
	189	39	33	0.85	Above	Negligible
	190	38	33	0.87	Above	Negligible
	191	38	33	0.87	Above	Negligible
	192	39	34	0.87	Above	Negligible
	193	38	33	0.87	Above	Negligible
	194	39	33	0.85	Above	Negligible
	195	38	34	0.89	Above	Negligible
	196	37	33	0.89	Above	Negligible
	197	38	32	0.84	Above	Negligible
	198	37	33	0.89	Above	Negligible

	199	38	33	0.87	Above	Negligible
	200	37	33	0.89	Above	Negligible
	201	36	32	0.89	Above	Negligible
	202	34	29	0.85	Above	Negligible
	203	33	29	0.88	Above	Negligible
	204	34	30	0.88	Above	Negligible
	205	33	29	0.88	Above	Negligible
	206	32	28	0.88	Above	Negligible
	207	31	28	0.9	Above	Negligible
	208	30	27	0.9	Above	Negligible
	209	29	26	0.9	Above	Negligible
	210	28	25	0.89	Above	Negligible
	211	27	25	0.93	Above	Negligible
	212	26	25	0.96	Above	Negligible
	213	26	25	0.96	Above	Negligible
	214	26	24	0.92	Above	Negligible
	215	25	24	0.96	Above	Negligible
	216	25	24	0.96	Above	Negligible
	217	24	23	0.96	Above	Negligible
	218	24	23	0.96	Above	Negligible
	219	27	23	0.85	Above	Negligible
	220	28	23	0.82	Above	Negligible
	221	29	24	0.83	Above	Negligible
	222	30	26	0.87	Above	Negligible
	223	31	26	0.84	Above	Negligible
	224	32	27	0.84	Above	Negligible
	225	33	28	0.85	Above	Negligible
	226	35	29	0.83	Above	Negligible
	227	35	30	0.86	Above	Negligible
	228	36	30	0.83	Above	Negligible
	229	36	31	0.86	Above	Negligible

	230	37	31	0.84	Above	Negligible
	231	38	32	0.84	Above	Negligible
	232	38	33	0.87	Above	Negligible
	233	38	33	0.87	Above	Negligible
	234	37	32	0.86	Above	Negligible
	235	36	32	0.89	Above	Negligible
	236	41	35	0.85	Above	Negligible
	237	40	35	0.88	Above	Negligible
	238	41	36	0.88	Above	Negligible
	239	41	36	0.88	Above	Negligible
	240	41	36	0.88	Above	Negligible
	241	40	36	0.9	Above	Negligible
	242	41	35	0.85	Above	Negligible
	243	41	35	0.85	Above	Negligible
	244	41	36	0.88	Above	Negligible
	245	41	36	0.88	Above	Negligible
	246	41	36	0.88	Above	Negligible
	247	41	36	0.88	Above	Negligible
	248	41	35	0.85	Above	Negligible
	249	41	36	0.88	Above	Negligible
	250	41	36	0.88	Above	Negligible
	251	41	36	0.88	Above	Negligible
	252	41	35	0.85	Above	Negligible
	253	40	35	0.88	Above	Negligible
	254	38	33	0.87	Above	Negligible
	255	38	33	0.87	Above	Negligible
	256	37	33	0.89	Above	Negligible
	257	38	33	0.87	Above	Negligible
	258	36	33	0.92	Above	Negligible
	259	36	32	0.89	Above	Negligible
	260	36	31	0.86	Above	Negligible

	261	35	31	0.89	Above	Negligible
	262	34	31	0.91	Above	Negligible
	263	33	30	0.91	Above	Negligible
	264	33	30	0.91	Above	Negligible
	265	32	30	0.94	Above	Negligible
	266	32	30	0.94	Above	Negligible
	267	31	30	0.97	Above	Negligible
	268	31	29	0.94	Above	Negligible
	269	30	29	0.97	Above	Negligible
	270	30	29	0.97	Above	Negligible
	271	28	24	0.86	Above	Negligible
	272	29	25	0.86	Above	Negligible
	273	30	25	0.83	Above	Negligible
	274	32	27	0.84	Above	Negligible
	275	33	28	0.85	Above	Negligible
	276	34	29	0.85	Above	Negligible
	277	35	30	0.86	Above	Negligible
	278	35	30	0.86	Above	Negligible
	279	36	31	0.86	Above	Negligible
	280	37	33	0.89	Above	Negligible
	281	38	33	0.87	Above	Negligible
	282	39	33	0.85	Above	Negligible
	283	39	34	0.87	Above	Negligible
	284	40	35	0.88	Above	Negligible
	285	40	35	0.88	Above	Negligible
	286	40	34	0.85	Above	Negligible
	287	39	33	0.85	Above	Negligible
	288	42	37	0.88	Above	Negligible
	289	42	37	0.88	Above	Negligible
	290	42	37	0.88	Above	Negligible
	291	42	37	0.88	Above	Negligible

	292	43	38	0.88	Above	Negligible
	293	43	38	0.88	Above	Negligible
	294	43	37	0.86	Above	Negligible
	295	43	39	0.91	Above	Negligible
	296	43	39	0.91	Above	Negligible
	297	44	38	0.86	Above	Negligible
	298	43	38	0.88	Above	Negligible
	299	43	39	0.91	Above	Negligible
	300	43	39	0.91	Above	Negligible
	301	44	38	0.86	Above	Negligible
	302	44	38	0.86	Above	Negligible
	303	44	39	0.89	Above	Negligible
	304	43	38	0.88	Above	Negligible
	305	43	38	0.88	Above	Negligible
	306	42	37	0.88	Above	Negligible
	307	41	36	0.88	Above	Negligible
	308	43	38	0.88	Above	Negligible
	309	42	38	0.9	Above	Negligible
	310	42	37	0.88	Above	Negligible
	311	42	38	0.9	Above	Negligible
	312	41	37	0.9	Above	Negligible
	313	41	37	0.9	Above	Negligible
	314	40	36	0.9	Above	Negligible
	315	40	37	0.92	Above	Negligible
	316	40	37	0.92	Above	Negligible
	317	39	36	0.92	Above	Negligible
	318	39	36	0.92	Above	Negligible
	319	38	36	0.95	Above	Negligible
	320	39	37	0.95	Above	Negligible
	321	38	36	0.95	Above	Negligible
	322	38	35	0.92	Above	Negligible

Centurion house (offices+Com)	0	6	7	1.17	Above	Negligible
	1	7	7	1	Above	Negligible
	2	7	7	1	Above	Negligible
	3	8	8	1	Above	Negligible
	4	9	9	1	Above	Negligible
	5	11	10	0.91	Above	Negligible
	6	11	10	0.91	Above	Negligible
	7	13	12	0.92	Above	Negligible
	8	9	9	1	Above	Negligible
	9	9	10	1.11	Above	Negligible
	10	10	10	1	Above	Negligible
	11	12	11	0.92	Above	Negligible
	12	14	13	0.93	Above	Negligible
	13	16	15	0.94	Above	Negligible
	14	17	15	0.88	Above	Negligible
	15	20	17	0.85	Above	Negligible
	16	12	12	1	Above	Negligible
	17	13	13	1	Above	Negligible
	18	14	14	1	Above	Negligible
	19	18	15	0.83	Above	Negligible
	20	20	17	0.85	Above	Negligible
	21	23	21	0.91	Above	Negligible
	22	25	21	0.84	Above	Negligible
	23	28	23	0.82	Above	Negligible
	24	16	15	0.94	Above	Negligible
	25	18	16	0.89	Above	Negligible
	26	20	18	0.9	Above	Negligible
	27	24	20	0.83	Above	Negligible
	28	28	23	0.82	Above	Negligible
	29	30	25	0.83	Above	Negligible
	30	32	27	0.84	Above	Negligible

	31	35	29	0.83	Above	Negligible
	32	23	21	0.91	Above	Negligible
	33	24	21	0.88	Above	Negligible
	34	25	23	0.92	Above	Negligible
	35	29	24	0.83	Above	Negligible
	36	33	27	0.82	Above	Negligible
	37	36	29	0.81	Above	Negligible
	38	37	31	0.84	Above	Negligible
	39	39	33	0.85	Above	Negligible
	40	32	29	0.91	Above	Negligible
	41	33	29	0.88	Above	Negligible
	42	34	30	0.88	Above	Negligible
	43	36	31	0.86	Above	Negligible
	44	38	32	0.84	Above	Negligible
	45	41	34	0.83	Above	Negligible
	46	42	36	0.86	Above	Negligible
	47	43	36	0.84	Above	Negligible
	48	45	39	0.87	Above	Negligible
	49	45	39	0.87	Above	Negligible
	50	45	40	0.89	Above	Negligible
	51	45	40	0.89	Above	Negligible
	52	46	40	0.87	Above	Negligible
	53	46	40	0.87	Above	Negligible
	54	46	40	0.87	Above	Negligible
	55	47	41	0.87	Above	Negligible
	56	47	41	0.87	Above	Negligible
	57	47	41	0.87	Above	Negligible
	58	47	42	0.89	Above	Negligible
	59	48	42	0.88	Above	Negligible
	60	48	42	0.88	Above	Negligible
	61	47	42	0.89	Above	Negligible

	62	47	41	0.87	Above	Negligible
	63	47	41	0.87	Above	Negligible
	64	48	42	0.88	Above	Negligible
	65	48	42	0.88	Above	Negligible
	66	48	42	0.88	Above	Negligible
	67	48	42	0.88	Above	Negligible
	68	47	42	0.89	Above	Negligible
	69	48	42	0.88	Above	Negligible
	70	48	42	0.88	Above	Negligible
	71	48	42	0.88	Above	Negligible
1 Central Street (Offices)	0	19	9	0.47	Below	High
	1	19	12	0.63	Below	Medium
	2	19	12	0.63	Below	Medium
	3	18	13	0.72	Below	Low
	4	23	11	0.48	Below	High
	5	25	14	0.56	Below	High
	6	25	15	0.6	Below	Medium
	7	24	15	0.62	Below	Medium
	8	21	13	0.62	Below	Medium
	9	29	15	0.52	Below	High
	10	32	18	0.56	Below	High
	11	33	19	0.58	Below	High
	12	33	19	0.58	Below	High
	13	28	19	0.68	Below	Medium
	14	38	21	0.55	Below	High
	15	39	23	0.59	Below	High
	16	41	23	0.56	Below	High
	17	42	23	0.55	Below	High
6 Mount Str (martial art school, meeting, training and art gallery)	0	33	20	0.61	Below	Medium
	1	33	21	0.64	Below	Medium

75 Southmill St (Offices)	0	9	9	1	Above	Negligible
	1	7	7	1	Above	Negligible
	2	7	6	0.86	Above	Negligible
	3	6	5	0.83	Above	Negligible
	4	6	5	0.83	Above	Negligible
	5	6	6	1	Above	Negligible
	6	7	5	0.71	Below	Low
	7	7	6	0.86	Above	Negligible
	8	9	5	0.56	Below	High
	9	10	11	1.1	Above	Negligible
	10	9	8	0.89	Above	Negligible
	11	8	7	0.88	Above	Negligible
	12	8	7	0.88	Above	Negligible
	13	25	20	0.8	Above	Negligible
	14	8	7	0.88	Above	Negligible
	15	8	6	0.75	Below	Low
	16	9	7	0.78	Below	Low
	17	10	7	0.7	Below	Low
	18	12	7	0.58	Below	High
	19	26	21	0.81	Above	Negligible
	20	13	13	1	Above	Negligible
	21	11	10	0.91	Above	Negligible
	22	11	9	0.82	Above	Negligible
	23	10	9	0.9	Above	Negligible
	24	10	9	0.9	Above	Negligible
	25	11	8	0.73	Below	Low
	26	11	9	0.82	Above	Negligible
	27	13	9	0.69	Below	Medium
	28	15	9	0.6	Below	Medium
	29	30	24	0.8	Above	Negligible
	30	30	25	0.83	Above	Negligible

	31	30	25	0.83	Above	Negligible
	32	30	24	0.8	Above	Negligible
	33	16	14	0.88	Above	Negligible
	34	14	13	0.93	Above	Negligible
	35	13	12	0.92	Above	Negligible
	36	14	12	0.86	Above	Negligible
	37	14	12	0.86	Above	Negligible
	38	15	12	0.8	Above	Negligible
	39	16	11	0.69	Below	Medium
	40	18	12	0.67	Below	Medium
	41	21	12	0.57	Below	High
	42	36	28	0.78	Above	Negligible
	43	36	29	0.81	Above	Negligible
	44	36	29	0.81	Above	Negligible
	45	35	29	0.83	Above	Negligible
	46	21	18	0.86	Above	Negligible
	47	19	16	0.84	Above	Negligible
	48	20	16	0.8	Above	Negligible
	49	20	16	0.8	Above	Negligible
	50	20	16	0.8	Above	Negligible
	51	21	16	0.76	Below	Low
	52	23	16	0.7	Below	Low
	53	25	15	0.6	Below	Medium
	54	28	16	0.57	Below	High
	55	40	31	0.78	Above	Negligible
	56	40	32	0.8	Above	Negligible
	57	40	33	0.82	Above	Negligible
	58	40	34	0.85	Above	Negligible
Television House (Offices)	0	13	9	0.69	Below	Medium
	1	16	11	0.69	Below	Medium
	2	20	14	0.7	Below	Low

	3	22	16	0.73	Below	Low
	4	24	18	0.75	Below	Low
	5	27	20	0.74	Below	Low
	6	30	24	0.8	Above	Negligible
	7	33	27	0.82	Above	Negligible
	8	34	28	0.82	Above	Negligible
37 Peter Street (Offices)	0	7	3	0.43	Below	High
	1	6	3	0.5	Below	High
	2	7	5	0.71	Below	Low
	3	7	7	1	Above	Negligible
	4	9	10	1.11	Above	Negligible
	5	13	14	1.08	Above	Negligible
	6	9	3	0.33	Below	High
	7	9	4	0.44	Below	High
	8	9	6	0.67	Below	Medium
	9	10	8	0.8	Above	Negligible
	10	11	11	1	Above	Negligible
	11	14	16	1.14	Above	Negligible
	12	19	3	0.16	Below	High
	13	18	4	0.22	Below	High
	14	18	4	0.22	Below	High
	15	17	4	0.24	Below	High
	16	16	6	0.38	Below	High
	17	15	7	0.47	Below	High
	18	15	9	0.6	Below	Medium
	19	17	13	0.76	Below	Low
	20	19	19	1	Above	Negligible
	21	38	4	0.11	Below	High
	22	38	5	0.13	Below	High
	23	36	6	0.17	Below	High
	24	35	6	0.17	Below	High

	25	33	7	0.21	Below	High
	26	30	9	0.3	Below	High
	27	27	12	0.44	Below	High
	28	27	17	0.63	Below	Medium
	29	30	22	0.73	Below	Low
	30	43	5	0.12	Below	High
	31	42	6	0.14	Below	High
	32	43	7	0.16	Below	High
	33	42	8	0.19	Below	High
	34	42	10	0.24	Below	High
	35	42	13	0.31	Below	High
	36	41	17	0.41	Below	High
	37	41	22	0.54	Below	High
	38	41	26	0.63	Below	Medium
	39	44	6	0.14	Below	High
	40	44	8	0.18	Below	High
	41	45	10	0.22	Below	High
	42	44	12	0.27	Below	High
	43	45	14	0.31	Below	High
	44	44	17	0.39	Below	High
	45	44	21	0.48	Below	High
	46	44	25	0.57	Below	High
	47	44	28	0.64	Above	Negligible
11-13 Bootle Street	0	15	1	0.07	Below	High
	1	26	7	0.27	Below	High
	2	25	5	0.2	Below	High
	3	25	4	0.16	Below	High
	4	24	3	0.12	Below	High
	5	24	2	0.08	Below	High
	6	24	1	0.04	Below	High
	7	21	2	0.1	Below	High

	8	20	1	0.05	Below	High
	9	19	2	0.11	Below	High
	10	17	3	0.18	Below	High
	11	16	3	0.19	Below	High
	12	14	1	0.07	Below	High
Marron Place Building (office)	0	31	10	0.32	Below	High
	1	36	8	0.22	Below	High
	2	37	8	0.22	Below	High
	3	37	7	0.19	Below	High
	4	36	6	0.17	Below	High
	5	36	5	0.14	Below	High
	6	35	5	0.14	Below	High
	7	34	5	0.15	Below	High
	8	32	4	0.12	Below	High
	9	21	3	0.14	Below	High
	10	31	4	0.13	Below	High
	11	28	3	0.11	Below	High
	12	38	11	0.29	Below	High
	13	40	11	0.28	Below	High
	14	40	9	0.22	Below	High
	15	40	8	0.2	Below	High
	16	39	7	0.18	Below	High
	17	39	6	0.15	Below	High
	18	38	5	0.13	Below	High
	19	38	5	0.13	Below	High
	20	37	5	0.14	Below	High
	21	24	3	0.12	Below	High
	22	35	5	0.14	Below	High
	23	33	4	0.12	Below	High
	24	42	12	0.29	Below	High
	25	42	11	0.26	Below	High

	26	41	10	0.24	Below	High
	27	41	9	0.22	Below	High
	28	42	8	0.19	Below	High
	29	41	7	0.17	Below	High
	30	40	7	0.18	Below	High
	31	40	6	0.15	Below	High
	32	38	7	0.18	Below	High
	33	25	4	0.16	Below	High
	34	38	6	0.16	Below	High
	35	35	5	0.14	Below	High
	36	43	15	0.35	Below	High
	37	43	12	0.28	Below	High
	38	43	11	0.26	Below	High
	39	43	12	0.28	Below	High
	40	43	10	0.23	Below	High
	41	43	8	0.19	Below	High
	42	42	8	0.19	Below	High
	43	41	7	0.17	Below	High
	44	41	8	0.2	Below	High
	45	27	4	0.15	Below	High
	46	39	7	0.18	Below	High
	47	37	6	0.16	Below	High
	48	44	16	0.36	Below	High
	49	44	14	0.32	Below	High
	50	44	13	0.3	Below	High
	51	45	11	0.24	Below	High
	52	45	11	0.24	Below	High
	53	44	10	0.23	Below	High
	54	44	10	0.23	Below	High
	55	44	10	0.23	Below	High
	56	43	9	0.21	Below	High

	57	29	6	0.21	Below	High
	58	42	9	0.21	Below	High
	59	40	9	0.22	Below	High
Albert hall	0	23	6	0.26	Below	High
	1	20	5	0.25	Below	High
	2	23	6	0.26	Below	High
	3	26	6	0.23	Below	High
	4	24	2	0.08	Below	High
	5	26	3	0.12	Below	High
	6	22	5	0.23	Below	High
	7	23	6	0.26	Below	High
	8	24	6	0.25	Below	High
	9	27	3	0.11	Below	High
	10	30	4	0.13	Below	High
	11	31	5	0.16	Below	High
	12	34	8	0.24	Below	High
	13	33	7	0.21	Below	High
	14	33	7	0.21	Below	High
	15	29	7	0.24	Below	High
	16	32	7	0.22	Below	High
	17	32	6	0.19	Below	High
	18	32	7	0.22	Below	High
	19	35	7	0.2	Below	High
	20	29	4	0.14	Below	High
	21	33	5	0.15	Below	High
	22	34	6	0.18	Below	High
	23	38	7	0.18	Below	High
	24	39	9	0.23	Below	High
	25	39	9	0.23	Below	High
	26	37	9	0.24	Below	High
	27	38	8	0.21	Below	High

	28	38	9	0.24	Below	High
	29	43	20	0.47	Below	High
23 St Peter (covered windows)	0	19	3	0.16	Below	High
	1	21	3	0.14	Below	High
	2	22	3	0.14	Below	High
	3	14	4	0.29	Below	High
	4	25	3	0.12	Below	High
	5	22	3	0.14	Below	High
	6	26	4	0.15	Below	High
	7	24	3	0.12	Below	High
2 Bootle St/Jerusalem Place (offices, Rest, residential?)	0	10	8	0.8	Above	Negligible
	1	10	8	0.8	Above	Negligible
	2	9	7	0.78	Below	Low
	3	9	6	0.67	Below	Medium
	4	9	6	0.67	Below	Medium
	5	10	6	0.6	Below	Medium
	6	12	4	0.33	Below	High
	7	6	3	0.5	Below	High
	8	6	3	0.5	Below	High
	9	10	9	0.9	Above	Negligible
	10	10	10	1	Above	Negligible
	11	17	14	0.82	Above	Negligible
	12	16	13	0.81	Above	Negligible
	13	16	13	0.81	Above	Negligible
	14	16	12	0.75	Below	Low
	15	15	12	0.8	Above	Negligible
	16	17	11	0.65	Below	Medium
	17	15	5	0.33	Below	High
	18	8	4	0.5	Below	High
	19	7	6	0.86	Above	Negligible

	20	8	7	0.88	Above	Negligible
	21	13	11	0.85	Above	Negligible
	22	15	13	0.87	Above	Negligible
	23	29	23	0.79	Below	Low
	24	29	21	0.72	Below	Low
	25	29	21	0.72	Below	Low
	26	29	21	0.72	Below	Low
	27	28	19	0.68	Below	Medium
	28	28	19	0.68	Below	Medium
	29	21	9	0.43	Below	High
	30	11	7	0.64	Below	Medium
	31	11	7	0.64	Below	Medium
	32	11	8	0.73	Below	Low
	33	12	9	0.75	Below	Low
	34	18	15	0.83	Above	Negligible
	35	20	17	0.85	Above	Negligible
	36	34	26	0.76	Below	Low
	37	34	25	0.74	Below	Low
	38	34	24	0.71	Below	Low
	39	35	24	0.69	Below	Medium
	40	36	23	0.64	Below	Medium
	41	34	23	0.68	Below	Medium
	42	27	13	0.48	Below	High
	43	17	11	0.65	Below	Medium
	44	17	12	0.71	Below	Low
	45	18	13	0.72	Below	Low
	46	17	13	0.76	Below	Low
	47	24	20	0.83	Above	Negligible
	48	27	23	0.85	Above	Negligible
	49	25	20	0.8	Above	Negligible
	50	30	23	0.77	Below	Low

Theatre Royal (Unused Theatre, NightClub)	0	9	9	1	Above	Negligible
	1	11	9	0.82	Above	Negligible
	2	15	15	1	Above	Negligible
	3	21	19	0.9	Above	Negligible
	4	15	13	0.87	Above	Negligible
	5	16	15	0.94	Above	Negligible
	6	10	9	0.9	Above	Negligible
	7	12	10	0.83	Above	Negligible
	8	22	20	0.91	Above	Negligible
	9	19	17	0.89	Above	Negligible
	10	21	20	0.95	Above	Negligible
	11	25	23	0.92	Above	Negligible
	12	23	20	0.87	Above	Negligible
	13	33	30	0.91	Above	Negligible
Radison Blu Edwardian Manchester (Hotel)	0	13	12	0.92	Above	Negligible
	1	16	14	0.88	Above	Negligible
	2	15	12	0.8	Above	Negligible
	3	13	11	0.85	Above	Negligible
	4	13	11	0.85	Above	Negligible
	5	13	10	0.77	Below	Low
	6	13	11	0.85	Above	Negligible
	7	14	12	0.86	Above	Negligible
	8	14	11	0.79	Below	Low
	9	13	12	0.92	Above	Negligible
	10	10	10	1	Above	Negligible
	11	20	19	0.95	Above	Negligible
	12	23	22	0.96	Above	Negligible
	13	16	16	1	Above	Negligible
	14	26	25	0.96	Above	Negligible
	15	32	29	0.91	Above	Negligible

	16	31	24	0.77	Below	Low
	17	32	24	0.75	Below	Low
	18	30	24	0.8	Above	Negligible
	19	29	25	0.86	Above	Negligible
	20	29	25	0.86	Above	Negligible
	21	33	25	0.76	Below	Low
	22	30	27	0.9	Above	Negligible
	23	34	26	0.76	Below	Low
	24	25	23	0.92	Above	Negligible
	25	16	16	1	Above	Negligible
	26	30	29	0.97	Above	Negligible
	27	20	20	1	Above	Negligible
	28	27	26	0.96	Above	Negligible
	29	32	31	0.97	Above	Negligible
	30	38	35	0.92	Above	Negligible
	31	37	33	0.89	Above	Negligible
	32	38	34	0.89	Above	Negligible
	33	29	29	1	Above	Negligible
	34	34	31	0.91	Above	Negligible
	35	37	34	0.92	Above	Negligible
	36	42	38	0.9	Above	Negligible
	37	42	37	0.88	Above	Negligible
	38	37	35	0.95	Above	Negligible
	39	42	38	0.9	Above	Negligible
	40	42	38	0.9	Above	Negligible
	41	41	36	0.88	Above	Negligible
	42	40	33	0.82	Above	Negligible
	43	42	35	0.83	Above	Negligible
	44	43	36	0.84	Above	Negligible
	45	43	36	0.84	Above	Negligible
	46	44	40	0.91	Above	Negligible

	47	43	38	0.88	Above	Negligible
	48	39	36	0.92	Above	Negligible
	49	44	39	0.89	Above	Negligible
	50	44	39	0.89	Above	Negligible
	51	43	40	0.93	Above	Negligible
	52	42	36	0.86	Above	Negligible
	53	44	37	0.84	Above	Negligible
	54	45	38	0.84	Above	Negligible
	55	45	38	0.84	Above	Negligible
	56	40	38	0.95	Above	Negligible
	57	45	41	0.91	Above	Negligible
	58	45	40	0.89	Above	Negligible
	59	45	41	0.91	Above	Negligible
	60	44	40	0.91	Above	Negligible
	61	45	41	0.91	Above	Negligible
	62	45	38	0.84	Above	Negligible
	63	43	36	0.84	Above	Negligible
	64	45	40	0.89	Above	Negligible
	65	46	39	0.85	Above	Negligible
	66	46	43	0.93	Above	Negligible
	67	46	42	0.91	Above	Negligible
	68	46	42	0.91	Above	Negligible
	69	46	43	0.93	Above	Negligible
	70	44	41	0.93	Above	Negligible
	71	41	39	0.95	Above	Negligible
	72	44	38	0.86	Above	Negligible
	73	46	41	0.89	Above	Negligible
	74	46	39	0.85	Above	Negligible
	75	46	41	0.89	Above	Negligible
	76	47	44	0.94	Above	Negligible
	77	47	43	0.91	Above	Negligible

	78	47	43	0.91	Above	Negligible
	79	41	40	0.98	Above	Negligible
	80	45	42	0.93	Above	Negligible
	81	47	44	0.94	Above	Negligible
	82	44	39	0.89	Above	Negligible
	83	47	41	0.87	Above	Negligible
	84	47	42	0.89	Above	Negligible
	85	47	42	0.89	Above	Negligible
44 Peter Street (Offices?)	0	18	15	0.83	Above	Negligible
	1	20	15	0.75	Below	Low
	2	20	16	0.8	Above	Negligible
	3	20	17	0.85	Above	Negligible
	4	20	17	0.85	Above	Negligible
	5	20	17	0.85	Above	Negligible
	6	24	19	0.79	Below	Low
	7	26	20	0.77	Below	Low
	8	26	21	0.81	Above	Negligible
	9	27	22	0.81	Above	Negligible
	10	28	22	0.79	Below	Low
	11	29	23	0.79	Below	Low
	12	28	24	0.86	Above	Negligible
	13	29	22	0.76	Below	Low
	14	30	23	0.77	Below	Low
	15	31	24	0.77	Below	Low
	16	32	24	0.75	Below	Low
	17	32	24	0.75	Below	Low
	18	33	26	0.79	Below	Low
	19	33	26	0.79	Below	Low
	20	34	25	0.74	Below	Low
	21	35	26	0.74	Below	Low
	22	35	27	0.77	Above	Negligible

	23	36	27	0.75	Above	Negligible
	24	37	27	0.73	Above	Negligible
	25	37	28	0.76	Above	Negligible
	26	38	28	0.74	Above	Negligible
Fourth Church of Christ Scientists	0	25	22	0.88	Above	Negligible
	1	20	16	0.8	Above	Negligible
	2	26	22	0.85	Above	Negligible
	3	27	21	0.78	Below	Low
	4	26	22	0.85	Above	Negligible
	5	31	27	0.87	Above	Negligible
	6	36	30	0.83	Above	Negligible
	7	31	24	0.77	Below	Low
	8	31	24	0.77	Below	Low
	9	31	24	0.77	Below	Low
	10	37	27	0.73	Above	Negligible
	11	40	34	0.85	Above	Negligible
	12	38	27	0.71	Above	Negligible
	13	37	27	0.73	Above	Negligible
De Kuyper (Commercial)	0	22	18	0.82	Above	Negligible
	1	21	19	0.9	Above	Negligible
	2	21	18	0.86	Above	Negligible
	3	22	18	0.82	Above	Negligible
	4	21	18	0.86	Above	Negligible
	5	21	18	0.86	Above	Negligible
	6	21	17	0.81	Above	Negligible
	7	25	21	0.84	Above	Negligible
	8	29	23	0.79	Below	Low
	9	32	24	0.75	Below	Low
Greath Northern Tower (Residential)	0	7	8	1.14	Above	Negligible
	1	8	8	1	Above	Negligible
	2	12	10	0.83	Above	Negligible

	3	13	11	0.85	Above	Negligible
	4	11	10	0.91	Above	Negligible
	5	13	13	1	Above	Negligible
	6	9	8	0.89	Above	Negligible
	7	16	13	0.81	Above	Negligible
	8	13	12	0.92	Above	Negligible
	9	17	16	0.94	Above	Negligible
	10	12	10	0.83	Above	Negligible
	11	19	17	0.89	Above	Negligible
	12	15	13	0.87	Above	Negligible
	13	16	15	0.94	Above	Negligible
	14	23	20	0.87	Above	Negligible
	15	21	19	0.9	Above	Negligible
	16	27	23	0.85	Above	Negligible
	17	22	19	0.86	Above	Negligible
	18	29	26	0.9	Above	Negligible
	19	20	17	0.85	Above	Negligible
	20	33	29	0.88	Above	Negligible
	21	27	23	0.85	Above	Negligible
	22	35	30	0.86	Above	Negligible
	23	25	21	0.84	Above	Negligible
	24	30	26	0.87	Above	Negligible
	25	39	33	0.85	Above	Negligible
	26	32	28	0.88	Above	Negligible
	27	38	32	0.84	Above	Negligible
	28	35	29	0.83	Above	Negligible
	29	43	36	0.84	Above	Negligible
	30	37	31	0.84	Above	Negligible
	31	41	35	0.85	Above	Negligible
	32	43	37	0.86	Above	Negligible
	33	39	33	0.85	Above	Negligible

	34	43	38	0.88	Above	Negligible
	35	37	33	0.89	Above	Negligible
	36	41	36	0.88	Above	Negligible
	37	45	39	0.87	Above	Negligible
	38	42	37	0.88	Above	Negligible
	39	44	39	0.89	Above	Negligible
	40	44	39	0.89	Above	Negligible
	41	46	41	0.89	Above	Negligible
	42	45	40	0.89	Above	Negligible
	43	46	41	0.89	Above	Negligible
	44	46	43	0.93	Above	Negligible
	45	47	43	0.91	Above	Negligible
	46	46	43	0.93	Above	Negligible
	47	48	43	0.9	Above	Negligible
	48	48	45	0.94	Above	Negligible
	49	48	44	0.92	Above	Negligible
	50	48	44	0.92	Above	Negligible
	51	48	44	0.92	Above	Negligible
	52	48	45	0.94	Above	Negligible
	53	48	44	0.92	Above	Negligible
	54	48	45	0.94	Above	Negligible
	55	48	44	0.92	Above	Negligible
	56	49	45	0.92	Above	Negligible
	57	48	44	0.92	Above	Negligible
	58	49	45	0.92	Above	Negligible
	59	48	45	0.94	Above	Negligible
	60	49	45	0.92	Above	Negligible
	61	48	45	0.94	Above	Negligible
	62	49	45	0.92	Above	Negligible
	63	48	45	0.94	Above	Negligible
Oddfellows House	0	21	16	0.76	Below	Low

	1	22	16	0.73	Below	Low
	2	20	16	0.8	Above	Negligible
	3	21	18	0.86	Above	Negligible
	4	21	18	0.86	Above	Negligible
	5	24	18	0.75	Below	Low
	6	23	18	0.78	Below	Low
	7	24	19	0.79	Below	Low
	8	23	16	0.7	Below	Low
	9	22	19	0.86	Above	Negligible
	10	21	18	0.86	Above	Negligible
	11	20	17	0.85	Above	Negligible
	12	19	16	0.84	Above	Negligible
	13	23	18	0.78	Below	Low
	14	19	16	0.84	Above	Negligible
	15	24	20	0.83	Above	Negligible
	16	24	21	0.88	Above	Negligible
	17	25	20	0.8	Above	Negligible
	18	26	22	0.85	Above	Negligible
	19	26	22	0.85	Above	Negligible
	20	26	21	0.81	Above	Negligible
	21	28	23	0.82	Above	Negligible
	22	28	21	0.75	Below	Low
	23	26	20	0.77	Below	Low
	24	26	20	0.77	Below	Low
	25	28	21	0.75	Below	Low
	26	29	23	0.79	Below	Low
	27	28	21	0.75	Below	Low
	28	29	22	0.76	Below	Low
	29	29	23	0.79	Below	Low
	30	31	26	0.84	Above	Negligible
	31	32	25	0.78	Below	Low

	32	32	25	0.78	Below	Low
	33	33	25	0.76	Below	Low
	34	32	25	0.78	Below	Low
	35	33	27	0.82	Above	Negligible
	36	34	26	0.76	Below	Low
	37	34	25	0.74	Below	Low
	38	33	26	0.79	Below	Low
	39	33	26	0.79	Below	Low
	40	35	26	0.74	Below	Low
	41	34	26	0.76	Below	Low
	42	34	26	0.76	Below	Low
	43	35	27	0.77	Above	Negligible
	44	34	27	0.79	Above	Negligible
Oddfellows House (offices)	0	24	20	0.83	Above	Negligible
	1	24	21	0.88	Above	Negligible
	2	24	20	0.83	Above	Negligible
	3	24	20	0.83	Above	Negligible
	4	23	18	0.78	Below	Low
	5	22	18	0.82	Above	Negligible
	6	25	21	0.84	Above	Negligible
	7	22	18	0.82	Above	Negligible
	8	25	19	0.76	Below	Low
	9	23	20	0.87	Above	Negligible
	10	23	20	0.87	Above	Negligible
	11	22	19	0.86	Above	Negligible
	12	24	20	0.83	Above	Negligible
	13	25	20	0.8	Above	Negligible
	14	25	20	0.8	Above	Negligible
	15	25	21	0.84	Above	Negligible
	16	28	23	0.82	Above	Negligible
	17	29	24	0.83	Above	Negligible

	18	29	25	0.86	Above	Negligible
	19	30	24	0.8	Above	Negligible
	20	29	25	0.86	Above	Negligible
	21	27	22	0.81	Above	Negligible
	22	28	22	0.79	Below	Low
	23	28	22	0.79	Below	Low
	24	29	24	0.83	Above	Negligible
	25	30	24	0.8	Above	Negligible
	26	29	23	0.79	Below	Low
	27	29	22	0.76	Below	Low
	28	30	25	0.83	Above	Negligible
	29	30	23	0.77	Below	Low
	30	30	24	0.8	Above	Negligible
	31	30	24	0.8	Above	Negligible
	32	34	28	0.82	Above	Negligible
	33	34	28	0.82	Above	Negligible
	34	35	28	0.8	Above	Negligible
	35	35	28	0.8	Above	Negligible
	36	35	27	0.77	Above	Negligible
	37	34	27	0.79	Above	Negligible
	38	34	29	0.85	Above	Negligible
	39	34	29	0.85	Above	Negligible
	40	35	28	0.8	Above	Negligible
	41	36	28	0.78	Above	Negligible
	42	34	27	0.79	Above	Negligible
	43	35	27	0.77	Above	Negligible
	44	36	28	0.78	Above	Negligible
	45	36	28	0.78	Above	Negligible
	46	36	28	0.78	Above	Negligible
	47	36	28	0.78	Above	Negligible
	48	40	32	0.8	Above	Negligible

	49	39	33	0.85	Above	Negligible
	50	40	32	0.8	Above	Negligible
	51	40	32	0.8	Above	Negligible
	52	39	30	0.77	Above	Negligible
	53	39	30	0.77	Above	Negligible
	54	39	33	0.85	Above	Negligible
	55	39	31	0.79	Above	Negligible
	56	41	31	0.76	Above	Negligible
	57	41	31	0.76	Above	Negligible
	58	40	30	0.75	Above	Negligible
	59	40	31	0.78	Above	Negligible
	60	40	32	0.8	Above	Negligible
	61	39	32	0.82	Above	Negligible
	62	41	32	0.78	Above	Negligible
	63	40	31	0.78	Above	Negligible
1 Scott Street (Offices, Commercial)	0	27	26	0.96	Above	Negligible
	1	10	8	0.8	Above	Negligible
	2	18	15	0.83	Above	Negligible
	3	15	12	0.8	Above	Negligible
	4	13	13	1	Above	Negligible
	5	1	0	0	Below	High
	6	6	5	0.83	Above	Negligible
	7	19	16	0.84	Above	Negligible
	8	37	35	0.95	Above	Negligible
	9	23	21	0.91	Above	Negligible
	10	29	24	0.83	Above	Negligible
	11	32	27	0.84	Above	Negligible
	12	39	38	0.97	Above	Negligible
	13	33	30	0.91	Above	Negligible
	14	37	32	0.86	Above	Negligible
	15	38	32	0.84	Above	Negligible

	16	23	19	0.83	Above	Negligible
	17	24	21	0.88	Above	Negligible
	18	42	39	0.93	Above	Negligible
	19	40	36	0.9	Above	Negligible
	20	41	36	0.88	Above	Negligible
	21	42	35	0.83	Above	Negligible
	22	28	23	0.82	Above	Negligible
	23	25	23	0.92	Above	Negligible
	24	28	25	0.89	Above	Negligible
	25	44	42	0.95	Above	Negligible
	26	42	38	0.9	Above	Negligible
	27	43	38	0.88	Above	Negligible
	28	43	37	0.86	Above	Negligible
	29	33	29	0.88	Above	Negligible
	30	32	28	0.88	Above	Negligible
	31	45	43	0.96	Above	Negligible
	32	44	41	0.93	Above	Negligible
	33	45	40	0.89	Above	Negligible
	34	46	39	0.85	Above	Negligible
	35	39	32	0.82	Above	Negligible
	36	47	45	0.96	Above	Negligible
	37	47	44	0.94	Above	Negligible
	38	47	42	0.89	Above	Negligible
	39	47	40	0.85	Above	Negligible
	40	42	36	0.86	Above	Negligible
	41	47	44	0.94	Above	Negligible
	42	47	42	0.89	Above	Negligible
	43	48	40	0.83	Above	Negligible
	44	44	39	0.89	Above	Negligible
123 Deansgate	0	10	11	1.1	Above	Negligible
	1	14	14	1	Above	Negligible

	2	19	18	0.95	Above	Negligible
	3	21	21	1	Above	Negligible
	4	11	11	1	Above	Negligible
	5	12	12	1	Above	Negligible
	6	12	11	0.92	Above	Negligible
	7	13	13	1	Above	Negligible
	8	14	14	1	Above	Negligible
	9	17	17	1	Above	Negligible
	10	15	15	1	Above	Negligible
	11	18	19	1.06	Above	Negligible
	12	21	21	1	Above	Negligible
	13	20	20	1	Above	Negligible
	14	22	22	1	Above	Negligible
	15	23	23	1	Above	Negligible
	16	23	22	0.96	Above	Negligible
	17	23	24	1.04	Above	Negligible
	18	25	25	1	Above	Negligible
	19	24	24	1	Above	Negligible
	20	25	25	1	Above	Negligible
	21	26	25	0.96	Above	Negligible
	22	26	26	1	Above	Negligible
	23	27	27	1	Above	Negligible
	24	13	13	1	Above	Negligible
	25	13	12	0.92	Above	Negligible
	26	14	13	0.93	Above	Negligible
	27	14	14	1	Above	Negligible
	28	15	15	1	Above	Negligible
	29	19	18	0.95	Above	Negligible
	30	16	18	1.12	Above	Negligible
	31	20	20	1	Above	Negligible
	32	23	23	1	Above	Negligible

	33	21	21	1	Above	Negligible
	34	24	23	0.96	Above	Negligible
	35	25	25	1	Above	Negligible
	36	24	24	1	Above	Negligible
	37	26	26	1	Above	Negligible
	38	27	28	1.04	Above	Negligible
	39	26	27	1.04	Above	Negligible
	40	28	28	1	Above	Negligible
	41	28	29	1.04	Above	Negligible
	42	29	28	0.97	Above	Negligible
	43	29	29	1	Above	Negligible
	44	14	14	1	Above	Negligible
	45	14	13	0.93	Above	Negligible
	46	15	15	1	Above	Negligible
	47	16	15	0.94	Above	Negligible
	48	17	16	0.94	Above	Negligible
	49	20	20	1	Above	Negligible
	50	18	18	1	Above	Negligible
	51	22	22	1	Above	Negligible
	52	25	25	1	Above	Negligible
	53	24	24	1	Above	Negligible
	54	26	26	1	Above	Negligible
	55	28	27	0.96	Above	Negligible
	56	27	27	1	Above	Negligible
	57	28	28	1	Above	Negligible
	58	29	30	1.03	Above	Negligible
	59	29	29	1	Above	Negligible
	60	31	30	0.97	Above	Negligible
	61	31	31	1	Above	Negligible
	62	31	31	1	Above	Negligible
	63	32	31	0.97	Above	Negligible

	64	16	16	1	Above	Negligible
	65	15	15	1	Above	Negligible
	66	16	17	1.06	Above	Negligible
	67	17	18	1.06	Above	Negligible
	68	18	19	1.06	Above	Negligible
	69	22	22	1	Above	Negligible
	70	21	21	1	Above	Negligible
	71	24	24	1	Above	Negligible
	72	27	27	1	Above	Negligible
	73	26	26	1	Above	Negligible
	74	28	28	1	Above	Negligible
	75	31	30	0.97	Above	Negligible
	76	30	29	0.97	Above	Negligible
	77	31	30	0.97	Above	Negligible
	78	33	32	0.97	Above	Negligible
	79	32	31	0.97	Above	Negligible
	80	33	33	1	Above	Negligible
	81	34	33	0.97	Above	Negligible
	82	35	34	0.97	Above	Negligible
	83	35	33	0.94	Above	Negligible
	84	18	18	1	Above	Negligible
	85	18	18	1	Above	Negligible
	86	19	19	1	Above	Negligible
	87	20	20	1	Above	Negligible
	88	21	21	1	Above	Negligible
	89	24	24	1	Above	Negligible
	90	22	23	1.05	Above	Negligible
	91	26	26	1	Above	Negligible
	92	30	30	1	Above	Negligible
	93	28	28	1	Above	Negligible
	94	31	31	1	Above	Negligible

	95	33	33	1	Above	Negligible
	96	32	32	1	Above	Negligible
	97	33	34	1.03	Above	Negligible
	98	36	35	0.97	Above	Negligible
	99	35	34	0.97	Above	Negligible
	100	36	35	0.97	Above	Negligible
	101	37	35	0.95	Above	Negligible
	102	37	36	0.97	Above	Negligible
	103	38	36	0.95	Above	Negligible
	104	22	22	1	Above	Negligible
	105	21	22	1.05	Above	Negligible
	106	23	22	0.96	Above	Negligible
	107	23	23	1	Above	Negligible
	108	24	25	1.04	Above	Negligible
	109	28	28	1	Above	Negligible
	110	26	26	1	Above	Negligible
	111	30	30	1	Above	Negligible
	112	34	34	1	Above	Negligible
	113	31	31	1	Above	Negligible
	114	34	34	1	Above	Negligible
	115	36	36	1	Above	Negligible
	116	35	36	1.03	Above	Negligible
	117	37	36	0.97	Above	Negligible
	118	38	37	0.97	Above	Negligible
	119	38	37	0.97	Above	Negligible
	120	39	38	0.97	Above	Negligible
	121	40	38	0.95	Above	Negligible
	122	40	38	0.95	Above	Negligible
	123	41	38	0.93	Above	Negligible
	124	29	28	0.97	Above	Negligible
	125	28	27	0.96	Above	Negligible

	126	29	28	0.97	Above	Negligible
	127	30	29	0.97	Above	Negligible
	128	31	30	0.97	Above	Negligible
	129	33	32	0.97	Above	Negligible
	130	32	31	0.97	Above	Negligible
	131	35	34	0.97	Above	Negligible
	132	38	36	0.95	Above	Negligible
	133	36	35	0.97	Above	Negligible
	134	39	38	0.97	Above	Negligible
	135	40	39	0.98	Above	Negligible
	136	39	38	0.97	Above	Negligible
	137	41	39	0.95	Above	Negligible
	138	42	40	0.95	Above	Negligible
	139	41	40	0.98	Above	Negligible
	140	42	41	0.98	Above	Negligible
	141	43	41	0.95	Above	Negligible
	142	43	41	0.95	Above	Negligible
	143	44	41	0.93	Above	Negligible
	144	39	36	0.92	Above	Negligible
	145	39	37	0.95	Above	Negligible
	146	39	37	0.95	Above	Negligible
	147	40	37	0.92	Above	Negligible
	148	40	38	0.95	Above	Negligible
	149	41	39	0.95	Above	Negligible
	150	40	39	0.98	Above	Negligible
	151	42	39	0.93	Above	Negligible
	152	43	41	0.95	Above	Negligible
	153	42	41	0.98	Above	Negligible
	154	44	42	0.95	Above	Negligible
	155	45	43	0.96	Above	Negligible
	156	44	42	0.95	Above	Negligible

	157	45	42	0.93	Above	Negligible
	158	45	43	0.96	Above	Negligible
	159	46	43	0.93	Above	Negligible
	160	46	43	0.93	Above	Negligible
	161	46	43	0.93	Above	Negligible
	162	46	44	0.96	Above	Negligible
	163	46	44	0.96	Above	Negligible
	164	48	44	0.92	Above	Negligible
	165	48	44	0.92	Above	Negligible
	166	48	45	0.94	Above	Negligible
	167	48	45	0.94	Above	Negligible
	168	48	45	0.94	Above	Negligible
	169	48	45	0.94	Above	Negligible
	170	48	45	0.94	Above	Negligible
	171	48	45	0.94	Above	Negligible
	172	48	45	0.94	Above	Negligible
	173	48	45	0.94	Above	Negligible
	174	48	45	0.94	Above	Negligible
	175	48	45	0.94	Above	Negligible
	176	48	45	0.94	Above	Negligible
	177	48	45	0.94	Above	Negligible
	178	48	45	0.94	Above	Negligible
	179	48	45	0.94	Above	Negligible
	180	48	45	0.94	Above	Negligible
	181	48	44	0.92	Above	Negligible
	182	48	45	0.94	Above	Negligible
	183	48	45	0.94	Above	Negligible
	184	48	45	0.94	Above	Negligible
	185	48	45	0.94	Above	Negligible
	186	48	45	0.94	Above	Negligible
	187	48	45	0.94	Above	Negligible

	188	48	45	0.94	Above	Negligible
	189	48	45	0.94	Above	Negligible
	190	48	45	0.94	Above	Negligible
	191	48	45	0.94	Above	Negligible
	192	48	45	0.94	Above	Negligible
	193	48	45	0.94	Above	Negligible
	194	48	45	0.94	Above	Negligible
	195	48	45	0.94	Above	Negligible
	196	48	45	0.94	Above	Negligible
	197	48	45	0.94	Above	Negligible
	198	48	45	0.94	Above	Negligible
	199	48	45	0.94	Above	Negligible
	200	48	45	0.94	Above	Negligible
	201	48	45	0.94	Above	Negligible
	202	48	45	0.94	Above	Negligible
	203	48	45	0.94	Above	Negligible
Scottish House	0	22	21	0.95	Above	Negligible
	1	22	21	0.95	Above	Negligible
	2	21	20	0.95	Above	Negligible
	3	20	20	1	Above	Negligible
	4	20	19	0.95	Above	Negligible
	5	20	19	0.95	Above	Negligible
	6	20	19	0.95	Above	Negligible
	7	20	18	0.9	Above	Negligible
	8	21	19	0.9	Above	Negligible
	9	20	19	0.95	Above	Negligible
	10	20	18	0.9	Above	Negligible
	11	21	18	0.86	Above	Negligible
	12	21	19	0.9	Above	Negligible
	13	21	19	0.9	Above	Negligible
	14	21	19	0.9	Above	Negligible

	15	21	19	0.9	Above	Negligible
	16	21	20	0.95	Above	Negligible
	17	22	20	0.91	Above	Negligible
	18	26	25	0.96	Above	Negligible
	19	26	25	0.96	Above	Negligible
	20	26	24	0.92	Above	Negligible
	21	25	24	0.96	Above	Negligible
	22	25	23	0.92	Above	Negligible
	23	25	23	0.92	Above	Negligible
	24	25	23	0.92	Above	Negligible
	25	25	23	0.92	Above	Negligible
	26	25	24	0.96	Above	Negligible
	27	25	24	0.96	Above	Negligible
	28	27	25	0.93	Above	Negligible
	29	26	25	0.96	Above	Negligible
	30	27	25	0.93	Above	Negligible
	31	27	25	0.93	Above	Negligible
	32	31	30	0.97	Above	Negligible
	33	31	29	0.94	Above	Negligible
	34	31	29	0.94	Above	Negligible
	35	31	28	0.9	Above	Negligible
	36	30	29	0.97	Above	Negligible
	37	31	28	0.9	Above	Negligible
	38	31	29	0.94	Above	Negligible
	39	31	29	0.94	Above	Negligible
	40	31	29	0.94	Above	Negligible
	41	32	29	0.91	Above	Negligible
	42	32	29	0.91	Above	Negligible
	43	32	29	0.91	Above	Negligible
	44	32	29	0.91	Above	Negligible
	45	33	29	0.88	Above	Negligible

	46	34	30	0.88	Above	Negligible
	47	34	31	0.91	Above	Negligible
	48	34	31	0.91	Above	Negligible
	49	35	31	0.89	Above	Negligible
	50	36	33	0.92	Above	Negligible
	51	35	32	0.91	Above	Negligible
	52	35	32	0.91	Above	Negligible
	53	35	33	0.94	Above	Negligible
	54	35	32	0.91	Above	Negligible
	55	35	32	0.91	Above	Negligible
	56	36	32	0.89	Above	Negligible
	57	36	33	0.92	Above	Negligible
	58	36	33	0.92	Above	Negligible
	59	37	34	0.92	Above	Negligible
	60	37	34	0.92	Above	Negligible
	61	37	35	0.95	Above	Negligible
	62	38	34	0.89	Above	Negligible
	63	38	34	0.89	Above	Negligible
	64	39	35	0.9	Above	Negligible
	65	39	35	0.9	Above	Negligible
	66	39	36	0.92	Above	Negligible
	67	39	36	0.92	Above	Negligible
	68	39	37	0.95	Above	Negligible
	69	39	37	0.95	Above	Negligible
	70	39	37	0.95	Above	Negligible
	71	39	37	0.95	Above	Negligible
	72	39	37	0.95	Above	Negligible
	73	40	38	0.95	Above	Negligible
	74	40	37	0.92	Above	Negligible
	75	41	38	0.93	Above	Negligible
	76	41	38	0.93	Above	Negligible



	77	41	38	0.93	Above	Negligible
	78	42	38	0.9	Above	Negligible
	79	42	38	0.9	Above	Negligible
	80	42	38	0.9	Above	Negligible
	81	42	39	0.93	Above	Negligible
	82	43	40	0.93	Above	Negligible
	83	43	40	0.93	Above	Negligible
	84	43	40	0.93	Above	Negligible
	85	44	40	0.91	Above	Negligible

Detailed Sunlight Results

Receptor	Win dows No	APSH H Basel ine (%)	APSH Propo sed (%)	APSH Ratio of Impac t	WPS H Basel ine (%)	WPS H Propo sed (%)	WPSH Ratio of Impac t	Absolu te Reduct ion (%)	BRE Com plian ce	Magni tude of Impac t
Elliot House (Chamber of Commerce)	0	41	31	0.76	2	2	1	10	Below	Low
	1	38	28	0.74	1	1	1	10	Below	Low
	2	36	26	0.72	1	1	1	10	Below	Low
	3	33	23	0.7	1	0	0	10	Below	High
	4	33	22	0.67	1	0	0	11	Below	High
	5	34	22	0.65	1	0	0	12	Below	High
	6	32	20	0.62	1	0	0	12	Below	High
	7	32	20	0.62	1	0	0	12	Below	High
	8	31	19	0.61	1	0	0	12	Below	High
	9	34	21	0.62	2	0	0	13	Below	High
	10	33	20	0.61	2	0	0	13	Below	High
	11	34	20	0.59	1	0	0	14	Below	High
	12	36	21	0.58	1	0	0	15	Below	High
	13	34	18	0.53	1	0	0	16	Below	High
	14	36	19	0.53	2	0	0	17	Below	High
	15	40	21	0.52	3	0	0	19	Below	High
	16	40	21	0.52	3	0	0	19	Below	High
	17	40	19	0.48	3	0	0	21	Below	High
	18	42	18	0.43	5	0	0	24	Below	High
	19	44	19	0.43	5	0	0	25	Below	High
	20	49	19	0.39	8	0	0	30	Below	High
	21	51	20	0.39	8	0	0	31	Below	High
	22	51	38	0.75	5	4	0.8	13	Below	Low
	23	50	37	0.74	4	3	0.75	13	Below	Low
	24	50	37	0.74	4	3	0.75	13	Below	Low
	25	47	33	0.7	2	1	0.5	14	Below	High

	26	48	34	0.71	2	1	0.5	14	Below	High
	27	46	32	0.7	1	0	0	14	Below	High
	28	48	34	0.71	2	1	0.5	14	Below	High
	29	46	32	0.7	1	0	0	14	Below	High
	30	48	34	0.71	1	0	0	14	Below	High
	31	47	31	0.66	2	0	0	16	Below	High
	32	48	32	0.67	2	0	0	16	Below	High
	33	47	29	0.62	2	0	0	18	Below	High
	34	47	29	0.62	2	0	0	18	Below	High
	35	48	28	0.58	2	0	0	20	Below	High
	36	49	27	0.55	4	0	0	22	Below	High
	37	51	29	0.57	5	0	0	22	Below	High
	38	52	29	0.56	5	0	0	23	Below	High
	39	53	27	0.51	7	0	0	26	Below	High
	40	59	28	0.47	11	0	0	31	Below	High
	41	61	31	0.51	11	0	0	30	Below	High
	42	65	31	0.48	14	0	0	34	Below	High
	43	64	29	0.45	13	0	0	35	Below	High
	44	66	49	0.74	11	7	0.64	17	Above	Negligible
	45	67	50	0.75	9	5	0.56	17	Above	Negligible
	46	67	49	0.73	9	5	0.56	18	Above	Negligible
	47	67	49	0.73	9	5	0.56	18	Above	Negligible
	48	67	49	0.73	9	5	0.56	18	Above	Negligible
	49	66	48	0.73	8	4	0.5	18	Below	High
	50	66	47	0.71	8	3	0.38	19	Below	High
	51	66	47	0.71	8	3	0.38	19	Below	High
	52	64	45	0.7	6	1	0.17	19	Below	High
	53	66	47	0.71	7	2	0.29	19	Below	High
	54	66	46	0.7	7	2	0.29	20	Below	High

	55	66	46	0.7	7	2	0.29	20	Below	High
	56	66	44	0.67	7	2	0.29	22	Below	High
	57	68	44	0.65	9	2	0.22	24	Below	High
	58	68	43	0.63	9	2	0.22	25	Below	High
	59	67	41	0.61	9	2	0.22	26	Below	High
	60	67	41	0.61	9	1	0.11	26	Below	High
	61	68	41	0.6	10	1	0.1	27	Below	High
	62	69	39	0.57	12	1	0.08	30	Below	High
	63	71	39	0.55	14	2	0.14	32	Below	High
	64	72	40	0.56	14	1	0.07	32	Below	High
	65	75	39	0.52	17	1	0.06	36	Below	High
	66	78	40	0.51	19	2	0.11	38	Below	High
The Old Nags Head (Pub)	0	51	17	0.33	7	0	0	34	Below	High
	1	53	16	0.3	7	0	0	37	Below	High
	2	51	16	0.31	4	0	0	35	Below	High
	3	51	14	0.27	3	0	0	37	Below	High
	4	51	13	0.25	3	0	0	38	Below	High
	5	52	13	0.25	3	0	0	39	Below	High
	6	62	25	0.4	12	0	0	37	Below	High
	7	65	23	0.35	12	0	0	42	Below	High
	8	65	21	0.32	12	0	0	44	Below	High
	9	61	17	0.28	9	0	0	44	Below	High
	10	63	16	0.25	10	0	0	47	Below	High
	11	65	16	0.25	11	0	0	49	Below	High
	12	72	27	0.38	15	0	0	45	Below	High
	13	73	21	0.29	16	0	0	52	Below	High
	14	74	18	0.24	17	0	0	56	Below	High
19 Jackson's row (office)	0	60	12	0.2	5	0	0	48	Below	High
Croxley House (offices+Nightclub)	0	66	7	0.11	11	0	0	59	Below	High
	1	65	8	0.12	10	0	0	57	Below	High

	2	67	7	0.1	13	0	0	60	Below	High
	3	74	9	0.12	17	0	0	65	Below	High
	4	77	9	0.12	20	0	0	68	Below	High
	5	81	9	0.11	23	0	0	72	Below	High
	6	79	8	0.1	22	0	0	71	Below	High
	7	82	9	0.11	23	0	0	73	Below	High
	8	82	9	0.11	23	0	0	73	Below	High
	9	83	9	0.11	24	0	0	74	Below	High
	10	87	9	0.1	28	0	0	78	Below	High
	11	85	16	0.19	26	1	0.04	69	Below	High
	12	85	11	0.13	26	1	0.04	74	Below	High
	13	86	11	0.13	27	1	0.04	75	Below	High
	14	87	9	0.1	28	0	0	78	Below	High
	15	86	24	0.28	27	1	0.04	62	Below	High
	16	86	22	0.26	27	1	0.04	64	Below	High
	17	86	22	0.26	27	1	0.04	64	Below	High
	18	86	19	0.22	27	1	0.04	67	Below	High
	19	87	16	0.18	28	1	0.04	71	Below	High
	20	87	14	0.16	28	1	0.04	73	Below	High
	21	88	15	0.17	29	1	0.03	73	Below	High
	22	87	30	0.34	28	1	0.04	57	Below	High
Loyds House (Offices, Restaurant, Offices)	0	83	9	0.11	26	0	0	74	Below	High
	1	74	8	0.11	18	0	0	66	Below	High
	2	71	7	0.1	16	0	0	64	Below	High
	3	71	7	0.1	16	0	0	64	Below	High
	4	71	7	0.1	16	1	0.06	64	Below	High
	5	72	9	0.12	17	1	0.06	63	Below	High
	6	72	9	0.12	16	1	0.06	63	Below	High
	7	71	9	0.13	15	1	0.07	62	Below	High
	8	70	10	0.14	14	1	0.07	60	Below	High

	9	69	9	0.13	13	0	0	60	Below	High
	10	67	9	0.13	11	0	0	58	Below	High
	11	62	10	0.16	7	0	0	52	Below	High
	12	61	12	0.2	6	0	0	49	Below	High
	13	58	11	0.19	5	1	0.2	47	Below	High
	14	54	12	0.22	2	0	0	42	Below	High
	15	52	15	0.29	3	1	0.33	37	Below	High
	16	61	20	0.33	9	3	0.33	41	Below	High
	17	47	16	0.34	3	3	1	31	Below	High
	18	46	16	0.35	3	4	1.33	30	Below	High
	19	44	17	0.39	6	6	1	27	Below	High
	20	31	23	0.74	5	9	1.8	8	Below	Low
	21	85	9	0.11	27	0	0	76	Below	High
	22	84	9	0.11	26	0	0	75	Below	High
	23	84	9	0.11	27	1	0.04	75	Below	High
	24	82	9	0.11	26	1	0.04	73	Below	High
	25	83	10	0.12	27	1	0.04	73	Below	High
	26	81	9	0.11	25	1	0.04	72	Below	High
	27	81	9	0.11	25	1	0.04	72	Below	High
	28	80	10	0.12	24	1	0.04	70	Below	High
	29	80	10	0.12	24	1	0.04	70	Below	High
	30	80	10	0.12	24	1	0.04	70	Below	High
	31	81	11	0.14	25	2	0.08	70	Below	High
	32	81	12	0.15	25	2	0.08	69	Below	High
	33	79	12	0.15	24	2	0.08	67	Below	High
	34	79	12	0.15	24	2	0.08	67	Below	High
	35	77	12	0.16	22	1	0.05	65	Below	High
	36	74	14	0.19	19	0	0	60	Below	High
	37	74	17	0.23	19	1	0.05	57	Below	High
	38	73	20	0.27	19	2	0.11	53	Below	High
	39	68	23	0.34	14	4	0.29	45	Below	High

	40	68	26	0.38	14	5	0.36	42	Above	Negligible
	41	69	29	0.42	16	8	0.5	40	Above	Negligible
	42	65	30	0.46	13	8	0.62	35	Above	Negligible
	43	52	32	0.62	16	11	0.69	20	Above	Negligible
	44	87	10	0.11	28	0	0	77	Below	High
	45	87	11	0.13	28	0	0	76	Below	High
	46	87	11	0.13	28	0	0	76	Below	High
	47	86	10	0.12	28	0	0	76	Below	High
	48	86	12	0.14	28	1	0.04	74	Below	High
	49	84	10	0.12	28	1	0.04	74	Below	High
	50	83	10	0.12	27	1	0.04	73	Below	High
	51	82	10	0.12	26	1	0.04	72	Below	High
	52	81	12	0.15	25	2	0.08	69	Below	High
	53	81	12	0.15	25	2	0.08	69	Below	High
	54	81	12	0.15	25	2	0.08	69	Below	High
	55	81	12	0.15	25	2	0.08	69	Below	High
	56	81	12	0.15	25	2	0.08	69	Below	High
	57	79	12	0.15	24	2	0.08	67	Below	High
	58	80	12	0.15	25	2	0.08	68	Below	High
	59	81	14	0.17	26	3	0.12	67	Below	High
	60	81	17	0.21	26	3	0.12	64	Below	High
	61	82	20	0.24	26	4	0.15	62	Below	High
	62	81	25	0.31	25	4	0.16	56	Below	High
	63	80	25	0.31	24	4	0.17	55	Below	High
	64	82	31	0.38	26	7	0.27	51	Above	Negligible
	65	81	33	0.41	26	8	0.31	48	Above	Negligible
	66	82	36	0.44	26	9	0.35	46	Above	Negligible

	67	81	40	0.49	25	11	0.44	41	Above	Negligible
	68	71	50	0.7	21	11	0.52	21	Above	Negligible
	69	88	15	0.17	29	1	0.03	73	Below	High
	70	88	13	0.15	29	1	0.03	75	Below	High
	71	88	14	0.16	29	1	0.03	74	Below	High
	72	88	15	0.17	29	1	0.03	73	Below	High
	73	88	17	0.19	29	2	0.07	71	Below	High
	74	88	16	0.18	29	2	0.07	72	Below	High
	75	86	13	0.15	29	2	0.07	73	Below	High
	76	84	12	0.14	28	2	0.07	72	Below	High
	77	83	12	0.14	27	2	0.07	71	Below	High
	78	83	13	0.16	27	3	0.11	70	Below	High
	79	83	13	0.16	27	3	0.11	70	Below	High
	80	83	15	0.18	27	4	0.15	68	Below	High
	81	82	14	0.17	26	3	0.12	68	Below	High
	82	81	15	0.19	25	3	0.12	66	Below	High
	83	82	16	0.2	25	3	0.12	66	Below	High
	84	83	17	0.2	26	3	0.12	66	Below	High
	85	84	21	0.25	27	6	0.22	63	Below	High
	86	85	21	0.25	28	5	0.18	64	Below	High
	87	85	23	0.27	28	6	0.21	62	Below	High
	88	85	29	0.34	28	8	0.29	56	Above	Negligible
	89	85	31	0.36	28	8	0.29	54	Above	Negligible
	90	85	33	0.39	28	8	0.29	52	Above	Negligible
	91	85	39	0.46	28	12	0.43	46	Above	Negligible
	92	85	43	0.51	28	14	0.5	42	Above	Negligible
	93	85	44	0.52	28	14	0.5	41	Above	Negligible

	94	79	59	0.75	25	15	0.6	20	Above	Negligible
St John's House (offices+Cafe GF)	0	46	40	0.87	1	1	1	6	Above	Negligible
	1	47	40	0.85	2	2	1	7	Above	Negligible
	2	45	38	0.84	1	1	1	7	Above	Negligible
	3	43	36	0.84	0	0	0	7	Below	High
	4	43	36	0.84	0	0	0	7	Below	High
	5	42	36	0.86	0	0	0	6	Below	High
	6	42	37	0.88	0	0	0	5	Below	High
	7	45	37	0.82	2	1	0.5	8	Below	High
	8	49	41	0.84	3	2	0.67	8	Below	Medium
	9	49	41	0.84	3	2	0.67	8	Below	Medium
	10	51	43	0.84	3	2	0.67	8	Below	Medium
	11	52	43	0.83	3	1	0.33	9	Below	High
	12	61	52	0.85	4	3	0.75	9	Below	Low
	13	60	50	0.83	3	2	0.67	10	Below	Medium
	14	61	50	0.82	4	2	0.5	11	Below	High
	15	58	46	0.79	3	1	0.33	12	Below	High
	16	58	46	0.79	3	1	0.33	12	Below	High
	17	58	47	0.81	3	1	0.33	11	Below	High
	18	58	48	0.83	3	1	0.33	10	Below	High
	19	55	44	0.8	8	4	0.5	11	Below	High
	20	56	46	0.82	6	3	0.5	10	Below	High
	21	57	47	0.82	7	4	0.57	10	Below	High
	22	59	49	0.83	8	5	0.62	10	Above	Negligible
	23	62	50	0.81	10	5	0.5	12	Above	Negligible
	24	71	60	0.85	12	9	0.75	11	Above	Negligible
	25	70	58	0.83	11	8	0.73	12	Above	Negligible

	26	70	58	0.83	11	8	0.73	12	Above	Negligible
	27	69	56	0.81	10	7	0.7	13	Above	Negligible
	28	69	56	0.81	10	7	0.7	13	Above	Negligible
	29	69	56	0.81	10	6	0.6	13	Above	Negligible
	30	69	56	0.81	10	5	0.5	13	Above	Negligible
	31	64	50	0.78	17	10	0.59	14	Above	Negligible
	32	69	55	0.8	19	12	0.63	14	Above	Negligible
	33	70	55	0.79	19	11	0.58	15	Above	Negligible
	34	71	56	0.79	19	11	0.58	15	Above	Negligible
	35	74	59	0.8	20	12	0.6	15	Above	Negligible
	36	84	69	0.82	25	18	0.72	15	Above	Negligible
	37	84	69	0.82	25	18	0.72	15	Above	Negligible
	38	84	68	0.81	25	18	0.72	16	Above	Negligible
	39	84	66	0.79	25	17	0.68	18	Above	Negligible
	40	84	66	0.79	25	17	0.68	18	Above	Negligible
	41	84	67	0.8	25	17	0.68	17	Above	Negligible
	42	84	67	0.8	25	16	0.64	17	Above	Negligible
	43	72	59	0.82	25	19	0.76	13	Above	Negligible
	44	75	61	0.81	25	18	0.72	14	Above	Negligible
	45	76	62	0.82	25	18	0.72	14	Above	Negligible
	46	77	62	0.81	25	17	0.68	15	Above	Negligible

	47	79	64	0.81	25	17	0.68	15	Above	Negligible
	48	88	73	0.83	29	21	0.72	15	Above	Negligible
	49	88	72	0.82	29	21	0.72	16	Above	Negligible
	50	87	70	0.8	28	20	0.71	17	Above	Negligible
	51	87	69	0.79	28	20	0.71	18	Above	Negligible
	52	87	69	0.79	28	20	0.71	18	Above	Negligible
	53	86	69	0.8	27	19	0.7	17	Above	Negligible
	54	86	69	0.8	27	18	0.67	17	Above	Negligible
	55	75	62	0.83	28	22	0.79	13	Above	Negligible
	56	78	65	0.83	28	22	0.79	13	Above	Negligible
	57	79	66	0.84	28	22	0.79	13	Above	Negligible
	58	80	67	0.84	28	22	0.79	13	Above	Negligible
	59	81	67	0.83	27	20	0.74	14	Above	Negligible
	60	88	73	0.83	29	21	0.72	15	Above	Negligible
	61	88	72	0.82	29	21	0.72	16	Above	Negligible
	62	88	71	0.81	29	21	0.72	17	Above	Negligible
	63	88	70	0.8	29	21	0.72	18	Above	Negligible
	64	88	70	0.8	29	21	0.72	18	Above	Negligible
	65	88	70	0.8	29	20	0.69	18	Above	Negligible
	66	88	70	0.8	29	19	0.66	18	Above	Negligible
	67	76	63	0.83	29	23	0.79	13	Above	Negligible

	68	79	66	0.84	29	23	0.79	13	Above	Negligible
	69	79	66	0.84	28	22	0.79	13	Above	Negligible
	70	81	68	0.84	28	22	0.79	13	Above	Negligible
	71	82	69	0.84	28	22	0.79	13	Above	Negligible
Sovereign House (offices)	0	25	17	0.68	5	3	0.6	8	Below	Medium
	1	26	18	0.69	5	3	0.6	8	Below	Medium
	2	30	22	0.73	6	3	0.5	8	Below	High
	3	30	21	0.7	6	3	0.5	9	Below	High
	4	27	17	0.63	5	1	0.2	10	Below	High
	5	24	18	0.75	3	1	0.33	6	Below	High
	6	52	41	0.79	5	2	0.4	11	Below	High
	7	58	47	0.81	7	3	0.43	11	Below	High
	8	56	46	0.82	6	2	0.33	10	Below	High
	9	30	20	0.67	8	4	0.5	10	Below	High
	10	29	21	0.72	6	4	0.67	8	Below	Medium
	11	35	27	0.77	10	7	0.7	8	Above	Negligible
	12	33	24	0.73	9	6	0.67	9	Below	Medium
	13	31	20	0.65	9	4	0.44	11	Below	High
	14	28	21	0.75	7	4	0.57	7	Below	High
	15	49	36	0.73	6	1	0.17	13	Below	High
	16	52	38	0.73	7	1	0.14	14	Below	High
	17	50	34	0.68	8	1	0.12	16	Below	High
	18	64	48	0.75	13	5	0.38	16	Above	Negligible
	19	70	55	0.79	15	7	0.47	15	Above	Negligible
	20	69	55	0.8	15	7	0.47	14	Above	Negligible
	21	39	28	0.72	12	7	0.58	11	Above	Negligible

	22	39	29	0.74	11	7	0.64	10	Above	Negligible
	23	38	29	0.76	11	7	0.64	9	Above	Negligible
	24	38	28	0.74	11	7	0.64	10	Above	Negligible
	25	36	25	0.69	10	5	0.5	11	Above	Negligible
	26	32	23	0.72	9	5	0.56	9	Below	High
	27	63	47	0.75	12	4	0.33	16	Below	High
	28	64	48	0.75	12	4	0.33	16	Below	High
	29	64	47	0.73	12	4	0.33	17	Below	High
	30	74	55	0.74	22	11	0.5	19	Above	Negligible
	31	77	61	0.79	21	12	0.57	16	Above	Negligible
	32	77	63	0.82	21	13	0.62	14	Above	Negligible
	33	45	34	0.76	14	9	0.64	11	Above	Negligible
	34	47	37	0.79	14	10	0.71	10	Above	Negligible
	35	53	43	0.81	16	11	0.69	10	Above	Negligible
	36	52	41	0.79	15	10	0.67	11	Above	Negligible
	37	44	31	0.7	13	6	0.46	13	Above	Negligible
	38	36	26	0.72	10	6	0.6	10	Above	Negligible
	39	76	57	0.75	24	13	0.54	19	Above	Negligible
	40	80	64	0.8	24	15	0.62	16	Above	Negligible
	41	80	66	0.82	24	16	0.67	14	Above	Negligible
	42	51	39	0.76	18	12	0.67	12	Above	Negligible
	43	56	44	0.79	19	13	0.68	12	Above	Negligible
	44	64	52	0.81	21	14	0.67	12	Above	Negligible

	45	66	54	0.82	21	15	0.71	12	Above	Negligible
	46	64	51	0.8	18	11	0.61	13	Above	Negligible
	47	51	38	0.75	15	8	0.53	13	Above	Negligible
	48	70	54	0.77	15	7	0.47	16	Above	Negligible
	49	73	56	0.77	15	6	0.4	17	Above	Negligible
	50	72	54	0.75	14	5	0.36	18	Above	Negligible
	51	80	63	0.79	28	19	0.68	17	Above	Negligible
	52	83	67	0.81	27	18	0.67	16	Above	Negligible
	53	65	54	0.83	22	17	0.77	11	Above	Negligible
	54	73	62	0.85	26	20	0.77	11	Above	Negligible
	55	76	64	0.84	27	21	0.78	12	Above	Negligible
	56	78	65	0.83	26	19	0.73	13	Above	Negligible
	57	78	65	0.83	25	18	0.72	13	Above	Negligible
The Rising Sun (pub)	0	38	26	0.68	2	0	0	12	Below	High
	1	44	31	0.7	4	0	0	13	Below	High
	2	45	32	0.71	7	1	0.14	13	Below	High
Queens Court (offices)	0	18	11	0.61	1	0	0	7	Below	High
	1	21	13	0.62	3	0	0	8	Below	High
	2	23	19	0.83	2	0	0	4	Above	Negligible
	3	25	20	0.8	2	0	0	5	Below	High
	4	19	16	0.84	2	1	0.5	3	Above	Negligible
	5	19	15	0.79	2	1	0.5	4	Above	Negligible
	6	37	27	0.73	7	3	0.43	10	Below	High
	7	36	27	0.75	7	3	0.43	9	Below	High

	8	31	27	0.87	3	3	1	4	Above	Negligible
	9	30	24	0.8	3	2	0.67	6	Below	Medium
	10	23	18	0.78	2	1	0.5	5	Below	High
	11	24	18	0.75	2	1	0.5	6	Below	High
	12	46	35	0.76	8	4	0.5	11	Below	High
	13	46	37	0.8	8	4	0.5	9	Below	High
	14	39	34	0.87	3	3	1	5	Above	Negligible
	15	37	30	0.81	3	2	0.67	7	Below	Medium
	16	32	26	0.81	2	1	0.5	6	Below	High
	17	31	24	0.77	2	1	0.5	7	Below	High
	18	61	50	0.82	11	7	0.64	11	Above	Negligible
	19	60	50	0.83	11	7	0.64	10	Above	Negligible
	20	54	48	0.89	5	5	1	6	Above	Negligible
	21	53	46	0.87	5	5	1	7	Above	Negligible
	22	42	36	0.86	3	3	1	6	Above	Negligible
	23	38	31	0.82	3	3	1	7	Above	Negligible
	24	76	63	0.83	18	12	0.67	13	Above	Negligible
	25	76	64	0.84	18	12	0.67	12	Above	Negligible
	26	73	65	0.89	15	13	0.87	8	Above	Negligible
	27	71	62	0.87	13	11	0.85	9	Above	Negligible
	28	64	54	0.84	11	7	0.64	10	Above	Negligible
	29	52	42	0.81	9	6	0.67	10	Above	Negligible
Alexandra Buildings (Offices + Commercial GL)	0	23	23	1	0	0	0	0	Above	Negligible
	1	22	22	1	0	0	0	0	Above	Negligible

	2	21	21	1	0	0	0	0	Above	Negligible
	3	20	20	1	0	0	0	0	Above	Negligible
	4	19	19	1	0	0	0	0	Above	Negligible
	5	18	18	1	0	0	0	0	Above	Negligible
	6	18	18	1	0	0	0	0	Above	Negligible
	7	18	18	1	0	0	0	0	Above	Negligible
	8	17	17	1	0	0	0	0	Above	Negligible
	9	17	17	1	0	0	0	0	Above	Negligible
	10	28	27	0.96	0	0	0	1	Above	Negligible
	11	29	28	0.97	0	0	0	1	Above	Negligible
	12	28	27	0.96	0	0	0	1	Above	Negligible
	13	27	26	0.96	0	0	0	1	Above	Negligible
	14	28	27	0.96	0	0	0	1	Above	Negligible
	15	27	27	1	0	0	0	0	Above	Negligible
	16	27	27	1	0	0	0	0	Above	Negligible
	17	29	28	0.97	0	0	0	1	Above	Negligible
	18	28	27	0.96	0	0	0	1	Above	Negligible
	19	28	27	0.96	0	0	0	1	Above	Negligible
	20	41	38	0.93	1	1	1	3	Above	Negligible
	21	41	38	0.93	1	1	1	3	Above	Negligible
	22	42	39	0.93	1	1	1	3	Above	Negligible

	23	43	39	0.91	1	1	1	4	Above	Negligible
	24	42	38	0.9	1	1	1	4	Above	Negligible
	25	41	39	0.95	1	1	1	2	Above	Negligible
	26	42	40	0.95	1	1	1	2	Above	Negligible
	27	43	39	0.91	1	1	1	4	Above	Negligible
	28	41	37	0.9	1	1	1	4	Above	Negligible
	29	42	37	0.88	1	1	1	5	Above	Negligible
	30	50	44	0.88	3	3	1	6	Above	Negligible
	31	52	47	0.9	4	4	1	5	Above	Negligible
	32	52	47	0.9	4	4	1	5	Above	Negligible
	33	53	48	0.91	4	4	1	5	Above	Negligible
	34	54	49	0.91	4	4	1	5	Above	Negligible
	35	54	50	0.93	4	4	1	4	Above	Negligible
	36	55	50	0.91	4	4	1	5	Above	Negligible
	37	55	50	0.91	4	4	1	5	Above	Negligible
	38	54	48	0.89	4	4	1	6	Above	Negligible
	39	57	48	0.84	5	5	1	9	Above	Negligible
Queens House (Offices+Commercial)	0	12	12	1	0	0	0	0	Above	Negligible
	1	23	22	0.96	0	0	0	1	Above	Negligible
	2	18	18	1	0	0	0	0	Above	Negligible
	3	31	27	0.87	0	0	0	4	Above	Negligible

	4	29	27	0.93	0	0	0	2	Above	Negligible
	5	43	37	0.86	1	1	1	6	Above	Negligible
	6	41	37	0.9	1	1	1	4	Above	Negligible
	7	55	47	0.85	4	4	1	8	Above	Negligible
	8	55	48	0.87	3	3	1	7	Above	Negligible
	9	67	54	0.81	12	8	0.67	13	Above	Negligible
	10	82	59	0.72	26	12	0.46	23	Above	Negligible
	11	82	59	0.72	26	12	0.46	23	Above	Negligible
	12	82	59	0.72	26	12	0.46	23	Above	Negligible
	13	82	58	0.71	26	11	0.42	24	Above	Negligible
	14	82	58	0.71	26	12	0.46	24	Above	Negligible
	15	81	58	0.72	25	11	0.44	23	Above	Negligible
Heron House (Manchester City Council, Restaurants, maybe some residential)	0	17	17	1	0	0	0	0	Above	Negligible
	1	18	18	1	1	1	1	0	Above	Negligible
	2	21	21	1	0	0	0	0	Above	Negligible
	3	21	21	1	0	0	0	0	Above	Negligible
	4	25	24	0.96	0	0	0	1	Above	Negligible
	5	25	24	0.96	0	0	0	1	Above	Negligible
	6	26	25	0.96	0	0	0	1	Above	Negligible
	7	26	25	0.96	0	0	0	1	Above	Negligible
	8	27	26	0.96	0	0	0	1	Above	Negligible

	9	29	27	0.93	1	1	1	2	Above	Negligible
	10	37	35	0.95	0	0	0	2	Above	Negligible
	11	39	37	0.95	1	1	1	2	Above	Negligible
	12	37	35	0.95	1	1	1	2	Above	Negligible
	13	40	38	0.95	0	0	0	2	Above	Negligible
	14	40	38	0.95	1	1	1	2	Above	Negligible
	15	30	27	0.9	0	0	0	3	Above	Negligible
	16	30	27	0.9	0	0	0	3	Above	Negligible
	17	32	28	0.88	0	0	0	4	Above	Negligible
	18	33	29	0.88	1	1	1	4	Above	Negligible
	19	34	30	0.88	1	1	1	4	Above	Negligible
	20	34	30	0.88	1	1	1	4	Above	Negligible
	21	36	31	0.86	1	1	1	5	Above	Negligible
	22	38	33	0.87	1	1	1	5	Above	Negligible
	23	38	33	0.87	1	1	1	5	Above	Negligible
	24	38	33	0.87	1	1	1	5	Above	Negligible
	25	38	33	0.87	1	1	1	5	Above	Negligible
	26	38	33	0.87	1	1	1	5	Above	Negligible
	27	39	34	0.87	0	0	0	5	Below	High
	28	41	37	0.9	2	2	1	4	Above	Negligible
	29	42	38	0.9	2	2	1	4	Above	Negligible
	30	42	38	0.9	1	1	1	4	Above	Negligible

	31	44	40	0.91	2	2	1	4	Above	Negligible
	32	46	43	0.93	2	2	1	3	Above	Negligible
	33	46	43	0.93	2	2	1	3	Above	Negligible
	34	49	46	0.94	2	2	1	3	Above	Negligible
	35	52	49	0.94	3	3	1	3	Above	Negligible
	36	44	40	0.91	1	1	1	4	Above	Negligible
	37	45	41	0.91	1	1	1	4	Above	Negligible
	38	46	40	0.87	1	1	1	6	Above	Negligible
	39	46	39	0.85	1	1	1	7	Above	Negligible
	40	48	41	0.85	1	1	1	7	Above	Negligible
	41	49	41	0.84	1	1	1	8	Above	Negligible
	42	49	42	0.86	1	1	1	7	Above	Negligible
	43	49	42	0.86	1	1	1	7	Above	Negligible
	44	49	42	0.86	1	1	1	7	Above	Negligible
	45	50	43	0.86	2	2	1	7	Above	Negligible
	46	50	43	0.86	2	2	1	7	Above	Negligible
	47	50	43	0.86	2	2	1	7	Above	Negligible
	48	51	45	0.88	2	2	1	6	Above	Negligible
	49	54	48	0.89	5	5	1	6	Above	Negligible
	50	55	50	0.91	4	4	1	5	Above	Negligible
	51	54	49	0.91	3	3	1	5	Above	Negligible

	52	56	51	0.91	5	5	1	5	Above	Negligible
	53	56	52	0.93	5	5	1	4	Above	Negligible
	54	56	52	0.93	4	4	1	4	Above	Negligible
	55	59	54	0.92	5	5	1	5	Above	Negligible
	56	61	56	0.92	6	6	1	5	Above	Negligible
	57	59	52	0.88	4	4	1	7	Above	Negligible
	58	59	52	0.88	4	4	1	7	Above	Negligible
	59	60	52	0.87	4	4	1	8	Above	Negligible
	60	60	51	0.85	4	4	1	9	Above	Negligible
	61	61	53	0.87	4	4	1	8	Above	Negligible
	62	61	52	0.85	4	4	1	9	Above	Negligible
	63	61	53	0.87	4	4	1	8	Above	Negligible
	64	62	54	0.87	5	5	1	8	Above	Negligible
	65	62	54	0.87	5	5	1	8	Above	Negligible
	66	62	54	0.87	5	5	1	8	Above	Negligible
	67	63	55	0.87	6	6	1	8	Above	Negligible
	68	64	56	0.88	7	7	1	8	Above	Negligible
	69	65	57	0.88	7	7	1	8	Above	Negligible
	70	66	58	0.88	8	8	1	8	Above	Negligible
	71	66	58	0.88	8	8	1	8	Above	Negligible
	72	66	58	0.88	8	8	1	8	Above	Negligible

	73	68	60	0.88	10	10	1	8	Above	Negligible
	74	68	61	0.9	10	10	1	7	Above	Negligible
	75	69	63	0.91	11	11	1	6	Above	Negligible
	76	71	65	0.92	13	13	1	6	Above	Negligible
	77	70	64	0.91	12	12	1	6	Above	Negligible
	78	73	60	0.82	14	9	0.64	13	Above	Negligible
	79	73	61	0.84	14	10	0.71	12	Above	Negligible
	80	73	60	0.82	14	10	0.71	13	Above	Negligible
	81	73	58	0.79	14	9	0.64	15	Above	Negligible
	82	74	60	0.81	15	10	0.67	14	Above	Negligible
	83	74	60	0.81	15	10	0.67	14	Above	Negligible
	84	75	61	0.81	16	11	0.69	14	Above	Negligible
	85	75	61	0.81	16	11	0.69	14	Above	Negligible
	86	75	60	0.8	16	11	0.69	15	Above	Negligible
	87	76	61	0.8	17	12	0.71	15	Above	Negligible
	88	76	61	0.8	17	12	0.71	15	Above	Negligible
	89	76	62	0.82	17	13	0.76	14	Above	Negligible
	90	76	63	0.83	17	13	0.76	13	Above	Negligible
	91	77	65	0.84	18	15	0.83	12	Above	Negligible
	92	77	65	0.84	18	15	0.83	12	Above	Negligible
	93	77	65	0.84	18	15	0.83	12	Above	Negligible

	94	78	66	0.85	19	16	0.84	12	Above	Negligible
	95	79	68	0.86	20	17	0.85	11	Above	Negligible
	96	79	69	0.87	20	17	0.85	10	Above	Negligible
	97	81	71	0.88	22	19	0.86	10	Above	Negligible
	98	81	72	0.89	22	20	0.91	9	Above	Negligible
	99	85	66	0.78	26	15	0.58	19	Above	Negligible
	100	85	66	0.78	26	15	0.58	19	Above	Negligible
	101	85	66	0.78	26	16	0.62	19	Above	Negligible
	102	85	65	0.76	26	16	0.62	20	Above	Negligible
	103	85	66	0.78	26	16	0.62	19	Above	Negligible
	104	87	66	0.76	28	16	0.57	21	Above	Negligible
	105	87	66	0.76	28	16	0.57	21	Above	Negligible
	106	87	66	0.76	28	16	0.57	21	Above	Negligible
	107	87	66	0.76	28	17	0.61	21	Above	Negligible
	108	86	67	0.78	27	18	0.67	19	Above	Negligible
	109	86	67	0.78	27	18	0.67	19	Above	Negligible
	110	86	69	0.8	27	19	0.7	17	Above	Negligible
	111	86	69	0.8	27	19	0.7	17	Above	Negligible
	112	86	69	0.8	27	19	0.7	17	Above	Negligible
	113	86	69	0.8	27	19	0.7	17	Above	Negligible
	114	86	69	0.8	27	19	0.7	17	Above	Negligible

	115	86	69	0.8	27	19	0.7	17	Above	Negligible
	116	86	71	0.83	27	20	0.74	15	Above	Negligible
	117	86	73	0.85	27	21	0.78	13	Above	Negligible
	118	86	74	0.86	27	22	0.81	12	Above	Negligible
	119	86	74	0.86	27	22	0.81	12	Above	Negligible
Brazenose House (Commercial+Offices)	0	48	42	0.88	9	6	0.67	6	Above	Negligible
	1	53	50	0.94	10	9	0.9	3	Above	Negligible
	2	54	52	0.96	11	10	0.91	2	Above	Negligible
	3	48	42	0.88	13	10	0.77	6	Above	Negligible
	4	58	54	0.93	10	9	0.9	4	Above	Negligible
	5	55	52	0.95	7	6	0.86	3	Above	Negligible
	6	55	53	0.96	8	7	0.88	2	Above	Negligible
	7	45	43	0.96	6	5	0.83	2	Above	Negligible
	8	44	41	0.93	4	3	0.75	3	Above	Negligible
	9	35	33	0.94	2	2	1	2	Above	Negligible
	10	30	30	1	2	2	1	0	Above	Negligible
	11	52	45	0.87	14	10	0.71	7	Above	Negligible
	12	52	45	0.87	14	10	0.71	7	Above	Negligible
	13	54	50	0.93	14	12	0.86	4	Above	Negligible
	14	54	51	0.94	14	13	0.93	3	Above	Negligible
	15	55	52	0.95	14	13	0.93	3	Above	Negligible

	16	56	53	0.95	14	13	0.93	3	Above	Negligible
	17	58	55	0.95	15	14	0.93	3	Above	Negligible
	18	57	54	0.95	14	13	0.93	3	Above	Negligible
	19	57	54	0.95	14	13	0.93	3	Above	Negligible
	20	56	52	0.93	14	13	0.93	4	Above	Negligible
	21	57	53	0.93	15	14	0.93	4	Above	Negligible
	22	59	56	0.95	15	14	0.93	3	Above	Negligible
	23	57	54	0.95	13	12	0.92	3	Above	Negligible
	24	56	54	0.96	13	12	0.92	2	Above	Negligible
	25	58	56	0.97	13	12	0.92	2	Above	Negligible
	26	51	47	0.92	14	12	0.86	4	Above	Negligible
	27	45	41	0.91	13	12	0.92	4	Above	Negligible
	28	61	57	0.93	13	12	0.92	4	Above	Negligible
	29	61	57	0.93	13	12	0.92	4	Above	Negligible
	30	61	58	0.95	13	12	0.92	3	Above	Negligible
	31	61	56	0.92	12	10	0.83	5	Above	Negligible
	32	62	57	0.92	12	10	0.83	5	Above	Negligible
	33	62	57	0.92	12	10	0.83	5	Above	Negligible
	34	62	57	0.92	12	10	0.83	5	Above	Negligible
	35	59	55	0.93	10	8	0.8	4	Above	Negligible
	36	59	54	0.92	11	8	0.73	5	Above	Negligible

	37	61	56	0.92	11	8	0.73	5	Above	Negligible
	38	61	56	0.92	11	8	0.73	5	Above	Negligible
	39	61	56	0.92	11	8	0.73	5	Above	Negligible
	40	61	58	0.95	11	9	0.82	3	Above	Negligible
	41	59	56	0.95	11	9	0.82	3	Above	Negligible
	42	58	55	0.95	10	8	0.8	3	Above	Negligible
	43	59	57	0.97	10	9	0.9	2	Above	Negligible
	44	59	57	0.97	10	9	0.9	2	Above	Negligible
	45	58	56	0.97	9	8	0.89	2	Above	Negligible
	46	51	49	0.96	9	8	0.89	2	Above	Negligible
	47	45	43	0.96	5	4	0.8	2	Above	Negligible
	48	52	49	0.94	5	4	0.8	3	Above	Negligible
	49	49	46	0.94	5	4	0.8	3	Above	Negligible
	50	46	43	0.93	4	3	0.75	3	Above	Negligible
	51	46	43	0.93	4	3	0.75	3	Above	Negligible
	52	44	41	0.93	3	2	0.67	3	Above	Negligible
	53	42	39	0.93	3	2	0.67	3	Above	Negligible
	54	43	40	0.93	3	2	0.67	3	Above	Negligible
	55	43	40	0.93	3	2	0.67	3	Above	Negligible
	56	40	40	1	2	2	1	0	Above	Negligible
	57	41	39	0.95	2	1	0.5	2	Above	Negligible

	58	39	39	1	1	1	1	0	Above	Negligible
	59	39	39	1	2	2	1	0	Above	Negligible
	60	39	39	1	2	2	1	0	Above	Negligible
	61	38	38	1	2	2	1	0	Above	Negligible
	62	35	35	1	1	1	1	0	Above	Negligible
	63	55	45	0.82	17	10	0.59	10	Above	Negligible
	64	55	45	0.82	17	10	0.59	10	Above	Negligible
	65	58	51	0.88	17	12	0.71	7	Above	Negligible
	66	60	54	0.9	19	15	0.79	6	Above	Negligible
	67	60	55	0.92	19	16	0.84	5	Above	Negligible
	68	62	57	0.92	19	16	0.84	5	Above	Negligible
	69	63	58	0.92	20	17	0.85	5	Above	Negligible
	70	64	59	0.92	20	17	0.85	5	Above	Negligible
	71	63	58	0.92	20	17	0.85	5	Above	Negligible
	72	62	56	0.9	20	17	0.85	6	Above	Negligible
	73	64	58	0.91	20	17	0.85	6	Above	Negligible
	74	63	59	0.94	19	17	0.89	4	Above	Negligible
	75	63	59	0.94	19	17	0.89	4	Above	Negligible
	76	63	60	0.95	19	17	0.89	3	Above	Negligible
	77	64	62	0.97	19	18	0.95	2	Above	Negligible
	78	58	55	0.95	20	18	0.9	3	Above	Negligible

	79	51	47	0.92	17	15	0.88	4	Above	Negligible
	80	66	61	0.92	18	15	0.83	5	Above	Negligible
	81	67	62	0.93	18	15	0.83	5	Above	Negligible
	82	67	62	0.93	18	15	0.83	5	Above	Negligible
	83	68	61	0.9	18	14	0.78	7	Above	Negligible
	84	69	61	0.88	19	14	0.74	8	Above	Negligible
	85	68	60	0.88	18	13	0.72	8	Above	Negligible
	86	68	61	0.9	17	13	0.76	7	Above	Negligible
	87	69	62	0.9	18	13	0.72	7	Above	Negligible
	88	69	62	0.9	18	13	0.72	7	Above	Negligible
	89	69	63	0.91	17	13	0.76	6	Above	Negligible
	90	69	63	0.91	17	13	0.76	6	Above	Negligible
	91	69	64	0.93	16	12	0.75	5	Above	Negligible
	92	69	65	0.94	16	13	0.81	4	Above	Negligible
	93	68	65	0.96	15	13	0.87	3	Above	Negligible
	94	68	65	0.96	15	13	0.87	3	Above	Negligible
	95	67	65	0.97	14	13	0.93	2	Above	Negligible
	96	67	65	0.97	13	12	0.92	2	Above	Negligible
	97	68	65	0.96	14	12	0.86	3	Above	Negligible
	98	56	54	0.96	10	9	0.9	2	Above	Negligible
	99	51	48	0.94	8	6	0.75	3	Above	Negligible

	100	58	55	0.95	7	6	0.86	3	Above	Negligible
	101	59	56	0.95	7	6	0.86	3	Above	Negligible
	102	57	54	0.95	6	5	0.83	3	Above	Negligible
	103	57	54	0.95	7	6	0.86	3	Above	Negligible
	104	55	52	0.95	6	5	0.83	3	Above	Negligible
	105	53	50	0.94	5	4	0.8	3	Above	Negligible
	106	52	49	0.94	5	4	0.8	3	Above	Negligible
	107	52	49	0.94	5	4	0.8	3	Above	Negligible
	108	50	49	0.98	4	4	1	1	Above	Negligible
	109	49	47	0.96	4	3	0.75	2	Above	Negligible
	110	46	46	1	3	3	1	0	Above	Negligible
	111	45	45	1	2	2	1	0	Above	Negligible
	112	45	45	1	2	2	1	0	Above	Negligible
	113	45	45	1	2	2	1	0	Above	Negligible
	114	42	42	1	1	1	1	0	Above	Negligible
	115	55	46	0.84	17	11	0.65	9	Above	Negligible
	116	55	46	0.84	17	11	0.65	9	Above	Negligible
	117	58	52	0.9	17	13	0.76	6	Above	Negligible
	118	60	55	0.92	19	16	0.84	5	Above	Negligible
	119	62	57	0.92	20	17	0.85	5	Above	Negligible
	120	62	58	0.94	19	17	0.89	4	Above	Negligible

	121	63	59	0.94	20	18	0.9	4	Above	Negligible
	122	64	60	0.94	20	18	0.9	4	Above	Negligible
	123	64	60	0.94	20	18	0.9	4	Above	Negligible
	124	64	59	0.92	20	18	0.9	5	Above	Negligible
	125	65	60	0.92	21	19	0.9	5	Above	Negligible
	126	66	62	0.94	21	19	0.9	4	Above	Negligible
	127	66	62	0.94	21	19	0.9	4	Above	Negligible
	128	65	62	0.95	21	19	0.9	3	Above	Negligible
	129	68	65	0.96	22	20	0.91	3	Above	Negligible
	130	63	59	0.94	23	20	0.87	4	Above	Negligible
	131	55	49	0.89	21	17	0.81	6	Above	Negligible
	132	71	65	0.92	22	18	0.82	6	Above	Negligible
	133	71	65	0.92	22	18	0.82	6	Above	Negligible
	134	72	66	0.92	23	19	0.83	6	Above	Negligible
	135	74	66	0.89	23	18	0.78	8	Above	Negligible
	136	73	65	0.89	22	17	0.77	8	Above	Negligible
	137	73	65	0.89	22	17	0.77	8	Above	Negligible
	138	74	66	0.89	23	18	0.78	8	Above	Negligible
	139	75	68	0.91	24	19	0.79	7	Above	Negligible
	140	75	68	0.91	22	17	0.77	7	Above	Negligible
	141	75	68	0.91	22	17	0.77	7	Above	Negligible

	142	75	69	0.92	21	16	0.76	6	Above	Negligible
	143	74	68	0.92	20	15	0.75	6	Above	Negligible
	144	74	69	0.93	19	15	0.79	5	Above	Negligible
	145	74	70	0.95	19	16	0.84	4	Above	Negligible
	146	74	70	0.95	19	16	0.84	4	Above	Negligible
	147	74	71	0.96	19	17	0.89	3	Above	Negligible
	148	73	70	0.96	18	16	0.89	3	Above	Negligible
	149	73	70	0.96	18	16	0.89	3	Above	Negligible
	150	63	60	0.95	17	15	0.88	3	Above	Negligible
	151	60	56	0.93	15	12	0.8	4	Above	Negligible
	152	66	63	0.95	11	10	0.91	3	Above	Negligible
	153	66	63	0.95	11	10	0.91	3	Above	Negligible
	154	65	62	0.95	10	9	0.9	3	Above	Negligible
	155	66	63	0.95	10	9	0.9	3	Above	Negligible
	156	62	59	0.95	8	7	0.88	3	Above	Negligible
	157	60	56	0.93	7	5	0.71	4	Above	Negligible
	158	60	56	0.93	7	5	0.71	4	Above	Negligible
	159	60	56	0.93	7	5	0.71	4	Above	Negligible
	160	57	56	0.98	5	5	1	1	Above	Negligible
	161	56	53	0.95	5	4	0.8	3	Above	Negligible
	162	55	53	0.96	4	4	1	2	Above	Negligible

	163	56	54	0.96	3	3	1	2	Above	Negligible
	164	57	55	0.96	3	3	1	2	Above	Negligible
	165	57	55	0.96	3	3	1	2	Above	Negligible
	166	55	53	0.96	2	2	1	2	Above	Negligible
	167	56	47	0.84	18	12	0.67	9	Above	Negligible
	168	57	48	0.84	18	12	0.67	9	Above	Negligible
	169	59	53	0.9	18	14	0.78	6	Above	Negligible
	170	61	56	0.92	20	17	0.85	5	Above	Negligible
	171	64	59	0.92	21	18	0.86	5	Above	Negligible
	172	63	59	0.94	20	18	0.9	4	Above	Negligible
	173	65	61	0.94	21	19	0.9	4	Above	Negligible
	174	66	62	0.94	21	19	0.9	4	Above	Negligible
	175	66	62	0.94	21	19	0.9	4	Above	Negligible
	176	65	60	0.92	21	19	0.9	5	Above	Negligible
	177	67	63	0.94	22	20	0.91	4	Above	Negligible
	178	68	64	0.94	23	21	0.91	4	Above	Negligible
	179	70	66	0.94	23	21	0.91	4	Above	Negligible
	180	69	66	0.96	23	21	0.91	3	Above	Negligible
	181	72	69	0.96	24	22	0.92	3	Above	Negligible
	182	64	61	0.95	24	22	0.92	3	Above	Negligible
	183	58	53	0.91	22	19	0.86	5	Above	Negligible

	184	74	69	0.93	24	21	0.88	5	Above	Negligible
	185	74	69	0.93	24	21	0.88	5	Above	Negligible
	186	75	70	0.93	25	22	0.88	5	Above	Negligible
	187	77	70	0.91	26	22	0.85	7	Above	Negligible
	188	79	72	0.91	26	22	0.85	7	Above	Negligible
	189	79	72	0.91	26	22	0.85	7	Above	Negligible
	190	81	74	0.91	27	23	0.85	7	Above	Negligible
	191	81	75	0.93	27	23	0.85	6	Above	Negligible
	192	82	77	0.94	27	23	0.85	5	Above	Negligible
	193	81	76	0.94	26	22	0.85	5	Above	Negligible
	194	80	74	0.92	25	20	0.8	6	Above	Negligible
	195	80	74	0.92	25	20	0.8	6	Above	Negligible
	196	80	75	0.94	25	21	0.84	5	Above	Negligible
	197	79	75	0.95	24	21	0.88	4	Above	Negligible
	198	78	74	0.95	23	20	0.87	4	Above	Negligible
	199	79	76	0.96	23	21	0.91	3	Above	Negligible
	200	79	75	0.95	23	20	0.87	4	Above	Negligible
	201	79	75	0.95	23	20	0.87	4	Above	Negligible
	202	68	64	0.94	22	19	0.86	4	Above	Negligible
	203	66	61	0.92	21	17	0.81	5	Above	Negligible
	204	73	70	0.96	17	16	0.94	3	Above	Negligible

	205	73	70	0.96	17	16	0.94	3	Above	Negligible
	206	71	68	0.96	16	15	0.94	3	Above	Negligible
	207	72	69	0.96	16	15	0.94	3	Above	Negligible
	208	71	68	0.96	14	13	0.93	3	Above	Negligible
	209	70	67	0.96	12	11	0.92	3	Above	Negligible
	210	70	67	0.96	12	11	0.92	3	Above	Negligible
	211	69	66	0.96	12	11	0.92	3	Above	Negligible
	212	69	65	0.94	12	10	0.83	4	Above	Negligible
	213	68	63	0.93	11	9	0.82	5	Above	Negligible
	214	66	63	0.95	9	9	1	3	Above	Negligible
	215	65	62	0.95	8	8	1	3	Above	Negligible
	216	64	61	0.95	8	8	1	3	Above	Negligible
	217	64	61	0.95	8	8	1	3	Above	Negligible
	218	63	61	0.97	7	7	1	2	Above	Negligible
	219	57	49	0.86	19	14	0.74	8	Above	Negligible
	220	60	52	0.87	19	14	0.74	8	Above	Negligible
	221	61	56	0.92	19	16	0.84	5	Above	Negligible
	222	62	58	0.94	20	18	0.9	4	Above	Negligible
	223	64	60	0.94	21	19	0.9	4	Above	Negligible
	224	65	61	0.94	21	19	0.9	4	Above	Negligible
	225	67	63	0.94	22	20	0.91	4	Above	Negligible

	226	68	64	0.94	22	20	0.91	4	Above	Negligible
	227	69	65	0.94	22	20	0.91	4	Above	Negligible
	228	69	66	0.96	22	21	0.95	3	Above	Negligible
	229	72	69	0.96	23	22	0.96	3	Above	Negligible
	230	71	68	0.96	23	22	0.96	3	Above	Negligible
	231	73	70	0.96	23	22	0.96	3	Above	Negligible
	232	72	70	0.97	23	22	0.96	2	Above	Negligible
	233	73	71	0.97	24	23	0.96	2	Above	Negligible
	234	64	61	0.95	24	22	0.92	3	Above	Negligible
	235	61	57	0.93	23	20	0.87	4	Above	Negligible
	236	76	71	0.93	25	22	0.88	5	Above	Negligible
	237	77	72	0.94	25	22	0.88	5	Above	Negligible
	238	80	75	0.94	26	23	0.88	5	Above	Negligible
	239	81	74	0.91	27	23	0.85	7	Above	Negligible
	240	82	75	0.91	27	23	0.85	7	Above	Negligible
	241	82	75	0.91	27	23	0.85	7	Above	Negligible
	242	82	75	0.91	27	23	0.85	7	Above	Negligible
	243	82	77	0.94	27	23	0.85	5	Above	Negligible
	244	82	77	0.94	27	23	0.85	5	Above	Negligible
	245	82	77	0.94	27	23	0.85	5	Above	Negligible
	246	83	78	0.94	27	23	0.85	5	Above	Negligible

	247	83	78	0.94	27	23	0.85	5	Above	Negligible
	248	83	79	0.95	27	24	0.89	4	Above	Negligible
	249	83	80	0.96	27	25	0.93	3	Above	Negligible
	250	83	80	0.96	27	25	0.93	3	Above	Negligible
	251	83	81	0.98	27	26	0.96	2	Above	Negligible
	252	82	79	0.96	26	24	0.92	3	Above	Negligible
	253	82	79	0.96	26	24	0.92	3	Above	Negligible
	254	70	67	0.96	24	22	0.92	3	Above	Negligible
	255	70	67	0.96	23	20	0.87	3	Above	Negligible
	256	81	77	0.95	23	21	0.91	4	Above	Negligible
	257	80	76	0.95	22	20	0.91	4	Above	Negligible
	258	79	75	0.95	21	19	0.9	4	Above	Negligible
	259	80	76	0.95	21	19	0.9	4	Above	Negligible
	260	79	75	0.95	20	18	0.9	4	Above	Negligible
	261	78	74	0.95	19	17	0.89	4	Above	Negligible
	262	78	74	0.95	19	17	0.89	4	Above	Negligible
	263	77	73	0.95	18	16	0.89	4	Above	Negligible
	264	75	72	0.96	17	16	0.94	3	Above	Negligible
	265	75	70	0.93	17	15	0.88	5	Above	Negligible
	266	74	69	0.93	16	14	0.88	5	Above	Negligible
	267	72	67	0.93	15	13	0.87	5	Above	Negligible

	268	71	68	0.96	14	13	0.93	3	Above	Negligible
	269	71	68	0.96	14	13	0.93	3	Above	Negligible
	270	71	68	0.96	14	13	0.93	3	Above	Negligible
	271	61	53	0.87	19	14	0.74	8	Above	Negligible
	272	63	55	0.87	19	14	0.74	8	Above	Negligible
	273	64	59	0.92	19	16	0.84	5	Above	Negligible
	274	67	63	0.94	21	19	0.9	4	Above	Negligible
	275	69	65	0.94	22	20	0.91	4	Above	Negligible
	276	69	65	0.94	22	20	0.91	4	Above	Negligible
	277	71	67	0.94	23	21	0.91	4	Above	Negligible
	278	72	68	0.94	23	21	0.91	4	Above	Negligible
	279	73	69	0.95	23	21	0.91	4	Above	Negligible
	280	75	72	0.96	23	22	0.96	3	Above	Negligible
	281	77	74	0.96	24	23	0.96	3	Above	Negligible
	282	77	74	0.96	24	23	0.96	3	Above	Negligible
	283	77	74	0.96	24	23	0.96	3	Above	Negligible
	284	76	74	0.97	24	23	0.96	2	Above	Negligible
	285	77	75	0.97	25	24	0.96	2	Above	Negligible
	286	67	64	0.96	26	24	0.92	3	Above	Negligible
	287	64	60	0.94	24	21	0.88	4	Above	Negligible
	288	83	78	0.94	27	24	0.89	5	Above	Negligible

	289	83	78	0.94	27	24	0.89	5	Above	Negligible
	290	83	78	0.94	27	24	0.89	5	Above	Negligible
	291	84	77	0.92	28	24	0.86	7	Above	Negligible
	292	84	77	0.92	28	24	0.86	7	Above	Negligible
	293	84	77	0.92	28	24	0.86	7	Above	Negligible
	294	84	78	0.93	28	24	0.86	6	Above	Negligible
	295	84	79	0.94	28	24	0.86	5	Above	Negligible
	296	84	79	0.94	28	24	0.86	5	Above	Negligible
	297	84	79	0.94	28	24	0.86	5	Above	Negligible
	298	84	79	0.94	28	24	0.86	5	Above	Negligible
	299	84	79	0.94	28	24	0.86	5	Above	Negligible
	300	84	80	0.95	28	25	0.89	4	Above	Negligible
	301	84	81	0.96	28	26	0.93	3	Above	Negligible
	302	85	82	0.96	28	26	0.93	3	Above	Negligible
	303	86	84	0.98	28	27	0.96	2	Above	Negligible
	304	86	84	0.98	28	27	0.96	2	Above	Negligible
	305	86	84	0.98	28	27	0.96	2	Above	Negligible
	306	75	73	0.97	28	27	0.96	2	Above	Negligible
	307	74	72	0.97	27	25	0.93	2	Above	Negligible
	308	87	84	0.97	28	27	0.96	3	Above	Negligible
	309	87	83	0.95	28	26	0.93	4	Above	Negligible

	310	87	83	0.95	28	26	0.93	4	Above	Negligible
	311	87	83	0.95	28	26	0.93	4	Above	Negligible
	312	87	83	0.95	28	26	0.93	4	Above	Negligible
	313	87	83	0.95	28	26	0.93	4	Above	Negligible
	314	87	83	0.95	28	26	0.93	4	Above	Negligible
	315	87	83	0.95	28	26	0.93	4	Above	Negligible
	316	87	83	0.95	28	26	0.93	4	Above	Negligible
	317	87	82	0.94	28	25	0.89	5	Above	Negligible
	318	87	82	0.94	28	25	0.89	5	Above	Negligible
	319	86	82	0.95	27	25	0.93	4	Above	Negligible
	320	86	82	0.95	27	25	0.93	4	Above	Negligible
	321	84	80	0.95	25	23	0.92	4	Above	Negligible
	322	82	78	0.95	24	22	0.92	4	Above	Negligible
Centurion house (offices+Com)	0	19	19	1	1	1	1	0	Above	Negligible
	1	20	20	1	1	1	1	0	Above	Negligible
	2	24	24	1	1	1	1	0	Above	Negligible
	3	26	25	0.96	1	1	1	1	Above	Negligible
	4	30	29	0.97	1	1	1	1	Above	Negligible
	5	34	33	0.97	1	1	1	1	Above	Negligible
	6	36	34	0.94	1	1	1	2	Above	Negligible
	7	39	35	0.9	1	1	1	4	Above	Negligible

	8	29	29	1	3	3	1	0	Above	Negligible
	9	28	28	1	3	3	1	0	Above	Negligible
	10	32	32	1	3	3	1	0	Above	Negligible
	11	34	32	0.94	4	4	1	2	Above	Negligible
	12	40	37	0.92	4	4	1	3	Above	Negligible
	13	45	43	0.96	6	6	1	2	Above	Negligible
	14	49	44	0.9	7	6	0.86	5	Above	Negligible
	15	53	47	0.89	7	6	0.86	6	Above	Negligible
	16	37	36	0.97	5	5	1	1	Above	Negligible
	17	40	39	0.98	5	5	1	1	Above	Negligible
	18	43	42	0.98	5	5	1	1	Above	Negligible
	19	45	43	0.96	7	7	1	2	Above	Negligible
	20	53	48	0.91	11	9	0.82	5	Above	Negligible
	21	57	53	0.93	12	10	0.83	4	Above	Negligible
	22	64	57	0.89	15	11	0.73	7	Above	Negligible
	23	65	56	0.86	15	11	0.73	9	Above	Negligible
	24	51	50	0.98	7	7	1	1	Above	Negligible
	25	52	51	0.98	7	7	1	1	Above	Negligible
	26	58	57	0.98	11	11	1	1	Above	Negligible
	27	62	60	0.97	13	13	1	2	Above	Negligible
	28	71	64	0.9	19	15	0.79	7	Above	Negligible

	29	73	66	0.9	20	15	0.75	7	Above	Negligible
	30	74	65	0.88	21	15	0.71	9	Above	Negligible
	31	78	67	0.86	23	17	0.74	11	Above	Negligible
	32	65	62	0.95	9	8	0.89	3	Above	Negligible
	33	64	62	0.97	8	7	0.88	2	Above	Negligible
	34	70	68	0.97	12	12	1	2	Above	Negligible
	35	71	68	0.96	13	13	1	3	Above	Negligible
	36	76	69	0.91	19	15	0.79	7	Above	Negligible
	37	77	70	0.91	20	15	0.75	7	Above	Negligible
	38	81	73	0.9	24	19	0.79	8	Above	Negligible
	39	81	71	0.88	24	19	0.79	10	Above	Negligible
	40	75	72	0.96	16	15	0.94	3	Above	Negligible
	41	75	73	0.97	16	15	0.94	2	Above	Negligible
	42	77	74	0.96	18	17	0.94	3	Above	Negligible
	43	79	74	0.94	20	18	0.9	5	Above	Negligible
	44	83	76	0.92	24	20	0.83	7	Above	Negligible
	45	85	78	0.92	26	21	0.81	7	Above	Negligible
	46	85	77	0.91	26	21	0.81	8	Above	Negligible
	47	85	76	0.89	26	21	0.81	9	Above	Negligible
	48	88	84	0.95	29	27	0.93	4	Above	Negligible
	49	88	85	0.97	29	27	0.93	3	Above	Negligible

	50	88	84	0.95	29	27	0.93	4	Above	Negligible
	51	88	81	0.92	29	25	0.86	7	Above	Negligible
	52	88	81	0.92	29	25	0.86	7	Above	Negligible
	53	88	81	0.92	29	24	0.83	7	Above	Negligible
	54	88	80	0.91	29	24	0.83	8	Above	Negligible
	55	88	79	0.9	29	24	0.83	9	Above	Negligible
	56	88	84	0.95	29	27	0.93	4	Above	Negligible
	57	88	85	0.97	29	27	0.93	3	Above	Negligible
	58	88	84	0.95	29	27	0.93	4	Above	Negligible
	59	88	82	0.93	29	25	0.86	6	Above	Negligible
	60	88	81	0.92	29	25	0.86	7	Above	Negligible
	61	88	81	0.92	29	24	0.83	7	Above	Negligible
	62	88	80	0.91	29	24	0.83	8	Above	Negligible
	63	88	79	0.9	29	24	0.83	9	Above	Negligible
	64	88	84	0.95	29	27	0.93	4	Above	Negligible
	65	88	85	0.97	29	27	0.93	3	Above	Negligible
	66	88	84	0.95	29	27	0.93	4	Above	Negligible
	67	88	82	0.93	29	25	0.86	6	Above	Negligible
	68	88	81	0.92	29	25	0.86	7	Above	Negligible
	69	88	81	0.92	29	24	0.83	7	Above	Negligible
	70	88	80	0.91	29	24	0.83	8	Above	Negligible

	71	88	79	0.9	29	24	0.83	9	Above	Negligible
1 Central Street (Offices)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
6 Mount Str (martial art school, meeting, training and art gallery)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
75 Southmill St (Offices)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-

	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-
	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	-	-	-	-	-	-	-	-	-
	37	-	-	-	-	-	-	-	-	-
	38	-	-	-	-	-	-	-	-	-

	39	-	-	-	-	-	-	-	-	-
	40	-	-	-	-	-	-	-	-	-
	41	-	-	-	-	-	-	-	-	-
	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-
	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
	48	-	-	-	-	-	-	-	-	-
	49	-	-	-	-	-	-	-	-	-
	50	-	-	-	-	-	-	-	-	-
	51	-	-	-	-	-	-	-	-	-
	52	-	-	-	-	-	-	-	-	-
	53	-	-	-	-	-	-	-	-	-
	54	-	-	-	-	-	-	-	-	-
	55	-	-	-	-	-	-	-	-	-
	56	-	-	-	-	-	-	-	-	-
	57	-	-	-	-	-	-	-	-	-
	58	-	-	-	-	-	-	-	-	-
Television House (Offices)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
37 Peter Street (Offices)	0	-	-	-	-	-	-	-	-	-

	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-

	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	-	-	-	-	-	-	-	-	-
	37	-	-	-	-	-	-	-	-	-
	38	-	-	-	-	-	-	-	-	-
	39	-	-	-	-	-	-	-	-	-
	40	-	-	-	-	-	-	-	-	-
	41	-	-	-	-	-	-	-	-	-
	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-
	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
11-13 Bootle Street	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
Marron Place Building (office)	0	-	-	-	-	-	-	-	-	-

	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-

	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	-	-	-	-	-	-	-	-	-
	37	-	-	-	-	-	-	-	-	-
	38	-	-	-	-	-	-	-	-	-
	39	-	-	-	-	-	-	-	-	-
	40	-	-	-	-	-	-	-	-	-
	41	-	-	-	-	-	-	-	-	-
	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-
	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
	48	-	-	-	-	-	-	-	-	-
	49	-	-	-	-	-	-	-	-	-
	50	-	-	-	-	-	-	-	-	-
	51	-	-	-	-	-	-	-	-	-
	52	-	-	-	-	-	-	-	-	-
	53	-	-	-	-	-	-	-	-	-
	54	-	-	-	-	-	-	-	-	-
	55	-	-	-	-	-	-	-	-	-
	56	-	-	-	-	-	-	-	-	-
	57	-	-	-	-	-	-	-	-	-
	58	-	-	-	-	-	-	-	-	-
	59	-	-	-	-	-	-	-	-	-
Albert hall	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-

	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
23 St Peter (covered windows)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-

	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
2 Bootle St/Jerusalem Place (offices, Rest, residential?)	0	21	21	1	7	7	1	0	Above	Negligible
	1	20	20	1	6	6	1	0	Above	Negligible
	2	20	20	1	6	6	1	0	Above	Negligible
	3	20	20	1	6	6	1	0	Above	Negligible
	4	20	20	1	6	6	1	0	Above	Negligible
	5	20	20	1	6	6	1	0	Above	Negligible
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	30	30	1	9	9	1	0	Above	Negligible
	12	29	29	1	7	7	1	0	Above	Negligible
	13	28	28	1	7	7	1	0	Above	Negligible
	14	28	28	1	7	7	1	0	Above	Negligible
	15	28	28	1	7	7	1	0	Above	Negligible
	16	28	28	1	7	7	1	0	Above	Negligible
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-

	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	41	40	0.98	10	10	1	1	Above	Negligible
	24	44	42	0.95	11	11	1	2	Above	Negligible
	25	43	40	0.93	10	10	1	3	Above	Negligible
	26	43	40	0.93	10	10	1	3	Above	Negligible
	27	44	41	0.93	10	10	1	3	Above	Negligible
	28	43	39	0.91	9	9	1	4	Above	Negligible
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-
	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	43	41	0.95	10	10	1	2	Above	Negligible
	37	46	43	0.93	11	11	1	3	Above	Negligible
	38	47	42	0.89	10	10	1	5	Above	Negligible
	39	48	43	0.9	10	10	1	5	Above	Negligible
	40	48	42	0.88	10	10	1	6	Above	Negligible
	41	48	42	0.88	10	10	1	6	Above	Negligible
	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-

	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
	48	-	-	-	-	-	-	-	-	-
	49	-	-	-	-	-	-	-	-	-
	50	-	-	-	-	-	-	-	-	-
Theatre Royal (Unused Theatre, NightClub)	0	5	5	1	0	0	0	0	Above	Negligible
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	6	6	1	0	0	0	0	Above	Negligible
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
Radison Blu Edwardian Manchester (Hotel)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-

	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-
	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	-	-	-	-	-	-	-	-	-
	37	-	-	-	-	-	-	-	-	-
	38	-	-	-	-	-	-	-	-	-
	39	-	-	-	-	-	-	-	-	-
	40	-	-	-	-	-	-	-	-	-
	41	-	-	-	-	-	-	-	-	-

	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-
	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
	48	-	-	-	-	-	-	-	-	-
	49	-	-	-	-	-	-	-	-	-
	50	-	-	-	-	-	-	-	-	-
	51	-	-	-	-	-	-	-	-	-
	52	-	-	-	-	-	-	-	-	-
	53	-	-	-	-	-	-	-	-	-
	54	-	-	-	-	-	-	-	-	-
	55	-	-	-	-	-	-	-	-	-
	56	-	-	-	-	-	-	-	-	-
	57	-	-	-	-	-	-	-	-	-
	58	-	-	-	-	-	-	-	-	-
	59	-	-	-	-	-	-	-	-	-
	60	-	-	-	-	-	-	-	-	-
	61	-	-	-	-	-	-	-	-	-
	62	-	-	-	-	-	-	-	-	-
	63	-	-	-	-	-	-	-	-	-
	64	-	-	-	-	-	-	-	-	-
	65	-	-	-	-	-	-	-	-	-
	66	-	-	-	-	-	-	-	-	-
	67	-	-	-	-	-	-	-	-	-
	68	-	-	-	-	-	-	-	-	-
	69	-	-	-	-	-	-	-	-	-
	70	-	-	-	-	-	-	-	-	-
	71	-	-	-	-	-	-	-	-	-
	72	-	-	-	-	-	-	-	-	-

	73	-	-	-	-	-	-	-	-	-
	74	-	-	-	-	-	-	-	-	-
	75	-	-	-	-	-	-	-	-	-
	76	-	-	-	-	-	-	-	-	-
	77	-	-	-	-	-	-	-	-	-
	78	-	-	-	-	-	-	-	-	-
	79	-	-	-	-	-	-	-	-	-
	80	-	-	-	-	-	-	-	-	-
	81	-	-	-	-	-	-	-	-	-
	82	-	-	-	-	-	-	-	-	-
	83	-	-	-	-	-	-	-	-	-
	84	-	-	-	-	-	-	-	-	-
	85	-	-	-	-	-	-	-	-	-
44 Peter Street (Offices?)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-

	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
Fourth Church of Christ Scientists	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
De Kuyper (Commercial)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-

	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
Greath Northern Tower (Residential)	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-
	25	-	-	-	-	-	-	-	-	-

	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-
	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	-	-	-	-	-	-	-	-	-
	37	-	-	-	-	-	-	-	-	-
	38	-	-	-	-	-	-	-	-	-
	39	-	-	-	-	-	-	-	-	-
	40	-	-	-	-	-	-	-	-	-
	41	-	-	-	-	-	-	-	-	-
	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-
	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
	48	-	-	-	-	-	-	-	-	-
	49	-	-	-	-	-	-	-	-	-
	50	-	-	-	-	-	-	-	-	-
	51	-	-	-	-	-	-	-	-	-
	52	-	-	-	-	-	-	-	-	-
	53	-	-	-	-	-	-	-	-	-
	54	-	-	-	-	-	-	-	-	-
	55	-	-	-	-	-	-	-	-	-
	56	-	-	-	-	-	-	-	-	-

	57	-	-	-	-	-	-	-	-	-
	58	-	-	-	-	-	-	-	-	-
	59	-	-	-	-	-	-	-	-	-
	60	-	-	-	-	-	-	-	-	-
	61	-	-	-	-	-	-	-	-	-
	62	-	-	-	-	-	-	-	-	-
	63	-	-	-	-	-	-	-	-	-
Oddfellows House	0	34	25	0.74	8	8	1	9	Above	Negligible
	1	35	26	0.74	8	8	1	9	Above	Negligible
	2	32	26	0.81	8	8	1	6	Above	Negligible
	3	31	27	0.87	9	9	1	4	Above	Negligible
	4	33	30	0.91	9	9	1	3	Above	Negligible
	5	37	29	0.78	8	8	1	8	Above	Negligible
	6	35	27	0.77	7	7	1	8	Above	Negligible
	7	37	30	0.81	9	9	1	7	Above	Negligible
	8	37	29	0.78	7	7	1	8	Above	Negligible
	9	37	31	0.84	9	9	1	6	Above	Negligible
	10	33	28	0.85	8	8	1	5	Above	Negligible
	11	34	29	0.85	8	8	1	5	Above	Negligible
	12	32	26	0.81	9	8	0.89	6	Above	Negligible
	13	37	29	0.78	7	7	1	8	Above	Negligible
	14	33	28	0.85	9	9	1	5	Above	Negligible
	15	39	30	0.77	11	10	0.91	9	Above	Negligible
	16	42	33	0.79	10	9	0.9	9	Above	Negligible

	17	39	29	0.74	11	10	0.91	10	Above	Negligible
	18	40	33	0.82	10	10	1	7	Above	Negligible
	19	41	36	0.88	13	13	1	5	Above	Negligible
	20	41	34	0.83	12	12	1	7	Above	Negligible
	21	42	34	0.81	10	10	1	8	Above	Negligible
	22	42	33	0.79	9	9	1	9	Above	Negligible
	23	41	30	0.73	11	10	0.91	11	Above	Negligible
	24	40	31	0.78	10	10	1	9	Above	Negligible
	25	43	31	0.72	12	10	0.83	12	Above	Negligible
	26	43	32	0.74	10	10	1	11	Above	Negligible
	27	43	33	0.77	10	10	1	10	Above	Negligible
	28	45	35	0.78	10	10	1	10	Above	Negligible
	29	42	33	0.79	10	10	1	9	Above	Negligible
	30	49	40	0.82	15	15	1	9	Above	Negligible
	31	49	38	0.78	13	11	0.85	11	Above	Negligible
	32	48	37	0.77	12	11	0.92	11	Above	Negligible
	33	50	40	0.8	12	12	1	10	Above	Negligible
	34	50	40	0.8	14	14	1	10	Above	Negligible
	35	50	39	0.78	13	10	0.77	11	Above	Negligible
	36	52	39	0.75	14	11	0.79	13	Above	Negligible
	37	50	39	0.78	13	11	0.85	11	Above	Negligible

	38	51	39	0.76	14	12	0.86	12	Above	Negligible
	39	50	37	0.74	13	11	0.85	13	Above	Negligible
	40	52	41	0.79	13	13	1	11	Above	Negligible
	41	51	41	0.8	13	13	1	10	Above	Negligible
	42	50	39	0.78	12	12	1	11	Above	Negligible
	43	50	39	0.78	13	12	0.92	11	Above	Negligible
	44	50	38	0.76	13	13	1	12	Above	Negligible
Oddfellows House (offices)	0	38	38	1	13	13	1	0	Above	Negligible
	1	38	38	1	13	13	1	0	Above	Negligible
	2	39	37	0.95	12	12	1	2	Above	Negligible
	3	38	37	0.97	12	12	1	1	Above	Negligible
	4	37	34	0.92	9	9	1	3	Above	Negligible
	5	39	35	0.9	9	9	1	4	Above	Negligible
	6	39	39	1	13	13	1	0	Above	Negligible
	7	36	35	0.97	9	9	1	1	Above	Negligible
	8	40	37	0.92	12	12	1	3	Above	Negligible
	9	37	36	0.97	8	8	1	1	Above	Negligible
	10	36	35	0.97	8	8	1	1	Above	Negligible
	11	36	35	0.97	8	8	1	1	Above	Negligible
	12	36	36	1	8	8	1	0	Above	Negligible
	13	38	36	0.95	10	10	1	2	Above	Negligible

	14	40	38	0.95	10	10	1	2	Above	Negligible
	15	38	37	0.97	9	9	1	1	Above	Negligible
	16	43	38	0.88	10	10	1	5	Above	Negligible
	17	44	43	0.98	13	13	1	1	Above	Negligible
	18	44	43	0.98	13	13	1	1	Above	Negligible
	19	47	44	0.94	14	14	1	3	Above	Negligible
	20	46	46	1	15	15	1	0	Above	Negligible
	21	41	37	0.9	10	10	1	4	Above	Negligible
	22	42	37	0.88	10	10	1	5	Above	Negligible
	23	43	38	0.88	10	10	1	5	Above	Negligible
	24	46	42	0.91	13	13	1	4	Above	Negligible
	25	45	42	0.93	11	11	1	3	Above	Negligible
	26	45	41	0.91	11	11	1	4	Above	Negligible
	27	44	39	0.89	11	11	1	5	Above	Negligible
	28	45	42	0.93	11	11	1	3	Above	Negligible
	29	48	44	0.92	14	14	1	4	Above	Negligible
	30	46	42	0.91	12	12	1	4	Above	Negligible
	31	44	41	0.93	11	11	1	3	Above	Negligible
	32	51	47	0.92	15	15	1	4	Above	Negligible
	33	51	47	0.92	15	15	1	4	Above	Negligible
	34	52	46	0.88	14	14	1	6	Above	Negligible

	35	53	47	0.89	15	15	1	6	Above	Negligible
	36	50	44	0.88	16	16	1	6	Above	Negligible
	37	50	43	0.86	16	16	1	7	Above	Negligible
	38	51	48	0.94	15	15	1	3	Above	Negligible
	39	51	49	0.96	16	16	1	2	Above	Negligible
	40	52	44	0.85	16	16	1	8	Above	Negligible
	41	52	46	0.88	16	16	1	6	Above	Negligible
	42	49	43	0.88	16	16	1	6	Above	Negligible
	43	51	44	0.86	16	16	1	7	Above	Negligible
	44	51	45	0.88	14	14	1	6	Above	Negligible
	45	52	46	0.88	14	14	1	6	Above	Negligible
	46	51	46	0.9	15	15	1	5	Above	Negligible
	47	51	45	0.88	14	14	1	6	Above	Negligible
	48	56	50	0.89	17	17	1	6	Above	Negligible
	49	56	50	0.89	17	17	1	6	Above	Negligible
	50	55	49	0.89	17	17	1	6	Above	Negligible
	51	56	50	0.89	17	17	1	6	Above	Negligible
	52	54	45	0.83	18	18	1	9	Above	Negligible
	53	54	45	0.83	18	17	0.94	9	Above	Negligible
	54	56	50	0.89	17	17	1	6	Above	Negligible
	55	54	46	0.85	18	18	1	8	Above	Negligible

	56	55	48	0.87	17	17	1	7	Above	Negligible
	57	55	48	0.87	17	17	1	7	Above	Negligible
	58	55	46	0.84	17	17	1	9	Above	Negligible
	59	55	46	0.84	17	17	1	9	Above	Negligible
	60	55	48	0.87	16	16	1	7	Above	Negligible
	61	55	48	0.87	16	16	1	7	Above	Negligible
	62	55	48	0.87	17	17	1	7	Above	Negligible
	63	55	47	0.85	16	16	1	8	Above	Negligible
1 Scott Street (Offices, Commercial)	0	56	54	0.96	13	12	0.92	2	Above	Negligible
	1	28	24	0.86	0	0	0	4	Above	Negligible
	2	43	36	0.84	4	3	0.75	7	Below	Low
	3	26	20	0.77	8	7	0.88	6	Below	Low
	4	10	10	1	10	10	1	0	Above	Negligible
	5	0	0		0	0	0	0	Above	Negligible
	6	4	3	0.75	4	3	0.75	1	Above	Negligible
	7	32	26	0.81	10	9	0.9	6	Above	Negligible
	8	70	65	0.93	14	13	0.93	5	Above	Negligible
	9	62	57	0.92	4	3	0.75	5	Below	Low
	10	72	63	0.88	14	10	0.71	9	Above	Negligible
	11	69	60	0.87	18	15	0.83	9	Above	Negligible
	12	76	70	0.92	20	18	0.9	6	Above	Negligible
	13	74	68	0.92	16	14	0.88	6	Above	Negligible

	14	77	68	0.88	19	15	0.79	9	Above	Negligible
	15	76	67	0.88	23	20	0.87	9	Above	Negligible
	16	39	32	0.82	13	11	0.85	7	Above	Negligible
	17	39	34	0.87	10	9	0.9	5	Above	Negligible
	18	79	72	0.91	23	20	0.87	7	Above	Negligible
	19	81	75	0.93	23	21	0.91	6	Above	Negligible
	20	82	72	0.88	24	19	0.79	10	Above	Negligible
	21	80	70	0.88	25	21	0.84	10	Above	Negligible
	22	42	35	0.83	13	11	0.85	7	Above	Negligible
	23	42	36	0.86	12	9	0.75	6	Above	Negligible
	24	44	37	0.84	13	9	0.69	7	Above	Negligible
	25	82	76	0.93	26	23	0.88	6	Above	Negligible
	26	84	79	0.94	26	24	0.92	5	Above	Negligible
	27	84	75	0.89	26	21	0.81	9	Above	Negligible
	28	82	72	0.88	26	22	0.85	10	Above	Negligible
	29	46	38	0.83	14	11	0.79	8	Above	Negligible
	30	46	38	0.83	15	10	0.67	8	Above	Negligible
	31	85	79	0.93	29	26	0.9	6	Above	Negligible
	32	87	82	0.94	29	27	0.93	5	Above	Negligible
	33	87	78	0.9	28	23	0.82	9	Above	Negligible
	34	85	75	0.88	27	23	0.85	10	Above	Negligible

	35	48	40	0.83	16	13	0.81	8	Above	Negligible
	36	85	79	0.93	29	26	0.9	6	Above	Negligible
	37	87	82	0.94	29	27	0.93	5	Above	Negligible
	38	88	79	0.9	29	24	0.83	9	Above	Negligible
	39	87	77	0.89	29	25	0.86	10	Above	Negligible
	40	54	46	0.85	19	16	0.84	8	Above	Negligible
	41	87	82	0.94	29	27	0.93	5	Above	Negligible
	42	88	79	0.9	29	24	0.83	9	Above	Negligible
	43	87	80	0.92	29	26	0.9	7	Above	Negligible
	44	57	50	0.88	19	16	0.84	7	Above	Negligible
123 Deansgate	0	31	31	1	4	4	1	0	Above	Negligible
	1	36	36	1	5	5	1	0	Above	Negligible
	2	42	42	1	7	7	1	0	Above	Negligible
	3	46	46	1	6	6	1	0	Above	Negligible
	4	34	34	1	5	5	1	0	Above	Negligible
	5	35	35	1	6	6	1	0	Above	Negligible
	6	34	34	1	4	4	1	0	Above	Negligible
	7	35	35	1	4	4	1	0	Above	Negligible
	8	33	33	1	4	4	1	0	Above	Negligible
	9	39	39	1	6	6	1	0	Above	Negligible
	10	38	38	1	6	6	1	0	Above	Negligible

	11	41	41	1	7	7	1	0	Above	Negligible
	12	46	46	1	9	9	1	0	Above	Negligible
	13	44	44	1	8	8	1	0	Above	Negligible
	14	46	46	1	9	9	1	0	Above	Negligible
	15	47	47	1	7	7	1	0	Above	Negligible
	16	49	49	1	9	9	1	0	Above	Negligible
	17	49	49	1	7	7	1	0	Above	Negligible
	18	53	53	1	10	10	1	0	Above	Negligible
	19	52	52	1	9	9	1	0	Above	Negligible
	20	54	54	1	10	10	1	0	Above	Negligible
	21	54	54	1	10	10	1	0	Above	Negligible
	22	57	56	0.98	10	10	1	1	Above	Negligible
	23	58	57	0.98	10	10	1	1	Above	Negligible
	24	35	35	1	6	6	1	0	Above	Negligible
	25	36	36	1	7	7	1	0	Above	Negligible
	26	35	35	1	5	5	1	0	Above	Negligible
	27	37	37	1	6	6	1	0	Above	Negligible
	28	35	35	1	6	6	1	0	Above	Negligible
	29	41	41	1	8	8	1	0	Above	Negligible
	30	40	40	1	8	8	1	0	Above	Negligible
	31	43	43	1	9	9	1	0	Above	Negligible

	32	49	49	1	11	11	1	0	Above	Negligible
	33	46	46	1	10	10	1	0	Above	Negligible
	34	51	51	1	12	12	1	0	Above	Negligible
	35	52	52	1	10	10	1	0	Above	Negligible
	36	54	54	1	12	12	1	0	Above	Negligible
	37	53	53	1	10	10	1	0	Above	Negligible
	38	57	57	1	12	12	1	0	Above	Negligible
	39	57	57	1	13	13	1	0	Above	Negligible
	40	57	57	1	12	12	1	0	Above	Negligible
	41	60	59	0.98	12	12	1	1	Above	Negligible
	42	60	59	0.98	12	12	1	1	Above	Negligible
	43	61	60	0.98	12	12	1	1	Above	Negligible
	44	38	38	1	8	8	1	0	Above	Negligible
	45	38	38	1	9	9	1	0	Above	Negligible
	46	37	37	1	6	6	1	0	Above	Negligible
	47	39	39	1	7	7	1	0	Above	Negligible
	48	37	37	1	7	7	1	0	Above	Negligible
	49	43	43	1	9	9	1	0	Above	Negligible
	50	42	42	1	9	9	1	0	Above	Negligible
	51	45	45	1	10	10	1	0	Above	Negligible
	52	52	52	1	12	12	1	0	Above	Negligible

	53	50	50	1	12	12	1	0	Above	Negligible
	54	53	53	1	13	13	1	0	Above	Negligible
	55	56	56	1	12	12	1	0	Above	Negligible
	56	56	56	1	13	13	1	0	Above	Negligible
	57	57	57	1	12	12	1	0	Above	Negligible
	58	61	61	1	15	15	1	0	Above	Negligible
	59	61	61	1	15	15	1	0	Above	Negligible
	60	62	61	0.98	14	14	1	1	Above	Negligible
	61	62	61	0.98	14	14	1	1	Above	Negligible
	62	63	63	1	14	14	1	0	Above	Negligible
	63	65	65	1	15	15	1	0	Above	Negligible
	64	42	42	1	8	8	1	0	Above	Negligible
	65	42	42	1	9	9	1	0	Above	Negligible
	66	43	43	1	7	7	1	0	Above	Negligible
	67	45	45	1	8	8	1	0	Above	Negligible
	68	44	44	1	8	8	1	0	Above	Negligible
	69	50	50	1	10	10	1	0	Above	Negligible
	70	49	49	1	10	10	1	0	Above	Negligible
	71	51	51	1	11	11	1	0	Above	Negligible
	72	57	57	1	13	13	1	0	Above	Negligible
	73	56	56	1	14	14	1	0	Above	Negligible

	74	60	60	1	14	14	1	0	Above	Negligible
	75	62	62	1	14	14	1	0	Above	Negligible
	76	61	61	1	14	14	1	0	Above	Negligible
	77	63	63	1	14	14	1	0	Above	Negligible
	78	67	66	0.99	17	17	1	1	Above	Negligible
	79	66	66	1	17	17	1	0	Above	Negligible
	80	65	65	1	15	15	1	0	Above	Negligible
	81	66	66	1	15	15	1	0	Above	Negligible
	82	67	67	1	15	15	1	0	Above	Negligible
	83	70	69	0.99	16	15	0.94	1	Above	Negligible
	84	49	49	1	8	8	1	0	Above	Negligible
	85	49	49	1	9	9	1	0	Above	Negligible
	86	48	48	1	7	7	1	0	Above	Negligible
	87	50	50	1	8	8	1	0	Above	Negligible
	88	51	51	1	9	9	1	0	Above	Negligible
	89	56	56	1	11	11	1	0	Above	Negligible
	90	55	55	1	11	11	1	0	Above	Negligible
	91	57	57	1	12	12	1	0	Above	Negligible
	92	62	62	1	14	14	1	0	Above	Negligible
	93	62	62	1	15	15	1	0	Above	Negligible
	94	65	65	1	15	15	1	0	Above	Negligible

	95	67	67	1	15	15	1	0	Above	Negligible
	96	66	66	1	15	15	1	0	Above	Negligible
	97	68	68	1	16	16	1	0	Above	Negligible
	98	71	71	1	18	18	1	0	Above	Negligible
	99	71	71	1	18	18	1	0	Above	Negligible
	100	71	71	1	17	17	1	0	Above	Negligible
	101	73	73	1	18	18	1	0	Above	Negligible
	102	73	72	0.99	18	17	0.94	1	Above	Negligible
	103	74	73	0.99	18	17	0.94	1	Above	Negligible
	104	57	57	1	8	8	1	0	Above	Negligible
	105	58	58	1	9	9	1	0	Above	Negligible
	106	56	56	1	7	7	1	0	Above	Negligible
	107	58	58	1	8	8	1	0	Above	Negligible
	108	60	60	1	9	9	1	0	Above	Negligible
	109	64	64	1	11	11	1	0	Above	Negligible
	110	63	63	1	11	11	1	0	Above	Negligible
	111	66	66	1	12	12	1	0	Above	Negligible
	112	70	70	1	15	15	1	0	Above	Negligible
	113	69	69	1	15	15	1	0	Above	Negligible
	114	71	71	1	16	16	1	0	Above	Negligible
	115	73	73	1	17	17	1	0	Above	Negligible

	116	72	72	1	16	16	1	0	Above	Negligible
	117	75	75	1	19	19	1	0	Above	Negligible
	118	77	77	1	21	21	1	0	Above	Negligible
	119	76	76	1	20	20	1	0	Above	Negligible
	120	77	77	1	21	21	1	0	Above	Negligible
	121	77	77	1	21	21	1	0	Above	Negligible
	122	78	77	0.99	22	21	0.95	1	Above	Negligible
	123	79	78	0.99	22	21	0.95	1	Above	Negligible
	124	68	67	0.99	12	12	1	1	Above	Negligible
	125	68	67	0.99	12	12	1	1	Above	Negligible
	126	68	67	0.99	12	12	1	1	Above	Negligible
	127	69	68	0.99	13	13	1	1	Above	Negligible
	128	70	69	0.99	14	14	1	1	Above	Negligible
	129	72	71	0.99	16	16	1	1	Above	Negligible
	130	72	71	0.99	16	16	1	1	Above	Negligible
	131	73	73	1	17	17	1	0	Above	Negligible
	132	76	76	1	20	20	1	0	Above	Negligible
	133	76	76	1	20	20	1	0	Above	Negligible
	134	76	76	1	20	20	1	0	Above	Negligible
	135	80	80	1	24	24	1	0	Above	Negligible
	136	77	77	1	21	21	1	0	Above	Negligible

	137	81	81	1	25	25	1	0	Above	Negligible
	138	80	80	1	24	24	1	0	Above	Negligible
	139	81	81	1	25	25	1	0	Above	Negligible
	140	81	81	1	25	25	1	0	Above	Negligible
	141	81	81	1	25	25	1	0	Above	Negligible
	142	81	80	0.99	25	24	0.96	1	Above	Negligible
	143	82	81	0.99	25	24	0.96	1	Above	Negligible
	144	78	74	0.95	22	19	0.86	4	Above	Negligible
	145	78	74	0.95	22	19	0.86	4	Above	Negligible
	146	79	75	0.95	23	20	0.87	4	Above	Negligible
	147	80	76	0.95	24	21	0.88	4	Above	Negligible
	148	80	76	0.95	24	21	0.88	4	Above	Negligible
	149	82	78	0.95	26	22	0.85	4	Above	Negligible
	150	82	78	0.95	26	22	0.85	4	Above	Negligible
	151	83	80	0.96	27	24	0.89	3	Above	Negligible
	152	84	83	0.99	28	27	0.96	1	Above	Negligible
	153	84	82	0.98	28	26	0.93	2	Above	Negligible
	154	84	83	0.99	28	27	0.96	1	Above	Negligible
	155	85	85	1	29	29	1	0	Above	Negligible
	156	85	85	1	29	29	1	0	Above	Negligible
	157	85	85	1	29	29	1	0	Above	Negligible

	158	85	85	1	29	29	1	0	Above	Negligible
	159	85	85	1	29	29	1	0	Above	Negligible
	160	86	86	1	30	30	1	0	Above	Negligible
	161	86	86	1	30	30	1	0	Above	Negligible
	162	86	85	0.99	30	29	0.97	1	Above	Negligible
	163	87	85	0.98	30	28	0.93	2	Above	Negligible
	164	86	81	0.94	30	26	0.87	5	Above	Negligible
	165	86	81	0.94	30	26	0.87	5	Above	Negligible
	166	86	81	0.94	30	26	0.87	5	Above	Negligible
	167	86	82	0.95	30	26	0.87	4	Above	Negligible
	168	86	82	0.95	30	26	0.87	4	Above	Negligible
	169	86	82	0.95	30	26	0.87	4	Above	Negligible
	170	86	82	0.95	30	26	0.87	4	Above	Negligible
	171	86	83	0.97	30	27	0.9	3	Above	Negligible
	172	86	85	0.99	30	29	0.97	1	Above	Negligible
	173	86	84	0.98	30	28	0.93	2	Above	Negligible
	174	86	85	0.99	30	29	0.97	1	Above	Negligible
	175	86	86	1	30	30	1	0	Above	Negligible
	176	86	86	1	30	30	1	0	Above	Negligible
	177	86	86	1	30	30	1	0	Above	Negligible
	178	86	86	1	30	30	1	0	Above	Negligible

	179	86	86	1	30	30	1	0	Above	Negligible
	180	86	86	1	30	30	1	0	Above	Negligible
	181	86	86	1	30	30	1	0	Above	Negligible
	182	86	85	0.99	30	29	0.97	1	Above	Negligible
	183	87	85	0.98	30	28	0.93	2	Above	Negligible
	184	86	82	0.95	30	26	0.87	4	Above	Negligible
	185	86	81	0.94	30	26	0.87	5	Above	Negligible
	186	86	82	0.95	30	26	0.87	4	Above	Negligible
	187	86	82	0.95	30	26	0.87	4	Above	Negligible
	188	86	82	0.95	30	26	0.87	4	Above	Negligible
	189	86	82	0.95	30	26	0.87	4	Above	Negligible
	190	86	82	0.95	30	26	0.87	4	Above	Negligible
	191	86	83	0.97	30	27	0.9	3	Above	Negligible
	192	86	85	0.99	30	29	0.97	1	Above	Negligible
	193	86	84	0.98	30	28	0.93	2	Above	Negligible
	194	86	85	0.99	30	29	0.97	1	Above	Negligible
	195	86	86	1	30	30	1	0	Above	Negligible
	196	86	86	1	30	30	1	0	Above	Negligible
	197	86	86	1	30	30	1	0	Above	Negligible
	198	86	86	1	30	30	1	0	Above	Negligible
	199	86	86	1	30	30	1	0	Above	Negligible


	200	86	86	1	30	30	1	0	Above	Negligible
	201	86	86	1	30	30	1	0	Above	Negligible
	202	86	85	0.99	30	29	0.97	1	Above	Negligible
	203	87	85	0.98	30	28	0.93	2	Above	Negligible
Scottish House	0	-	-	-	-	-	-	-	-	-
	1	-	-	-	-	-	-	-	-	-
	2	-	-	-	-	-	-	-	-	-
	3	-	-	-	-	-	-	-	-	-
	4	-	-	-	-	-	-	-	-	-
	5	-	-	-	-	-	-	-	-	-
	6	-	-	-	-	-	-	-	-	-
	7	-	-	-	-	-	-	-	-	-
	8	-	-	-	-	-	-	-	-	-
	9	-	-	-	-	-	-	-	-	-
	10	-	-	-	-	-	-	-	-	-
	11	-	-	-	-	-	-	-	-	-
	12	-	-	-	-	-	-	-	-	-
	13	-	-	-	-	-	-	-	-	-
	14	-	-	-	-	-	-	-	-	-
	15	-	-	-	-	-	-	-	-	-
	16	-	-	-	-	-	-	-	-	-
	17	-	-	-	-	-	-	-	-	-
	18	-	-	-	-	-	-	-	-	-
	19	-	-	-	-	-	-	-	-	-
	20	-	-	-	-	-	-	-	-	-
	21	-	-	-	-	-	-	-	-	-
	22	-	-	-	-	-	-	-	-	-
	23	-	-	-	-	-	-	-	-	-
	24	-	-	-	-	-	-	-	-	-

	25	-	-	-	-	-	-	-	-	-
	26	-	-	-	-	-	-	-	-	-
	27	-	-	-	-	-	-	-	-	-
	28	-	-	-	-	-	-	-	-	-
	29	-	-	-	-	-	-	-	-	-
	30	-	-	-	-	-	-	-	-	-
	31	-	-	-	-	-	-	-	-	-
	32	-	-	-	-	-	-	-	-	-
	33	-	-	-	-	-	-	-	-	-
	34	-	-	-	-	-	-	-	-	-
	35	-	-	-	-	-	-	-	-	-
	36	-	-	-	-	-	-	-	-	-
	37	-	-	-	-	-	-	-	-	-
	38	-	-	-	-	-	-	-	-	-
	39	-	-	-	-	-	-	-	-	-
	40	-	-	-	-	-	-	-	-	-
	41	-	-	-	-	-	-	-	-	-
	42	-	-	-	-	-	-	-	-	-
	43	-	-	-	-	-	-	-	-	-
	44	-	-	-	-	-	-	-	-	-
	45	-	-	-	-	-	-	-	-	-
	46	-	-	-	-	-	-	-	-	-
	47	-	-	-	-	-	-	-	-	-
	48	-	-	-	-	-	-	-	-	-
	49	-	-	-	-	-	-	-	-	-
	50	-	-	-	-	-	-	-	-	-
	51	-	-	-	-	-	-	-	-	-
	52	-	-	-	-	-	-	-	-	-
	53	-	-	-	-	-	-	-	-	-
	54	-	-	-	-	-	-	-	-	-
	55	-	-	-	-	-	-	-	-	-


	56	-	-	-	-	-	-	-	-	-
	57	-	-	-	-	-	-	-	-	-
	58	-	-	-	-	-	-	-	-	-
	59	-	-	-	-	-	-	-	-	-
	60	-	-	-	-	-	-	-	-	-
	61	-	-	-	-	-	-	-	-	-
	62	-	-	-	-	-	-	-	-	-
	63	-	-	-	-	-	-	-	-	-
	64	-	-	-	-	-	-	-	-	-
	65	-	-	-	-	-	-	-	-	-
	66	-	-	-	-	-	-	-	-	-
	67	-	-	-	-	-	-	-	-	-
	68	-	-	-	-	-	-	-	-	-
	69	-	-	-	-	-	-	-	-	-
	70	-	-	-	-	-	-	-	-	-
	71	-	-	-	-	-	-	-	-	-
	72	-	-	-	-	-	-	-	-	-
	73	-	-	-	-	-	-	-	-	-
	74	-	-	-	-	-	-	-	-	-
	75	-	-	-	-	-	-	-	-	-
	76	-	-	-	-	-	-	-	-	-
	77	-	-	-	-	-	-	-	-	-
	78	-	-	-	-	-	-	-	-	-
	79	-	-	-	-	-	-	-	-	-
	80	-	-	-	-	-	-	-	-	-
	81	-	-	-	-	-	-	-	-	-
	82	-	-	-	-	-	-	-	-	-
	83	-	-	-	-	-	-	-	-	-
	84	-	-	-	-	-	-	-	-	-
	85	-	-	-	-	-	-	-	-	-

Appendix 1.4

INTERNAL OVERSHADOWING RESULTS



Overshadowing sensitive receptors within the Proposed Scheme




Summary of Results – Overshadowing of the Amenity Spaces in the Proposed Scheme


Results of Overshadowing Analysis for Open Spaces within the Proposed Scheme

Receptor	Description	Sensitivity	Ground Area Receiving >2hr sunlight	Ratio
1	Amenity Space Block A - South	High	65.05	Above
2	Amenity Space Block A – North	High	61.11	Above
3	Amenity Space External Terrace	High	71.89	Above
4	Amenity Space External Terrace	High	62.77	Above
5	Amenity Space External Terrace	High	58.05	Above
6	Amenity Space - Block B	High	51.28	Above
7	Ground Level	High	68.01	Above

Overshadowing - BRE Compliance - 21 March




Overshadowing - Sunlight Hours - 21 March




Appendix 1.6

EXTERNAL OVERSHADOWING ANALYSIS



Jackson's Row Sensitive Receptors for Overshadowing



Results of Overshadowing Analysis for Open Spaces

Square Name	Ground Area Receiving >2hr sunlight		Ratio
	Baseline	Proposed	
A- Albert Square	91.1%	90.7%	1.0
B- Lincoln Square	58.9%	56.8%	1.0
C - Deansgate Square	93.7%	87.3%	0.9
D- Great Northern	45.4%	45.4%	1.0



8 First Street
Manchester
M15 4RP

wsp.com