



5d4 BETWEEN THE PARTNER & ADJACENT WALL (m)	FULL HEIGHT CANTONERS AND SHOUL WALL	PARTIAL HEIGHT WALL WITH PROTECTION OR RECESSES
<10	✓	SOILING DIST. MORE THAN 10m OR PARTIAL HEIGHT CANTONERS
>10 - <100		SOILING DIST. MORE THAN 10m OR PARTIAL HEIGHT CANTONERS
>100 - <500	✓	SOILING DIST. MORE THAN 10m OR PARTIAL HEIGHT CANTONERS
>500	✓	✓

PLEASE NOTE:
POSITION OF LOWER
CALL STATION CAN VARY
FROM SITE TO SITE.



FOR EXTERNAL LIFT POWER SUPPLY
NEED TO BE LOCATED INSIDE BUILDING
AND DUCTED TO LIFT POSITION

The customer is responsible for carrying out the work below. These are required for the lift to comply with the Supply of Machinery (Safety) Regulations 1992. If any points are not clear, please contact Pollocklifts without delay.

- 1.0 GENERAL
- 1.1 Clear access into and through the building for the passage of the lift equipment and personnel must be maintained.
- 1.2 Unload delivered materials and store in a suitable dry and secure location within 5m of intended lift. Parts should be handled with care and using correctly to avoid damaging components and disfigure finishes. Parts may become damaged by storage outside or in damp conditions.

Do not scale from the drawings. All dimensions are in millimetres except where otherwise stated. All dimensions are to be measured from datum line A.

- 3.0 LIFT AREA
- 3.1 Floor and side walls in the area where the platform lift is to be located must be firm, smooth level, suitably drained and have no projections or recesses across their face. Any walls surrounding the lift should be positioned as per Table 4 away from the lift edges in order to eliminate tripping hazards.
- 3.2 Make good where necessary around the platform lift and its associated equipment after they are finally positioned and fixed.

4.1. Provide a 230V, 1 phase, 50 hertz, 3 wire permanent supply terminating in a fused spur 13A within close vicinity of the lift (within the fabric of the building + A 20mm Duct installed terminating at lifting

- position as indicated). The switch 5A Choking Circuit must be able to accept 1 x 5A HRC fuse. GEO type "T" or equivalent fuses to BS589 Part 2.
- 4.2 For External installation it is recommended that lighting is provided controlled by PIRs.
- 4.3 The electrical work must comply with the latest revision of the IEE Wiring Regulations.
- 4.5 It is recommended that the supply is protected by a suitable RCD.
- 4.6 Where flush / surface mounted cable stations are required, walls should be chased out prior to lift installation to allow for mounting of cable conduit and call panels. Client to make good after lift commissioning.

1.....

2.....

3.....

4.....

5.....

6.....

7.....

APPROVED WORKING DRAWING	
BY:.....	COMP:.....
SIGNED:.....	DATE:.....

LIFT DATA

PLATFORM SIZE	800W	RAL 9007 COLOUR	Travel TBC
UPPER GATE HANDED	RIGHT HAND	TBC	
LOWER GATE HANDED	LEFT HAND	TBC	

UNIT 1 SLOEFIELD DRIVE

UNIT 1 SLOEFIELD DRIVE
CARRICKFERGUS
COUNTY ANTRIM
NORTHERN IRELAND
BT38 BGX
TEL: 00 44 (0) 28 933681 677
WEB: WWW.POLLOCKLIFTS.CO.UK

UNIT: 23 STEP LIFT

NAME: GENERAL ARRANGEMENT

6090809