



Memorandum

To Jack Naven

From Leanne Chapman

Date 5 April 2023

Subject **136367/FO/2023**

The installation of internal and external lighting.

We have reviewed the above application in relation to highways and our comments are as follows:

CONTEXT

The application seeks consent for the installation of internal and external lighting at 1 Spinningfields Square, Manchester, M3 3AP.

HIGHWAYS RESPONSE

The internal lighting proposals are acceptable.

Further detail is sought regarding the external lighting proposal. The lighting proposed for the roof top terrace should be designed to ensure an ULOR (Upward Light Output Ratio) of 0.05 or lower.

Highways Reference: 14272/SIGN/2023