

4. Extract Ventilation & Odour Control Equipment details

Kitchen Extract Fan will be Flakt Woods Estoc Targe

(powerBox 102-630-3)

Data sheet enclosed, however system pressure estimated at 700pa, and will be re-calculated once final installation drawing completed.

Sound attenuator will as manufactured by Northern Fans Ltd, and will be approx. 2000mm x 1000mm and indicated in the red box on enclosed data sheets.

UVO1000 modules will be as manufactured by Purified Air Ltd

ESP4500 modules will be as manufactured by Purified Air Ltd

Carbon Filters - SITESAFE cassettes, manufactured by Purified Air Ltd