



Disabled Access Plan
Ground Floor
scale A1@1:100

Proposed works

1. Fire exit door with push bar, 900mm effective opening.
2. 1500mm dia turning circle for access to DDA toilet facilities.
3. Fully compliant DDA toilet facilities.
4. 1100mm wide corridor for wheelchair access.
5. Existing door threshold step to remain therefore no alteration to or loss of existing accessibility

NOTE:

1st floor access is not necessary for disabled as we have accommodated they needs at ground floor level. The 1st floor is male and female toilet, storage and restaurant managers accommodation.