

REPORT

Company Number:12077288

admin@unblockthedrain.com

www.unblockthedrain.com

Tel:07949949406

Tel:01204 979298

Address:61 stirrups meadow
lowton Warrington

WA3 2SS

Account details:

Sort Code: 30-96-26

Account Number: 53324060

admin@unblockthedrain.com



Survey:

Site address:
66/68 Moseley rd
Ladybarn

Main sewer at FMH7 IL 1.4 m deep and is 225 in diameter. This runs across the back of properties, 21, 23,25 and 27 is owned by, United utilities we surveyed upstream 14m.

This is diverted to the right of 27 we abandoned survey at 16m due to root ingress. We carried on downstream 3.3 m to FMH8 IL is 1.7m deep We carried on another 12m to FMH9 IL 2 m deep we carried on 24.5 m to FMH10 This is hidden under the undergrowth to the side of property, 21.

Rodding access 1, 100 mm plastic pipe downstream to rainwater inspection chamber, two IL 0 .74, we carried on to the attenuation crates

Rodding access 2 downstream to rainwater inspection chamber one IL 0.60 we carried on downstream to rainwater inspection chamber to IL 0 .74

SVP, one downstream to FMH1 I L 0 .33 m downstream to FMH2 IL 0 .53 downstream to FMH3 IL 0.74 downstream to FMH4 IL 1.17 m combined system from this point downstream to FMH7 IL 1.45 m

SVP2 downstream to FMH6 IL 0.37 m in downstream to FMH 5IL 0.42 m downstream, to FMH4 IL 1.17m is combined system from this point.