

OFF LEVENSHULME ROAD, GORTON

Private Development

Proposed Equipment Schedule

22 February 2023

SHD895-SHD-HLG-LEVE-SH-EO-Lighting Schedule-R0



info@shdlighting.co.uk 07834 490 192 www.shdlighting.co.uk

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Location	Unit Description	Service Connection Type	Primary Isolator Detail	Secondary Isolator / Termination Type Detail
PR01	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T1
PR02	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T2
PR03	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T1
PR04	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T2
PR05	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T2
PR06	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T2
PR07	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K08 700-A5-CLO 18w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T2
PR08	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K12 500-A5-CLO 19w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T2
PR09	Not available	Not available	Refer to 'SHD895-SHD-HLG-LEVE-DR-EO-Lighting Layout-R0' private lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standards as supplied by Mallatle, CU Phosco, Valmont Stainton or similar. complete with post top mounted at 0° tilt, ASD Lighting Highway Diamond Elite Micro (HWD2-#3K12 500-A5-CLO 19w) and Lucy Zodion ZCELL 20lux photocell mounted in 7 pin NEMA socket	Private cable network connection	32A double pole isolator and BS 88 type 2 outgoing fuses	Termination Type T1

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.