

**Project**

Project Name: 28520 Mayo Civils Pankhurst Building Dover St Manchester 06
12 22

Project Date: 06/12/2022

Inspection Standard: MSCC5 Sewers & Drainage GB (SRM5 Scoring)



Table of Contents

Project Name	Project Number	Project Date
28520 Mayo Civils Pankhurst Building Dover St Manchester 06 12 22		06/12/2022

Project Information	P-1
Scoring Summary	P-2
Section Item 1: MH1.002 > EXT MH1 (MH1.002X)	1

Project Information

Project Name	Project Number	Project Date
28520 Mayo Civils Pankhurst Building Dover St Manchester 06 12 22		06/12/2022

Client

Company: MAYO CIVIL ENGINEERING Ltd
Department: UNIT D, ROCHDALE INDUSTRIAL ESTATE
Street: NORMAN ROAD
Town or City: ROCHDALE
County: LANCASHIRE
Post Code: OL11 4HS

Site

Company: MAYO CIVIL ENGINEERING Ltd
Contact: 28520 Mayo Civils Pankhurst Building Dover St Manchester
06 12 22

Contractor

Company: NRC Waste Water Solutions
Contact: Derek Kearns
Department: U K Operations Business manager
Street: unit D Russell Road
Town or City: Rock Ferry
County: Wirral
Post Code: CH42 1LU
Phone: 01516430800
Mobile: 07557 231 879
Email: dkearns@nrcc.com

Scoring Summary

Project Name	Project Number	Project Date
28520 Mayo Civils Pankhurst Building Dover St Manchester 06 12 22		06/12/2022

Structural Defects

Section	PLR	Grade	Description
All inspected pipes are in an acceptable structural condition (< grade 3).			

Service / Operational Condition

Section	PLR	Grade	Description
All inspected pipes are in an acceptable service condition (< grade 3).			

Abandoned Surveys


Section	PLR	Description
All inspections complete, none are abandoned.		

Information

These scoring summaries are based on the SRM grading from the WRc.

Section Pictures - 06/12/2022 - MH1.002X

Item No.	Inspection Direction	PLR	Client's Job Ref	Contractor's Job Ref
1	Upstream	MH1.002X	28520	



MH1.002X_65f6a484-fb48-4a6e-abf0-721bff9792e3_20221206_101009_890.jpg, 00:00:38, 5.67 m
Junction at 12 o'clock, 150mm dia