

Madeleine Mooney

Subject: RE: Nell Lane, Chorlton

From: michael@griffservices.co.uk <michael@griffservices.co.uk>

Sent: 03 August 2022 09:59

To: dentonconstructb@aol.com; joanne@griffservices.co.uk

Subject: RE: Nell Lane, Chorlton

Ian,

Yes, I can confirm that panels will seat below 200mm on roof.

Regards,

Michael Gancarz *Bsc Eng MEIT*
Managing Director

GRIFF SERVICES LTD

Head Quarters

Digital World Centre, 1 Lowry Plaza, The Quays, Manchester, M50 3UB

Operations and Logistics

Enterprise House, Unit 7A, Bailey Road, Trafford Park, Manchester, M17 1SA

T: 0161 399 0201 **Direct Line: extension 106**

M: 07957 087 182

W: www.griffservices.co.uk

E: michael@griffservices.co.uk



Please consider the environment and do not print this email unless absolutely necessary.

This Email and any files transmitted with it are confidential or contain privileged or copyright material. The material and information is in for use of the addressee only. If you are not the addressee you may not copy, forward, disclose or use any part of it. If you have received message in error, please delete it from your system and notify the sender immediately by return E-mail. GRIFF Services Ltd does not accept responsibility for changes made to this message after it has been sent. Internet communications cannot be guaranteed to be appropriate, secure or free of viruses. The sender does not accept liability for any errors or omissions.

From: dentonconstructb@aol.com <dentonconstructb@aol.com>

Sent: 02 August 2022 17:38

To: michael@griffservices.co.uk; joanne@griffservices.co.uk

Subject: FW: Nell Lane, Chorlton

Hi Michael / Joanne

Please see information on the seams

Please can you confirm this will still mean panel will be below 200 mm above the main roofing line

Look forward to hearing from you

Should you have any queries regarding the above please do not hesitate to contact us.

Ian Stanyer

Denton Construction, 8 Bexley Square Salford M3 6BZ

Tel 0161-834-8525 **Fax** 0161-834-8526

Mob 07973-743315

email denonconstructb@aol.com

web www.dentonconstructionltd.co.uk

From: info@bsmroofing.co.uk <info@bsmroofing.co.uk>

Sent: 02 August 2022 17:24

To: denonconstructb@aol.com

Subject: RE: Nell Lane, Chorlton

Hi Ian,

Please find VM Information attached with the seam information on page 8, our seam centres are at 600 mm

Regards

Byron

From: denonconstructb@aol.com <denonconstructb@aol.com>

Sent: 02 August 2022 17:17

To: info@bsmroofing.co.uk

Subject: Nell Lane, Chorlton

Hi Byron

Please could you send over the seam profile you are intending to use – the PV company have requested it so they can choose the correct fixing for their panels and can confirm the projection off the roof – the architects has advised that the planners want to see the dimension off the roof of the panels

Look forward to hearing from you

Should you have any queries regarding the above please do not hesitate to contact us.

Ian Stanyer

Denton Construction, 8 Bexley Square Salford M3 6BZ

Tel 0161-834-8525 **Fax** 0161-834-8526

Mob 07973-743315

email denonconstructb@aol.com

web www.dentonconstructionltd.co.uk