



0 12.5 25 37.5m




LOCATION PLAN I:1250



EXISTING GROUND FLOOR PLAN
1:100

- Mid span strutting should be provided to floor and ceiling joists.
- Where new brickwork abuts existing walls cavities should be continuous.
- A cavity tray (300mm wide DPC) to be provided over the brickwork on all door and windows opening and single storey roof abutment.
- All internal and external lintels to have 150mm minimum bearing.
- 30x5mmx1.2m galvanized steel straps to be used for lateral restraint at top with gable wall and roof rafters and at wall plate @ 2m c/c.
- Steel work to Structure Engineer's design and specifications. Boxed in 2 layers of plasterboard or single layer of Fireline.
- Sockets and switches between 450mm and 1200mm.
- All drainage to the satisfaction of the LABC Inspector on site.
- All new gas and heating works to be carried out by a Gas Safe Registered Installer and certificate to be provided on completion.
- All new Electrical work to be carried out by a qualified and competent person and certificate to be issued on completion of works.
- All smoke & heat detectors to be battery packed, mains powered, hardwired and interlinked to all storey landings.
- New 102mm facing brick work to match existing. 125mm Cavity to be partly filled with 75mm Kinspan's Thermaflow TW50/Celotex CW4000 cavity insulation OR 150mm cavity to be fully filled with Knauf's Dritherm 32 cavity insulation.
- 100mm Thermalite block work to internal skin. Dot & dab plasterboards taped and skim finished.
- Proposed external walls incorporating appropriate cavity wall ties, at max. 750mm horizontal and 450mm vertical centers (300mm at wall reveals).
- All studwork to be 12.5mm plasterboard (12.5mm moisture resistant in bathrooms) either side of 75x50mm softwood framework @ max. 400mm c/cs, head and sole plate to be provided. With gypsum skim finish to plasterboard and 75mm 'crown framethem' insulation between framework.
- All new windows to use double glazed units with a 'low-e' soft coating with an emissivity of 0.05. The double glazed panes are to be separated by a 16mm gap to provide a U-value of 1.4w/m²k. Trickle vents to windows. Safety glazing to critical locations as per approved document K1. Windows to open 1/20 th of the floor area. All first floor habitable room windows to be fire escape, windows to be 800-1100mm above FFL. Safety glazing to critical locations.
- Ceiling to be 12.5mm Gyproc Wallboard Duplex taped and skimmed. NOTE - Special precautions may be required when electric cables are covered by insulating materials.
- All internal SVRs to be boxed in with 2 No. layers of 12.5mm plasterboard, outer layer to be moisture resistant, on 75x50mm softwood framework @ max. 400mm c/cs with 30mm 'QuietZone Acoustic Blanket' fixed to manufacturers specification and an access panel to enable rodding of the Soil Pipe. All pipe work to be wrapped in 'QuietZone Partition Roll'.



0 .5 1 1.5m

PROPOSED GROUND FLOOR PLAN

Do not scale from this drawing. All information should be checked by the contractor on site before commencing work. Any discrepancies should be reported to the architect immediately. All rights are reserved and are not transferable. Unauthorised reproductions of this drawing are not permitted.

PURPOSE OF ISSUE BUILDING CONTROL

GENERAL NOTES

- (1) THE CONTRACTOR IS TO CHECK AND VERIFY ALL BUILDING AND SITE DIMENSIONS, LEVELS AND SEWER INVERT LEVELS AT CONNECTION POINTS BEFORE WORK COMMENCES.
- (2) THE CONTRACTOR IS TO COMPLY IN ALL RESPECTS WITH THE CURRENT BUILDING REGULATIONS WHETHER OR NOT SPECIFIC STANDARDS ARE REFERRED TO IN THE PLANS.
- (3) BEFORE WORK COMMENCES - ENSURE ALL PLANNING CONDITIONS AND BUILDING REGULATION CONDITIONS HAVE BEEN RESOLVED TO THE SATISFACTION OF THE LOCAL AUTHORITY.
- (4) ALL WORKS TO COMPLY WITH THE WORKMANSHIP CLAUSES IN BS800 SERIES AND TO BE IN FULL COMPLIANCE WITH THE BUILDING REGULATIONS.
- (5) CONTRACTOR IS TO NOTIFY BUILDING CONTROL AT THE APPROPRIATE STAGES IN CONSTRUCTION - NECESSARY FOR THEM TO DETERMINE THE WORKS STATUTORY COMPLIANCE. THE CONTRACTOR IS TO PROVIDE APPROPRIATE STRUCTURAL DETAILS BEFORE ANY WORK COMMENCES ON SITE.
- (7) THE PLANS RELATING TO THE PROPOSED PROJECT TO BE READ IN CONJUNCTION WITH ALL APPROPRIATE STRUCTURAL ENGINEERS DETAILS.
- (8) DO NOT SCALE FROM PLANS. USE FIGURED AND ON SITE DIMENSIONS ONLY. IF QUERIES ARISE ON SITE CONTACT SITE AGENT.
- (9) THE CONTRACTOR IS TO CHECK ALL DIMENSIONS ON SITE PRIOR TO COMMENCEMENT OF WORK ON SITE AND ANY DISCREPANCIES BE BROUGHT TO THE ATTENTION OF THE SITE AGENT.
- (10) ALL SITE WORK TO BE CARRIED OUT TO THE BUILDING REGULATIONS 2010, ITS REVISIONS, CURRENT BRITISH STANDARDS AND CODES OF PRACTICE.
- (11) ALL STATUTORY SITE INSPECTIONS ARE TO BE SEEN AND APPROVED BY L.A.B.C.O. PRIOR TO ANY COVERING UP OF WORK.
- (12) NO WORK IS TO BE CARRIED OUT FROM THIS PLAN UNTIL IT HAS BEEN STAMPED APPROVED BY COUNCIL BUILDING CONTROL AND PLANNING DEPARTMENTS.
- (13) ALL DRAINAGE AND WASTE PIPING TO BE PROPOSED AND SITED TO MEET THE CONDITIONS OF THE DRAINAGE SITE.
- (14) ALL CONCRETE WORK TO BE CARRIED OUT TO BS5328:1981 AND BS1282:1985.
- (10) ALL BRICKWORK TO BE CARRIED OUT TO BS5328:1973:1985.
- (15) ALL TIMBER TO BE TREATED WITH A SUITABLE PRESERVATIVE TO BS1262:1975.
- (16) ALL WORK REGARDING THIS PROJECT IS SUBJECT TO THE BCO'S APPROVAL AND SATISFACTION.
- (17) ALL STRUCTURAL WORK MUST BE INSPECTED AT THE RELEVANT STAGES BY THE STRUCTURAL ENGINEER AND/OR THE BUILDING CONTROL OFFICER, AND COMPLY WITH THEIR REQUIREMENTS.
- (18) ALL ELECTRICAL WORK IS TO COMPLY WITH ALL THE RELEVANT REGULATIONS AND STANDARDS AND BE CERTIFICATE TO BE PROVIDED ON COMPLETION OF WORK.
- (19) SITE TO BE LEFT CLEAN BY CONTRACTOR AFTER COMPLETION OF PROJECT.

- CODE 4 LEAD FLASHINGS (MIN UPSTAND 150mm & MIN 150mm SPREAD ON TILE) AND CAVITY TRAYS ARE TO BE USED WHERE INDICATED.
- DOUBLE GLAZING TO BE PROVIDED TO ALL WINDOWS TO NEW STRUCTURE, THEREFORE U-VALUE OF WALLS TO BE 0.28w/m²k AND U-VALUE OF WINDOWS TO BE 1.8w/m²k, & EXTERNAL DOOR 1.8w/m²k (I.E.. CONSTRUCTED AS INDICATED) SAFETY GLAZING TO CRITICAL LOCATIONS.
- EXISTING EXTERIOR FINISHES TO BE MAINTAINED BY DUCTING FROM EXISTING VENTS WITH 100mm EARTHENWARE PIPES Laid IN HARDWARE TO NEW EXTERNAL VENTS, GIVING A MIN VENTILATION AREA EQUIVALENT TO 3000sqmm PER METER RUN - THE NEW CAVITIES SHOULD BE CONTINUOUS WITH THOSE OF THE EXISTING PROPERTY.
- INSULATED CAVITY CLOSERS TO BE PROVIDED AT ALL WINDOWS & DOOR OPENINGS.

NEW GROUND FLOOR

ALL VEGETABLE SOIL AND DELETERIOUS MATTER STRIPPED OFF SITE AND REMOVED TO AN APPROPRIATE LOCATION. THE EXISTING HARDWARE AND COMPACT LAY 1200 GAUGE DPM AND FULLY LAP WITH DPC. ANY JOINTS IN DPM TO BE LAPPED MIN. 300mm. PROVIDE 100mm 'KINSPAN/XTRATHERM/CELOTIX' INSULATION AS SHOWN ON SECTION. LAY MIN. 100mm CONCRETE (1:2:4:20mm AGGREGATE) SLAB FINISH SURFACE OF WITH 65mm SAND/CEMENT SCREED OR 25mm ASPHALT. EXISTING WOOD FLOOR LAY 100MM DIA PVC PIPE IN NEW GROUND FLOOR.

PROJECT
8 Earl Walk, Manchester

CLIENT
Mr. Theophilus Emmanuel

DRAWING TITLE
Outbuilding Plan

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-

JOB No
NA-P01

SCALE
1:50@A2

DATE
Dec. 2022

REVISION
-