





				Trial Pit Log			Trialpit No HP01 Sheet 1 of 1		
Project Name: Gorton Library				Project No. 070452		Co-ords: - Level:		Date 11/11/2022	
Location: Gorton				Client: Morgan Sindall		Dimensions (m): Depth 0.61		Scale 1:20	
		Logged RBJ							
Water Strike	Samples and In Situ Testing			Depth (m)	Level (m)	Legend	Stratum Description		
	Depth	Type	Results						
	0.20	ES		0.05			MADE GROUND: Grey medium well rounded pea gravel. MADE GROUND: Dark brown/black very gravelly clay. Gravel is medium to coarse and sub-angular to sub-rounded of brick, sandstone and siltstone.		
				0.60 0.61			MADE GROUND: Grey concrete. End of pit at 0.61 m		
							1		
							2		
							3		
							4		
Remarks: Foundation hand pit to 0.61m bgl. Hand pit terminated due to spacial restrictions. Refer to foundation hand pit drawing HP01. No groundwater encountered.									
Stability: Stable.									

				Trial Pit Log			Trialpit No HP02 Sheet 1 of 1			
Project Name: Gorton Library				Project No. 070452		Co-ords: - Level:		Date 11/11/2022		
Location: Gorton				Dimensions (m): Depth 1.05				Scale 1:20		
Client: Morgan Sindall								Logged RBJ		
Water Strike	Samples and In Situ Testing			Depth (m)	Level (m)	Legend	Stratum Description			
	Depth	Type	Results							
				0.05			MADE GROUND: Grey concrete flag.			
				0.10			MADE GROUND: Yellow/brown fine to medium sand.			
	0.40	B					MADE GROUND: Brown/black slightly silty, sandy, very clayey gravel with occasional cobbles. Gravel is fine to coarse and angular to sub-rounded of brick, glass, clinker, concrete, tar and sandstone. Cobbles of angular brick.			
	0.50	ES								
			0.80			Soft black very silty CLAY.				
			1.05			----- End of pit at 1.05 m				
Remarks: Foundation hand pit to 1.05m bgl. Refer to foundation hand pit drawing HP02. No groundwater encountered.									1	
Stability: Stable.									2	
									3	
									4	



				Trial Pit Log			Trialpit No HP04 Sheet 1 of 1		
Project Name: Gorton Library				Project No. 070452		Co-ords: - Level:		Date 11/11/2022	
Location: Gorton				Client: Morgan Sindall		Dimensions (m): Depth 1.00		Scale 1:20	
		Logged RBJ							
Water Strike	Samples and In Situ Testing			Depth (m)	Level (m)	Legend	Stratum Description		
	Depth	Type	Results						
	0.65	ES		0.23			Grass over TOPSOIL: Dark brown slightly gravelly, very silty clay with frequent rootlets. Gravel is fine to medium and sub-angular to sub-rounded of sandstone and siltstone.		
				0.55			MADE GROUND: Brown and grey very sandy gravel. Sand is fine to medium and gravel is medium to coarse and angular to sub-angular of limestone and concrete.		
				0.90			MADE GROUND: Black/brown sandy, silty, very clayey gravel. Gravel is medium to coarse and angular to sub-angular of brick, clinker, sandstone and siltstone.		
				1.00			Firm brown mottled grey silty gravelly CLAY. Gravel is medium to coarse and sub-angular to sub-rounded of siltstone, sandstone and rare coal.		
							End of pit at 1.00 m		
Remarks: Foundation hand pit to 1.00m bgl. Refer to foundation hand pit drawing HP04. No groundwater encountered.									
Stability: Stable.									

