

GENERAL NOTES:

1. THIS DRAWING IS COPYRIGHT AND SHALL NOT BE REPRODUCED WITHOUT PERMISSION
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DISCIPLINES, DRAWINGS, SCHEDULES AND SPECIFICATIONS, LEGENDS AND STANDARD DETAILS
3. DIMENSIONS GOVERN ON ALL DRAWINGS AND DETAILS. SHOULD ANY DISCREPANCIES BE FOUND ON THIS DRAWING AND ANY ASSOCIATED DRAWINGS OR SPECIFICATIONS, THIS SHOULD BE BROUGHT TO THE ATTENTION OF BRENTWOOD DESIGN IMMEDIATELY
4. CONTRACTORS MUST CHECK AND VERIFY ALL INFORMATION / DIMENSIONS / LEVELS IN CONJUNCTION WITH ALL RELEVANT DRAWINGS AND ACTUAL SITE CONDITIONS BEFORE COMPLETING ANY MANUFACTURING / INSTALLATION DRAWINGS OR COMMENCING SITE INSTALLATION WORK
5. DO NOT SCALE FROM THIS DRAWING

NOTES

1. FIRE ALARM DESIGN IS SUBJECT TO RECEIVING THE FIRE STRATEGY LAYOUTS FROM THE ARCHITECT, AS THIS WILL AFFECT ELEMENTS OF THE DESIGN
2. EMERGENCY LIGHTING DESIGN IS SUBJECT TO RECEIVING THE FIRE STRATEGY LAYOUTS FROM THE ARCHITECT, AS THIS WILL AFFECT ELEMENTS OF THE DESIGN
3. EXTERNAL LIGHTING REQUIREMENTS TO BE CONFIRMED BY THE ARCHITECT
4. EXIT SIGNAGE LAYOUT TBC BY ARCHITECT, ADDITIONAL SUPPLIES MAY BE REQUIRED
5. ACCESS CONTROL STRATEGY REQUIRED FROM THE ARCHITECT TO CONFIRM LOCATION OF FIRE ALARM INTERFACES AND POWER SUPPLIES. PARKER WILSON LOCATIONS SHOWN CURRENTLY
6. 2 NO. PIR DETECTORS ARE REQUIRED ON LANDING IN STAIRCORE AT LEVELS 1, 4, 7, 10 & 13 TO SWITCH FLOORS ABOVE AND BELOW
7. 2 NO. PIR DETECTORS ARE REQUIRED ON LANDING IN STAIRCORE AT LEVELS 1, & 4 TO SWITCH FLOORS ABOVE AND BELOW
8. TYPE 'G' LUMINAIRE MOUNTED AT 1800mm AFFL

GENERAL LIGHTING LEGEND

PLEASE SEE LUMINAIRE SCHEDULE FOR MANUFACTURER INFORMATION

- PENDANT LUMINAIRE
- SURFACE DOWNLIGHT
- RECESSED DOWNLIGHT
- LED STRIP
- SUSPENDED FEATURE LINEAR LUMINAIRE
- IMPACT RATED LINEAR LUMINAIRE
- 600 x 600 RECESSED LUMINAIRE
- SURFACE CIRCULAR LUMINAIRE
- TWIN SPOT EMERGENCY LED
- SURFACE EMERGENCY LUMINAIRE
- EMERGENCY EXIT SIGN WITH LEGEND
- EMERGENCY BULKHEAD
- PIR SENSOR
- WALL MOUNTED MICROWAVE SENSOR
- LIGHT SWITCH "W" DENOTES WAYS & "G" DENOTES GANGS
- TESTING/GENERIC LIGHTING KEY SWITCH
- DIGITAL TIMECLOCK
- PHOTOCELL

FIRE ALARM LEGEND

- SMOKE DETECTOR C/W SOUNDER BASE AND VISUAL BEACON
- SMOKE DETECTOR C/W SOUNDER BASE
- SMOKE DETECTOR
- HEAT DETECTOR C/W SOUNDER BASE
- HEAT DETECTOR
- FIRE ALARM SOUNDER AND VISUAL BEACON
- FIRE ALARM INTERFACE
- MANUAL CALL POINT
- FIRE ALARM PANEL
- SMOKE DETECTOR WITHIN CEILING VOID

|     |          |                                                                    |     |     |
|-----|----------|--------------------------------------------------------------------|-----|-----|
| P06 | 20/12/21 | LIGHTING RELOCATED ON STAIRS                                       | LR  | RD  |
| P05 | 14/11/20 | RECEPTION DESK LIGHTING AMENDED                                    | JC  | MC  |
| P04 | 29/09/20 | LUMINAIRE REFERENCES AMENDED & PARKER WILSON COMMENTS INCORPORATED | JC  | MC  |
| P03 | 24/08/20 | MAJOR DRAWING UPDATES                                              | JC  | MC  |
| P02 | 16/06/20 | UPDATED FIRE ALARM DESIGN                                          | JC  | MC  |
| P01 | 12/06/20 | PRELIMINARY ISSUE                                                  | JC  | MC  |
| Rev | Date     | Description                                                        | Dwn | CHK |

**BRENTWOOD**  
CONSULTING ENGINEERS

First Floor, 21 Horsebarn Square South, Harncliffe, HG2 8NH  
T: 01432 875853 W: www.brentwoodgroup.co.uk  
&  
Jacton House, 24 Wood Street, Manchester, M4 6NW  
T: 0161 569 4620

CLIENT



Integrated Building Services Ltd

PROJECT

ANCOATS GARDENS

DRAWING TITLE

LIGHTING & FIRE ALARM LAYOUT  
GROUND FLOOR

DRAWING STATUS

CONSTRUCTION

|                           |          |          |                 |
|---------------------------|----------|----------|-----------------|
| DRAWN BY                  | CHK BY   | DATE     | SCALE           |
| JC                        | MC       | 06/11/20 | As indicated@A1 |
| DRAWING NO.               | REVISION |          |                 |
| EC2016-BGL-63-00-DR-E-102 |          |          | P06             |