



To	Head of Planning	FAO: Robert Griffin
From	Head of Compliance, Enforcement and Community Safety	
Contact Officer:	Karen Williamson	Our Ref: 743568
Date:	28 June 2022	Telephone: 31347

Consultation on Planning Application

Application No: 133748/FO/2022

Description: Development of a residential accommodation block, comprising 42 no. residential units (Use Class C3) with ground floor commercial restaurant / cafe and retail units (Use Class E and sui generis), car parking, cycle parking and associated infrastructure.

Location: 98 Wilmslow Road, Manchester, M14 5AL

I write in response to your memorandum regarding the above application and to inform you that I have considered the application and recommend that the following conditions are attached to any approval.

RESIDENTIAL

REF*

a) Before the development commences a scheme for the storage and disposal of refuse shall be submitted to and approved in writing by the City Council as local planning authority.

New developments shall have refuse storage space for segregated waste collection and recycling. Internal and external storage areas are required.

b) The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health.

*The proforma/ Waste Management Strategy must include the following information:

- Estimated volumes and types of waste produced by the development;
- Details of internal and external stores for both waste and recycling, including any plans and designs;
- Location of the proposed collection point and details of the route the collection vehicle will take;
- Details of how waste will be transferred between stores and to the collection location; and
- Details of number and capacity of bins proposed and collection frequency.
- Other details as per 'Waste Proforma v1.0' - refer to guidance at: http://www.manchester.gov.uk/downloads/download/6048/waste_management_strategy

Details of ALL recyclable waste should be provided.

EH are in receipt of an Acoustic Report by Lighthouse Acoustics.

NSE4(b)

Residential sound insulation AND overheating

a) Before the development commences a scheme for acoustically insulating the proposed residential accommodation against noise from Wilmslow Road and the commercial units on the ground floor, shall be submitted to and approved in writing by the City Council as local planning authority. There may be other actual or potential sources of noise which require consideration on or near the site, including any local commercial/industrial premises.

The potential for overheating shall also be assessed and the noise insulation scheme shall take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the dwelling units are occupied.

Noise survey data shall include measurements taken during a rush-hour period and night time to determine the appropriate sound insulation measures necessary. The following noise criteria shall be required to be achieved:

Bedrooms (night time - 23.00 - 07.00)	30 dB L_{Aeq} (individual noise events shall not exceed 45 dB $L_{Amax,F}$ by more than 15 times)
Living Rooms (daytime - 07.00 - 23.00)	35 dB L_{Aeq}
Gardens and terraces (daytime)	55 dB L_{Aeq}

Additionally, where entertainment noise is a factor in the noise climate the sound insulation scheme shall be designed to achieve internal noise levels in the 63Hz and 125Hz octave centre frequency bands so as not to exceed (in habitable rooms) 47dB and 41dB ($L_{eq,5min}$), respectively.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The

report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise criteria.

Reason: To secure a reduction in noise from traffic or other sources in order to protect future residents from noise disturbance and to reduce the potential for overheating.

EH are in receipt of an Acoustic Report by Lighthouse Acoustics.

We accept the glazing specifications; however we need further information on the mechanical ventilation. Also if the bedroom furnishing differs from the report assumptions, (carpet and curtains) then another report needs to be undertaken. We also require an overheating assessment to be carried out on the rooms that require mechanical ventilation.

Regarding all commercial units, once they have been decided, separate acoustic reports are required.

More details are needed regarding ALL external equipment once decided.

COMMERCIAL

REF*

a) Before the development commences a scheme for the storage and disposal of refuse shall be submitted to and approved in writing by the City Council as local planning authority.

New developments shall have refuse storage space for segregated waste collection and recycling. Internal and external storage areas are required.

b) The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health.

*The proforma/ Waste Management Strategy must include the following information:

- Estimated volumes and types of waste produced by the development;
- Details of internal and external stores for both waste and recycling, including any plans and designs;
- Location of the proposed collection point and details of the route the collection vehicle will take;
- Details of how waste will be transferred between stores and to the collection location; and
- Details of number and capacity of bins proposed and collection frequency.

Other details as per 'Waste Proforma v1.0' - refer to guidance at:
http://www.manchester.gov.uk/downloads/download/6048/waste_management_strategy

Details of ALL recyclable waste should be provided

FUME*

Fume/odours

a) Fumes, vapours and odours shall be extracted and discharged from the premises in accordance with a scheme to be submitted to and approved in writing by the City Council as local planning authority before the use commences.

Mixed use schemes shall ensure provision for internal ducting in risers that terminate at roof level. Schemes that are outside the scope of such developments shall ensure that flues terminate at least 1m above the eave level and/or any openable windows/ventilation intakes of nearby properties.

b) Prior to commencement of the use hereby approved confirmation shall be submitted for the approval of the City Council as local planning authority that the approved scheme has been implemented.

Reason - In the interests of the amenities of occupiers of nearby properties.

**The applicant will need to consult with a suitably qualified ventilation engineer and submit a kitchen fume extract strategy report for approval. The strategy should include risk assessments for odour and noise and be based on appropriate guidance such as that published by EMAQ titled 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems' dated September 2018. Details should also be provided in relation to replacement air.*

EH are in receipt of an odour assessment by Redmore Environmental dated Feb 22. We accept this however require specifics when more details are known.

HOURS1

Premises opening hours

The premises shall not be open outside the following hours unless otherwise agreed in writing by the City Council as local planning authority:-

Hours to be submitted.

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

HOURS2

Deliveries to commercial premises

Deliveries, servicing and collections, including waste collections shall not take place outside the following hours: 07:30 to 20:00, Monday to Saturday, no deliveries/waste collections on Sundays/Bank Holidays.

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

NSE1

a) The premises shall be acoustically insulated and treated to limit the break out of noise in accordance with a noise study of the premises and a scheme of acoustic treatment that has been submitted to and approved in writing by the City Council as local planning authority. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

Where entertainment noise is proposed the L_{Aeq} (entertainment noise) shall be controlled to 5dB below the L_{A90} (without entertainment noise) in each octave band at the facade of the nearest noise sensitive location, and internal noise levels at structurally adjoined residential properties in the 63Hz and 125Hz octave frequency bands shall be controlled so as not to exceed (in habitable rooms) 47dB and 41dB ($L_{eq,5min}$), respectively.

b) Prior to occupation of the development a verification report will be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that acceptable criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To safeguard the amenities of the occupiers of the building and occupiers of nearby properties.

Note (e.g. if the use is for a pub, bar, nightclub): The scheme proposed may need to include different measures such as acoustic lobbies at access and egress points of the premises, acoustic treatment of the building structure, sound limiters linked to sound amplification equipment and specified maximum internal noise levels.

EH are in receipt of an Acoustic Report by Lighthouse Acoustics.

Regarding all commercial units, once they have been decided, separate acoustic reports are required.

ALL

AIR QUALITY 1 (AQ Impact and/or Exposure Assessment)

a) Prior to commencement of the development, an air quality impact exposure assessment together with mitigation measures to safeguard local air quality shall be submitted to and approved in writing by the City Council as local planning authority.

b) Prior to occupation of the development any agreed mitigation measures shall be implemented and verified as such in writing by the City Council as local planning authority and shall remain in situ whilst the use or development is in operation.

Reason: To secure a reduction in air pollution from traffic or other sources in order to protect existing and future residents from air pollution, pursuant to policies EN16, SP1 and DM1 of the Core Strategy.

EH accept the Air Quality Report by Redmore Environmental. All mitigation methods stated are to be undertaken.

DEMOLITION/CONSTRUCTION MANAGEMENT PLAN

Prior to the commencement of development, a demolition / construction management plan outlining working practices shall be submitted to and approved in writing by the City Council as Local Planning authority, which for the avoidance of doubt shall include as a minimum:

- Measures to control noise and vibration;
- Dust suppression measures;
- Compound locations where relevant;
- Details of an emergency contact telephone number;
- A community consultation plan and;
- Sheeting of construction vehicles.

The development shall only be carried out in accordance with the approved management plan.

Reason - To safeguard the amenities of nearby residents pursuant to policies SP1, EN19 and DM1 of the Manchester Core Strategy.

**The applicant should refer to our noise from building sites [webpage](#) for further information/guidance and also [IAQM/EPUK Construction Guidance](#)*

DEMOLITION/CONSTRUCTION HOURS

Construction/demolition works shall be confined to the following hours unless otherwise agreed in writing by the City Council as local planning authority:

- Monday - Friday: 7.30am - 6pm
- Saturday: 8.30am - 2pm
- Sunday / Bank holidays: No work

NSE6

External plant/equipment/servicing

- a) Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5dB (L_{Aeq}) below the typical background (L_{A90}) level at the nearest noise sensitive location. Prior to commencement of the use hereby approved the scheme shall be submitted to and approved in writing by the City Council as local planning authority in order to secure a reduction in the level of noise emanating from the site. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.
- b) Prior to the operation of the scheme a verification report shall be submitted to and approved in writing by the City Council as local planning authority to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic report. The report shall also undertake post completion testing to confirm that the noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To minimise the impact of the development and to prevent a general increase in pre-existing background noise levels around the site.

EH are in receipt of an Acoustic Report by Lighthouse Acoustics.

More details are needed regarding ALL external equipment once decided.

CLAND01 (1) New applications, no previous contaminated land conditions

- a) Before the development hereby approved commences, a report (the Preliminary Risk Assessment) to identify and evaluate all potential sources and impacts of any ground contamination, groundwater contamination and/or ground gas relevant to the site shall be submitted to and approved in writing by the City Council as local planning authority. The Preliminary Risk Assessment shall conform to City Council's current guidance document (Planning Guidance in Relation to Ground Contamination).

In the event of the Preliminary Risk Assessment identifying risks which in the written opinion of the Local Planning Authority require further investigation, the development shall not commence until a scheme for the investigation of the site and the identification of remediation measures (the Site Investigation Proposal) has been submitted to and approved in writing by the City Council as local planning authority.

The measures for investigating the site identified in the Site Investigation Proposal shall be carried out, before development commences and a report prepared outlining what

measures, if any, are required to remediate the land (the Site Investigation Report and/or Remediation Strategy) which shall be submitted to and approved in writing by the City Council as local planning authority.

b) When the development within each phase commences, the development shall be carried out in accordance with the previously agreed Remediation Strategy and a Completion/Verification Report shall be submitted to and approved in writing by the City Council as local planning authority.

In the event that ground contamination, groundwater contamination and/or ground gas, not previously identified, are found to be present on the site at any time before the development in each phase is occupied, then development shall cease and/or the development shall not be occupied until, a report outlining what measures, if any, are required to remediate the land (the Revised Remediation Strategy) is submitted to and approved in writing by the City Council as local planning authority and the development shall be carried out in accordance with the Revised Remediation Strategy, which shall take precedence over any Remediation Strategy or earlier Revised Remediation Strategy.

Reason - To ensure that the presence of or the potential for any contaminated land and/or groundwater is detected and appropriate remedial action is taken in the interests of public safety, pursuant to [INSERT] of the Unitary Development Plan for the City of Manchester.

EH are in receipt of a Desk Study by bEk Enviro Ltd, dated Jan 2022

We accept this and await a Site Investigation.

Information for Developers guidance documents can be downloaded using the following link:

http://www.manchester.gov.uk/info/500207/planning_and_regeneration/1962/additional_planning_guidance/3

Should you wish to discuss this matter further please contact Karen Williamson on extension 31347.

Fiona Sharkey
Head of Compliance, Enforcement and Community Safety