

Application number: 133748/FO/2022

Proposal: Development of a residential accommodation block, comprising 42 no. residential units (Use Class C3) with ground floor commercial restaurant / cafe and retail units (Use Class E and sui generis), car parking, cycle parking and associated infrastructure.

Location: 98 Wilmslow Road, Manchester, M14 5AL,

Applicant: Mr Patrick Sheridan, Views Holdings Limited

LLFA Comments 15 June 2022

The information uploaded to the Planning Portal 11 May 2022 has been considered.

We recommend the following Conditions:

Condition 1: No development shall take place until surface water drainage works have been implemented in accordance with Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacements national standards and details that have been submitted to and approved in writing by the Local Planning Authority.

In order to avoid/discharge the above drainage condition the following additional information has to be provided:

- Detailed drainage layout showing all components, levels and connectivity;
- Maximised integration of green SuDS components (utilising interception, infiltration or attenuation) if practicable;
- Evidence that the surface water attenuation that offers a reduction in surface water runoff rate to 5 l/s has been retained through to detailed design;
- Runoff volume in the 1 in 100 year, 6 hours rainfall shall be constrained to a value as close as is reasonable practicable to the greenfield runoff volume for the same event, but never to exceed the runoff volume from the development site prior to redevelopment;
- Evidence that the drainage system has been designed (unless an area is designated to hold and/or convey water as part of the design) so that flooding does not occur during a 1 in 100 year rainfall event with allowance for 45% climate change in any part of a building;
- Hydraulic calculation of the proposed drainage system;
- Assessment of overland flow routes for extreme events that is diverted away from buildings (including basements). Overland flow routes need to be designed to convey the flood water in a safe manner in the event of a blockage or exceedance of the proposed drainage system capacity including inlet structures. A layout with overland flow routes needs to be presented with appreciation of these overland flow routes with regards to the properties on site and adjacent properties off site.
- Construction details of flow control and SuDS elements.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution. This condition is imposed in light of national policies within the NPPF and NPPG and local policies EN08 and EN14.

If there is no clear adoption policy in place to take over the proposed drainage system after construction, we suggest the following construction and maintenance condition to be considered by the LPA:

Condition 2: No development hereby permitted shall be occupied until details of the implementation, maintenance and management of the sustainable drainage scheme have been submitted to and approved by the local planning authority. The scheme shall be implemented and thereafter managed and maintained in accordance with the approved details. Those details shall include:

- Verification report providing photographic evidence of construction as per design drawings;
- As built construction drawings if different from design construction drawings;
- Management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime.

Reason: To manage flooding and pollution and to ensure that a managing body is in place for the sustainable drainage system and there is funding and maintenance mechanism for the lifetime of the development.