

1000 x (500) FRESH AIR INTAKE LOUVRE

1000 x (400) SIDE WITHDRAWAL FRESH AIR FILTER

SET DOWN

500 x (500) FRESH AIR HEATER

500Ø 1D SOUND ATTENUATOR

FRESH AIR SUPPLY FAN

500 x 500 DUCT RISE TO FLAT ROOF

EXTRACT DUCT, 2 HOUR FIRE RATED

KITCHEN CANOPY, COMPLETE WITH GREASE SEPARATOR

Rev	Date	Description
F	13.10.22	FRESH AIR SOUND ATTENUATOR FROM 2D TO 1D. LOCATION OF EXTRACT DUCT THROUGH ROOF SPECIFIED. AIR & EXTRACT DUCT ROUTES ADJUSTED.
E	10.10.22	FRESH AIR LOUVRE SIZE INCREASED. FRESH AIR PLANT MOVED TO WAITER STATION. EXTRACT DUCT THROUGH ROOF SPECIFIED. EXTRACT PLANT MOVED TO FLAT ROOF.
D	9.10.22	LIFT MOTOR ROOM & ROOF TOP ADJUSTED.
C	8.9.22	SYSTEM REVISED TO SUIT NEW LAYOUT. EXTRACT PLANT MOVED TO FLAT ROOF.
B	3.8.22	FRESH AIR PLANT RELOCATED AND LIFT MACHINERY ADJUSTED.
A	2.8.22	COOLING SYSTEMS REMOVED, FRESH AIR & EXTRACT SYSTEMS REVISED.

SWAN Project

tel: 0161 300 3465 fax: 0161 959 2093 E mail: info@climatmanchester.co.uk

Client: CLIMAT MANCHESTER LTD

Project: ROOF TERRACE RESTAURANT, PARSONAGE

Title: MECHANICAL LAYOUT