

6. Extract Ventilation & Odour Control Equipment details

Kitchen Extract Fan will be Flakt Woods Estoc Targe

(powerBox 80-560-3)

Data sheet enclosed, however system pressure estimated at 500pa, and will be re-calculated once final installation drawing completed.

Sound attenuator will as manufactured by Northern Fans Ltd, and will be the equivalent to 2 x Diameter, (no internal pod) and indicated in the red box on enclosed data sheets.

ESP4500 modules will be as manufactured by Purified Air Ltd