

NOTES:

1. THIS DRAWING IS COPYRIGHT AND THE PROPERTY OF BELL MUNRO CONSULTING LTD. THE DRAWING MUST NOT BE REPRODUCED IN PART OR IN WHOLE WITHOUT PRIOR WRITTEN AUTHORITY.
2. THIS DRAWING MUST NOT BE SCALED BY EITHER CONTRACTORS OR OTHER CONSULTANTS ANY DIMENSIONAL OR SETTING - OUT DISCREPANCIES ARE TO BE REPORTED TO BELL MUNRO CONSULTING PRIOR TO CONSTRUCTION / FABRICATION COMMENCING.
3. THIS DRAWING MUST BE READ IN CONJUNCTION WITH THE RELEVANT BVC SPECIFICATIONS TOGETHER WITH THE APPROPRIATE ARCHITECTS AND SERVICES CONSULTANTS DRAWINGS AND SPECIFICATIONS.


MATERIALS SPECIFICATIONS FOR CARRIAGEWAY & PRIVATE DRIVES

SURFACE COURSE : 30MM CLOSE GRADED MACADAM (CARRIAGWAY) OR 20MM CLOSE GRADED MACADAM (DRIVEWAY) TO CLAUSE 7.4 OF BS4957:PART 1, 2001 10MM NOMINAL SIZE AGGREGATE, 100 PEN BINDER

BINDER COURSE : 60MM DENSE BITUMEN MACADAM TO CLAUSE 6.5 BS4987:PART 1, 2001, 20MM NOMINAL SIZE AGGREGATE, 50 PEN BINDER

SUB BASE : TYPE I GRANULAR FILL NON FROST SUSCEPTIBLE (MCHW CLAUSE 803 OF DTP SPEC FOR HIGHWAYS WORKS)

CAPPING LAYER : THICKNESS TO BE CONFIRMED FOLLOWING CBR TEST OF SUB GRADE. SEE CBR TABLES BELOW. 6F2 OR 6F5 - MATERIAL TO BE APPROVED

 DENOTES CLOSE GRADED MACADAM WITH 10MM AGGREGATE WITH CARRIAGEWAY SPEC.

 MARSHALLS SAXON PAVING 450 X 450 X 35MM

CAPPING AND SUB-BASE THICKNESS FOR ROAD AND PARKING CONSTRUCTION			
CBR Value (%) Capping and Sub-Base (Sub-Base Only)			
<1	Special consideration required	300	
2-5	200 & 150	250	
5-10	150 & 150	200	
10-15	100 & 150	200	
15+	not applicable	150	

FOOTWAYS AROUND HOUSES TO BE 600 X 600 X 38 MARSHALL SAXON PAVING. COLOUR AS PER LANDSCAPED ARCHITECTS DRAWINGS.

EK DENOTES NEW PRECAST STANDARD CONCRETE FLAT TOP EDGING KERB - 50 X 150

NOTE: PRIVATE LEVELS INTERPOLATED USING PREVIOUS AND NEW TOPOGRAPHICAL INFORMATION. EXISTING PLOT FINISHED FLOOR LEVELS ARE ALSO ASSUMED

PROPOSED CHANGED LEVELS ARE SHOWN IN RED

