

Paul Cummings

From: Richard Cymler <Richard@ballandberry.co.uk>
Sent: 30 August 2022 14:11
To: Nick Carter
Cc: Paul Cummings; Russell Hawkins; Michael Clarkson
Subject: RE: Our Lady's - Progress Meeting Minutes

Hi Nick

This is fine as I expected – nothing further required on the ventilation details

Thanks
Richard


Richard Cymler
Regional Director

BSc, MCIQB, C Build E MCABE, DMS

M 0756 220 5664 **W** www.ballandberry.co.uk
T 0333 023 0262 **in** [linkedin](#)



PRESTON · MANCHESTER · LEEDS · BIRMINGHAM · LONDON



This email and its attachments may be confidential and are intended solely for the use of the individual to whom it is addressed. Any views or opinions expressed are solely those of the author and do not necessarily represent those of Ball & Berry Limited. If you are not the intended recipient of this email and its attachments you must take no action based upon them, nor must you copy or show them to anyone. Please contact the sender if you believe you have received this email in error. Please consider the environment before printing this email.

From: Nick Carter <nick.carter@rosslee.co.uk>
Sent: 26 August 2022 14:41
To: Richard Cymler <Richard@ballandberry.co.uk>
Cc: Paul Cummings <paul.cummings@pozzoni.co.uk>; Russell Hawkins <russell.hawkins@rosslee.co.uk>; Michael Clarkson <michael@rosslee.co.uk>
Subject: FW: Our Lady's - Progress Meeting Minutes

CAUTION: This email originated from outside your organization. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Hi Richard,

Please see the below comment regarding the extraction to the kitchen as you queried – does this satisfy?

Kind regards,



Nick Carter

Contracts Manager

Nick.carter@rosslee.co.uk

Tel: 01254 393225 (ext 220)

Fax: 01254 389982

Mob: 07976 009815

Black Abbey Street

Accrington

BB5 1HT



R Developments Limited | Company Registration No: 4459448 England | VAT Reg No: 784 2268 06
Registered Office – Black Abbey Street, Accrington BB5 1HT

This message is confidential - if you are not the intended recipient of the message, please notify the sender immediately. Any unauthorised disclosure, use or dissemination, either whole or partial, is prohibited.

Please consider the environment before printing this email

From: Geoff Ferguson <geoff.ferguson@cplbuildingservices.co.uk>

Sent: 25 August 2022 12:34

To: Nick Carter <nick.carter@rosslee.co.uk>

Cc: Paul Cummings <paul.cummings@pozzoni.co.uk>; Russell Hawkins <russell.hawkins@rosslee.co.uk>; Keith Hurst <keith.hurst@cplbuildingservices.co.uk>

Subject: RE: Our Lady's - Progress Meeting Minutes

Nick

As We understand it, the kitchen is not a “cooking “ type of kitchen where you would have a kitchen canopy with grease filters but more of a servery. The ventilation is just general supply and extract with fusible link fire dampers where the duct passes through the floors, the paragraphs 10.12 to 10.14 seem to refer to a more commercial type of kitchen.

Regards

Geoff Ferguson

Geoff Ferguson

Project Delivery : Project Manager

01772 723723 #212 : 07964 615628

ZERO HARM – SAFETY • HEALTH • ENVIRONMENT



INDUSTRIAL, COMMERCIAL & DOMESTIC
BUILDING SERVICES ENGINEERS

Unit C1, Anchorage Business Park, Chain Caul Way, Ashton on Ribble, Preston, PR2 2YL