




— — — — — Fall restraint line
Subject to further agreement with end user

Reinforced bituminous
membrane with anti-slip finish

Penthouse louvre, horizontal BWIC
opening 1000 W x 1000 L.
Louvre face area 4 x 1000 W x 750 H.
Louvre free area 1.30 m².
Fusible link fire damper fixed by welded
frame to u/s slab, 1 x 1000 W x 1000 L.



Penetrations for cable trays

[illegible]

GENERAL NOTES:

DAY Architectural Ltd accepts no responsibility for any costs, losses or claims whatsoever arising from these drawings, specifications and related documents unless there is full compliance with the Client or any unauthorised user of the following:

- 1 All boundaries, dimensions and levels are to be checked on site before construction and any discrepancies reported to the Architect / Designer.
- 2 Partial Service: Any discrepancies with site or other information is to be advised to the Architect / Designer and direction and / or approval is to be sought before the implementation of the detail.
- 3 Block and site plans are reproduced under license from the Ordnance Survey.
- 4 Do not scale this drawing.
- 5 For the purpose of coordination, all relevant parties must check this information prior to implementation and report any discrepancies to the Architect / Designer.

CLIENT	
IHP	

Manchester University
NHS Foundation Trust



PROJECT	Project RED - Electrical Infrastructure
---------	---

DRAWING

Proposed Roof Plan

SCALE
As indicated @ A2

FIRST ISSUED
10/25/22

PROJECT	CLIENT REF	DRAWN BY	CHECKED BY
1188-21	RED	AK	JC

SUITABILITY

DAY

DAY Architectural Ltd.
Studio 1, Lancaster Buildings
77 Deansgate, Manchester, M3
2BW

T: 0161 834 9703
W: www.day-architectural.com

REV	DESCRIPTION	DATE	REV BY
-----	-------------	------	--------

Information contained on this drawing is the sole copyright of DAY Architectural Ltd. and is not to be reproduced without their permission.