

Appendix F5: Daylight and Sunlight Results for Mirrored Baseline v Proposed

					VSC (WINDOW)					NSL					APSH (ROOM)						
Floor	Room	Property Type	Room Use	Window	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
					%	%		%	Criteria	%	%	SQM	%	Criteria	Annual	Winter	Annual	Winter	Annual	Winter	Criteria
River Street Tower																					
F01	R1	Residential	Bedroom	W1/F01	11.8	11.6	0.2	1.7%	YES	74.2	80.1	-1.3	-8.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Bedroom	W2/F01	10.9	10.7	0.2	1.8%	YES												
			Bedroom	W15/F01	15.6	15.6	0	0.0%	YES												
	R2 (3)	Residential	Kitchen	W3/F01	10.6	9.9	0.7	6.6%	YES	18.4	32.4	-8.2	-76.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Kitchen	W4/F01	10.1	8.4	1.7	16.8%	YES												
	R3	Residential	Bedroom	W5/F01	8.7	6.1	2.6	29.9%	NO	19	9.6	1.1	49.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	Residential	Bedroom	W6/F01	7.8	5	2.8	35.9%	NO	16.5	6.5	1.2	60.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	Residential	Bedroom	W7/F01	7	4.3	2.7	38.6%	NO	15.1	6.4	1.1	57.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	Residential	Bedroom	W8/F01	6.4	3.7	2.7	42.2%	NO	12.1	4.7	0.9	60.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	Residential	Studio-Apt	W9/F01	6.8	3.5	3.3	48.5%	NO	22.6	7	2.6	69.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	Residential	Studio-Apt	W10/F01	6.6	3	3.6	54.5%	NO	21	11.6	1.6	44.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	Residential	Studio-Apt	W11/F01	6.7	2.5	4.2	62.7%	NO	52.9	14.3	8.4	73.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Studio-Apt	W12/F01	7.3	2.3	5	68.5%	NO												
	R10	Residential	Studio-Apt	W13/F01	8.3	2.1	6.2	74.7%	NO	65.9	8.9	20.0	86.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Studio-Apt	W14/F01	10	1.9	8.1	81.0%	NO												
F02	R1	Residential	Bedroom	W1/F02	13.5	12.5	1	7.4%	YES	89.7	89.1	0.1	0.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Bedroom	W2/F02	12.7	11.4	1.3	10.2%	YES												
			Bedroom	W15/F02	19.9	19.9	0	0.0%	YES												
	R2 (3)	Residential	Kitchen	W3/F02	12.2	10.6	1.6	13.1%	YES	23.1	33.7	-6.2	-45.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Kitchen	W4/F02	11.5	9	2.5	21.7%	NO												
	R3	Residential	Bedroom	W5/F02	9.8	6.6	3.2	32.7%	NO	24.6	9.8	1.8	60.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	Residential	Bedroom	W6/F02	8.5	5.5	3	35.3%	NO	18.6	6.9	1.4	63.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	Residential	Bedroom	W7/F02	7.5	4.7	2.8	37.3%	NO	15.5	6.6	1.1	57.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	Residential	Bedroom	W8/F02	6.6	4.1	2.5	37.9%	NO	12	5.4	0.8	55.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	Residential	Studio-Apt	W9/F02	6.8	3.8	3	44.1%	NO	21.5	7.4	2.4	65.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	Residential	Studio-Apt	W10/F02	6.6	3.4	3.2	48.5%	NO	20.7	12.3	1.4	40.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	Residential	Studio-Apt	W11/F02	6.6	2.8	3.8	57.6%	NO	50	15.7	7.5	68.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Studio-Apt	W12/F02	7.1	2.5	4.6	64.8%	NO												
	R10	Residential	Studio-Apt	W13/F02	7.9	2.3	5.6	70.9%	NO	64	9.6	19.0	85.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Studio-Apt	W14/F02	9.5	2.1	7.4	77.9%	NO												
F03	R1	Residential	Bedroom	W1/F03	15.3	13.3	2	13.1%	YES	91.5	90.4	0.2	1.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
RIVER STREET TOWER (CONTINUED)																					
			BEDROOM	W2/F03	14.3	12.2	21	14.7%	YES												
			BEDROOM	W15/F03	22.1	22.1	0	0.0%	YES												
	R2 (3)	RESIDENTIAL	KITCHEN	W3/F03	13.8	11.3	2.5	18.1%	YES	30.8	35.4	-2.7	-14.9%	YES		N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN	W4/F03	12.9	9.7	3.2	24.8%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F03	10.7	7.3	3.4	31.8%	NO	28.8	10.8	2.2	62.6%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F03	9.1	6.1	3	33.0%	NO	19.7	7.5	1.5	61.8%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F03	7.8	5.3	2.5	32.1%	NO	15.5	7.5	1.0	51.3%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F03	6.8	4.6	2.2	32.4%	NO	11.8	6.3	0.7	46.8%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W9/F03	6.9	4.3	2.6	37.7%	NO	18.3	8	1.7	56.4%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	STUDIO-APT	W10/F03	6.6	3.8	2.8	42.4%	NO	20.6	13.2	1.3	36.2%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	STUDIO-APT	W11/F03	6.7	3.2	3.5	52.2%	NO	43.2	18.1	5.5	58.0%	NO		N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W12/F03	7	2.9	4.1	58.6%	NO												
	R10	RESIDENTIAL	STUDIO-APT	W13/F03	7.8	2.6	5.2	66.7%	NO	45.2	10.5	12.1	76.7%	NO		N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W14/F03	9	2.3	6.7	74.4%	NO												
F04	R1	RESIDENTIAL	BEDROOM	W1/F04	16.6	14.3	2.3	13.9%	YES	92.9	90.7	0.5	2.3%	YES		N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F04	15.5	13.1	2.4	15.5%	YES												
			BEDROOM	W15/F04	24	24	0	0.0%	YES												
	R2 (3)	RESIDENTIAL	KITCHEN	W3/F04	14.8	12.1	2.7	18.2%	YES	41.1	36.7	2.6	10.6%	YES		N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN	W4/F04	13.8	10.5	3.3	23.9%	NO												
	R3	RESIDENTIAL	BEDROOM	W5/F04	11.3	8	3.3	29.2%	NO	28.6	11.5	2.1	59.8%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W6/F04	9.5	6.8	2.7	28.4%	NO	20.1	8.2	1.5	59.0%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	BEDROOM	W7/F04	8.1	5.9	2.2	27.2%	NO	15.3	8.3	0.9	46.2%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM	W8/F04	7.1	5.2	1.9	26.8%	NO	11.7	7.1	0.6	39.6%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W9/F04	7.1	4.8	2.3	32.4%	NO	17.2	8.6	1.5	50.0%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	STUDIO-APT	W10/F04	6.8	4.3	2.5	36.8%	NO	19.9	14.2	1.0	28.5%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	STUDIO-APT	W11/F04	6.8	3.6	3.2	47.1%	NO	42.7	20.1	4.9	52.9%	NO		N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W12/F04	7.2	3.2	4	55.6%	NO												
	R10	RESIDENTIAL	STUDIO-APT	W13/F04	7.8	2.9	4.9	62.8%	NO	40.8	11.3	10.3	72.3%	NO		N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W14/F04	9.1	2.6	6.5	71.4%	NO												
F05	R1	RESIDENTIAL	BEDROOM	W1/F05	11.8	8.8	3	25.4%	NO	28.8	11.8	2.1	59.2%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM	W2/F05	10	7.6	2.4	24.0%	NO	20.2	8.6	1.4	57.5%	NO		N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
RIVER STREET TOWER (CONTINUED)																					
	R3	RESIDENTIAL	BEDROOM	W3/F05	8.4	6.7	1.7	20.2%	NO	15.3	8.9	0.8	42.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W4/F05	7.3	5.9	1.4	19.2%	YES	12	7.5	0.6	37.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W5/F05	7.3	5.5	1.8	24.7%	NO	17.2	9.2	1.3	46.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W6/F05	6.9	4.9	2	29.0%	NO	19.7	14.8	0.8	25.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W7/F05	6.2	3.9	2.3	37.1%	NO	42.5	20.6	4.8	51.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W8/F05	7.3	3.7	3.6	49.3%	NO												
	R8	RESIDENTIAL	BEDROOM	W9/F05	7.2	3	4.2	58.3%	NO	18.9	9.9	0.8	47.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W10/F05	8.5	2.6	5.9	69.4%	NO	35.2	5.3	2.7	84.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W11/F05	11	2.7	8.3	75.5%	NO	33.2	6.2	4.7	81.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W12/F05	13.5	2.6	10.9	80.7%	NO	38.7	7	5.5	81.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W13/F05	16.7	2.9	13.8	82.6%	NO	38.3	7.2	5.5	81.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F06	R1	RESIDENTIAL	BEDROOM	W1/F06	27.5	27.5	0	0.0%	YES	85.1	83.8	0.2	15%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F06	12.5	10	2.5	20.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F06	10.4	8.7	1.7	16.3%	YES	20.2	10.7	1.2	47.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F06	8.8	7.7	1.1	12.5%	YES	15.6	11	0.6	29.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F06	7.6	6.9	0.7	9.2%	YES	11.8	10.1	0.2	13.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F06	7.6	6.4	1.2	15.8%	YES	17.3	11.2	1.0	35.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F06	7.2	5.8	1.4	19.4%	YES	20.7	17	0.6	18.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F06	6.3	4.7	1.6	25.4%	NO	44	23.4	4.5	46.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F06	7.4	4.3	3.1	41.9%	NO												
	R8	RESIDENTIAL	BEDROOM	W10/F06	7.3	3.5	3.8	52.1%	NO	18.9	12.4	0.6	34.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F06	8.5	3	5.5	64.7%	NO	35.4	5.8	2.7	83.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F06	11.1	2.9	8.2	73.9%	NO	33.2	6.9	4.6	79.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F06	13.7	2.9	10.8	78.8%	NO	38.6	7.4	5.5	80.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F06	16.8	3	13.8	82.1%	NO	38.4	8	5.3	79.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F06	19	19	0	0.0%	YES	97	97	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W16/F06	27.6	27.6	0	0.0%	YES												
F07	R1	RESIDENTIAL	BEDROOM	W1/F07	28.3	28.3	0	0.0%	YES	85.3	84	0.2	15%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F07	13	11.3	1.7	13.1%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F07	10.9	10	0.9	8.3%	YES	20.2	13.2	0.9	34.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F07	9.1	9	0.1	11%	YES	15.8	13.6	0.3	14.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
RIVER STREET TOWER (CONTINUED)																					
	R4	RESIDENTIAL	BEDROOM	W5/F07	7.9	8.1	-0.2	-2.5%	YES	12.1	12.3	0.0	-1.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F07	7.8	7.5	0.3	3.8%	YES	17.2	13.1	0.7	23.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F07	7.3	6.9	0.4	5.5%	YES	20.6	20.1	0.1	2.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F07	6.5	5.7	0.8	12.3%	YES	44.9	25.9	4.2	42.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F07	7.5	5	2.5	33.3%	NO						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F07	7.4	4.1	3.3	44.6%	NO	18.5	14.7	0.3	20.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F07	8.6	3.4	5.2	60.5%	NO	36	5.7	2.8	84.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F07	11.2	3.2	8	71.4%	NO	33.3	7.1	4.6	78.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F07	13.8	3.1	10.7	77.5%	NO	39	8	5.4	79.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F07	16.9	3.2	13.7	81.1%	NO	38.3	8.3	5.2	78.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F07	19.6	19.7	-0.1	-0.5%	YES	96.9	96.9	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F08			BEDROOM	W16/F07	28.5	28.5	0	0.0%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	RESIDENTIAL	BEDROOM	W1/F08	29	29	0	0.0%	YES	85.5	84.1	0.2	15%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F08	13.6	12.9	0.7	5.1%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM	W3/F08	11.3	11.6	-0.3	-2.7%	YES	20.2	16.7	0.4	17.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F08	9.5	10.6	-1.1	-11.6%	YES	15.9	17.4	-0.2	-9.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F08	8.1	9.6	-1.5	-18.5%	YES	11.8	16.1	-0.5	-35.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F08	8.1	8.9	-0.8	-9.9%	YES	17.4	16.6	0.1	4.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F08	7.5	8.2	-0.7	-9.3%	YES	20.5	23.5	-0.5	-14.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F08	6.6	6.8	-0.2	-3.0%	YES	45.5	29.4	3.5	35.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				STUDIO-APT	W9/F08	7.7	5.9	1.8	23.4%	NO						N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F08	7.5	4.7	2.8	37.3%	NO	19.2	17	0.2	11.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F08	8.7	3.8	4.9	56.3%	NO	35.9	5.7	2.8	84.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F08	11.3	3.6	7.7	68.1%	NO	33.5	7.7	4.5	77.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F08	13.9	3.3	10.6	76.3%	NO	39.1	7.9	5.5	79.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F08	17.1	3.3	13.8	80.7%	NO	38.4	8.8	5.2	77.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F08	20.2	20.3	-0.1	-0.5%	YES	97.4	97.4	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F09			BEDROOM	W16/F08	29	29	0	0.0%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	RESIDENTIAL	BEDROOM	W1/F09	29.7	29.7	0	0.0%	YES	85	84.1	0.1	11%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F09	14.2	14.8	-0.6	-4.2%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM	W3/F09	11.8	13.5	-1.7	-14.4%	YES	20.1	23.4	-0.4	-16.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
RIVER STREET TOWER (CONTINUED)																					
	R3	RESIDENTIAL	BEDROOM	W4/F09	9.8	12.5	-2.7	-27.6%	YES	15.7	23.8	-1.0	-51.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F09	8.4	11.5	-3.1	-36.9%	YES	11.7	21.5	-1.2	-83.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F09	8.3	10.6	-2.3	-27.7%	YES	17.5	21.6	-0.7	-23.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F09	7.7	9.8	-2.1	-27.3%	YES	20.6	29.5	-1.5	-43.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F09	6.7	8.2	-1.5	-22.4%	YES	46.1	34.3	2.6	25.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F09	7.8	6.9	0.9	11.5%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F09	7.6	5.5	2.1	27.6%	NO	19.6	19.2	0.0	2.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F09	8.9	4.4	4.5	50.6%	NO	35.5	6.1	2.7	82.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F09	11.4	3.9	7.5	65.8%	NO	33.4	7.6	4.5	77.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F09	14	3.5	10.5	75.0%	NO	38.8	7.9	5.4	79.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F09	17.2	3.5	13.7	79.7%	NO	38.4	8.8	5.2	77.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R13	RESIDENTIAL	BEDROOM	W15/F09	20.8	21	-0.2	-1.0%	YES	97.3	97.3	0.0	0.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W16/F09	29.5	29.5	0	0.0%	YES												
F10	R1	RESIDENTIAL	BEDROOM	W1/F10	30.4	30.4	0	0.0%	YES	85.4	84.2	0.1	1.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F10	14.7	16.3	-1.6	-10.9%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F10	12.2	15.1	-2.9	-23.8%	YES	20.1	28.8	-1.1	-43.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F10	10.2	14.1	-3.9	-38.2%	YES	15.8	29.1	-1.6	-84.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F10	8.7	13.1	-4.4	-50.6%	YES	11.8	26	-1.7	-119.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F10	8.5	12.2	-3.7	-43.5%	YES	17.5	26.9	-1.6	-54.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F10	7.9	11.3	-3.4	-43.0%	YES	20.8	38.1	-2.9	-83.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F10	6.9	9.3	-2.4	-34.8%	YES	46.1	43.7	0.5	5.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F10	7.9	7.9	0	0.0%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F10	7.7	6.3	1.4	18.2%	YES	18.9	21.1	-0.2	-11.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F10	9	4.9	4.1	45.6%	NO	35.6	5.4	2.8	84.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F10	11.5	4.3	7.2	62.6%	NO	33.3	7.5	4.5	77.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F10	14.1	3.8	10.3	73.0%	NO	39.1	8	5.4	79.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F10	17.3	3.7	13.6	78.6%	NO	38.7	8.8	5.2	77.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F11	R1	RESIDENTIAL	BEDROOM	W1/F11	30.8	30.8	0	0.0%	YES	85	84.1	0.1	1.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F11	15.1	17.6	-2.5	-16.6%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F11	12.6	16.5	-3.9	-31.0%	YES	20	32.8	-1.6	-64.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F11	10.5	15.4	-4.9	-46.7%	YES	15.8	32.9	-2.1	-108.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY	ROOM	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
		TYPE	USE		%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
RIVER STREET TOWER (CONTINUED)																					
	R4	RESIDENTIAL	BEDROOM	W5/F11	9	14.4	-5.4	-60.0%	YES	116	29.2	-2.2	-151.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F11	8.8	13.5	-4.7	-53.4%	YES	17.4	29.7	-2.1	-70.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F11	8.1	12.5	-4.4	-54.3%	YES	20.6	44.7	-4.1	-116.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F11	7.1	10.3	-3.2	-45.1%	YES	46.4	56.1	-2.1	-20.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F11	8	8.8	-0.8	-10.0%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F11	7.9	7	0.9	11.4%	YES	19	22.2	-0.3	-16.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F11	9.1	5.5	3.6	39.6%	NO	35.8	5.7	2.8	84.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F11	11.7	4.7	7	59.8%	NO	33.3	7.3	4.6	78.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F11	14.2	4	10.2	71.8%	NO	39	8.1	5.4	79.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F11	17.4	3.8	13.6	78.2%	NO	38.4	8.9	5.2	77.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F12	R1	RESIDENTIAL	BEDROOM	W1/F12	31.2	31.2	0	0.0%	YES	85.3	83.9	0.2	1.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F12	15.5	18.8	-3.3	-21.3%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM	W3/F12	13	17.8	-4.8	-36.9%	YES	20.1	37.4	-2.1	-85.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F12	10.9	16.7	-5.8	-53.2%	YES	15.9	37.2	-2.6	-133.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F12	9.3	15.7	-6.4	-68.8%	YES	11.9	33.3	-2.6	-181.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F12	9	14.7	-5.7	-63.3%	YES	17.3	33.1	-2.7	-90.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F12	8.3	13.7	-5.4	-65.1%	YES	20.6	49.2	-4.8	-138.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F12	7.2	11.3	-4.1	-56.9%	YES	46.4	63.9	-3.8	-37.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F12	8.2	9.5	-1.3	-15.9%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM	W10/F12	8	7.5	0.5	6.2%	YES	18.5	22.6	-0.4	-22.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F12	9.2	5.9	3.3	35.9%	NO	35.6	5.6	2.7	84.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F12	11.8	5	6.8	57.6%	NO	33.3	7.4	4.5	77.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F12	14.3	4.2	10.1	70.6%	NO	38.8	8.1	5.4	79.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F12	17.5	3.9	13.6	77.7%	NO	38.3	8.7	5.2	77.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F13	R1	RESIDENTIAL	BEDROOM	W1/F13	31.5	31.5	0	0.0%	YES	85.4	84.2	0.1	1.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F13	15.9	19.9	-4	-25.2%	YES						N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM	W3/F13	13.4	18.8	-5.4	-40.3%	YES	20.2	43.8	-2.9	-116.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F13	11.3	17.8	-6.5	-57.5%	YES	15.7	43.2	-3.4	-174.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F13	9.6	16.6	-7	-72.9%	YES	12.2	38.2	-3.2	-214.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F13	9.3	15.7	-6.4	-68.8%	YES	17.5	37.4	-3.4	-113.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F13	8.5	14.5	-6	-70.6%	YES	21.1	54.5	-5.7	-158.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
RIVER STREET TOWER (CONTINUED)																					
	R7	RESIDENTIAL	STUDIO-APT	W8/F13	7.4	11.8	-4.4	-59.5%	YES	46.4	68.1	-4.7	-46.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F13	8.3	10	-1.7	-20.5%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F13	8.2	7.8	0.4	4.9%	YES	19	22.8	-0.3	-19.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F13	9.4	6	3.4	36.2%	NO	35.9	5.8	2.7	83.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F13	11.9	5.1	6.8	57.1%	NO	33.5	7.5	4.6	77.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F13	14.5	4.3	10.2	70.3%	NO	38.7	8	5.4	79.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F13	17.6	4	13.6	77.3%	NO	38.7	8.7	5.2	77.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F14	R1	RESIDENTIAL	BEDROOM	W1/F14	31.8	31.8	0	0.0%	YES	85.5	84.2	0.2	15%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F14	16.3	21	-4.7	-28.8%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F14	13.8	19.8	-6	-43.5%	YES	20.3	51.4	-3.8	-152.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F14	11.6	18.7	-7.1	-61.2%	YES	15.7	50.3	-4.2	-220.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F14	10	17.5	-7.5	-75.0%	YES	11.9	44.6	-4.0	-276.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F14	9.5	16.5	-7	-73.7%	YES	17.5	42.3	-4.2	-141.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F14	8.8	15.3	-6.5	-73.9%	YES	20.7	60.6	-6.7	-192.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F14	7.6	12.4	-4.8	-63.2%	YES	46.5	72.4	-5.6	-55.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F14	8.5	10.4	-1.9	-22.4%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F14	8.3	8.1	0.2	2.4%	YES	18.4	23	-0.4	-25.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F14	9.6	6.2	3.4	35.4%	NO	35.5	5.7	2.7	83.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F14	12.1	5.2	6.9	57.0%	NO	33.4	7.5	4.5	77.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F14	14.6	4.3	10.3	70.5%	NO	39.1	7.8	5.5	80.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F14	17.8	4	13.8	77.5%	NO	38.6	8.4	5.3	78.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F15	R1	RESIDENTIAL	BEDROOM	W1/F15	32.1	32.1	0	0.0%	YES	85.5	84.6	0.1	11%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F15	16.7	22	-5.3	-31.7%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F15	14.2	20.8	-6.6	-46.5%	YES	20.9	60.2	-4.8	-188.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F15	12	19.6	-7.6	-63.3%	YES	16.5	56.7	-4.9	-244.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F15	10.3	18.3	-8	-77.7%	YES	13	51.3	-4.7	-293.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F15	9.8	17.3	-7.5	-76.5%	YES	17.6	46.5	-4.9	-165.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F15	9	16	-7	-77.8%	YES	21.2	67.3	-7.8	-216.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F15	7.8	12.9	-5.1	-65.4%	YES	47	76.1	-6.4	-62.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F15	8.7	10.8	-2.1	-24.1%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F15	8.5	8.3	0.2	2.4%	YES	18.7	23.1	-0.4	-23.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MIL	PR	LOSS	LOSS	MEETS	MIL	PR	LOSS	LOSS	MEETS	MIL		PR		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
RIVER STREET TOWER (CONTINUED)																					
	R9	RESIDENTIAL	BEDROOM	W11/F15	9.8	6.3	3.5	35.7%	NO	35.3	6	2.7	83.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F15	12.3	5.3	7	56.9%	NO	33.7	7.3	4.6	78.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F15	14.8	4.4	10.4	70.3%	NO	39.6	8	5.5	79.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F15	18	4.1	13.9	77.2%	NO	39.2	8.5	5.4	78.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F16	R1	RESIDENTIAL	BEDROOM	W1/F16	32.4	32.4	0	0.0%	YES	85.1	85.9	-0.1	-0.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F16	17.1	23	-5.9	-34.5%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F16	14.6	21.8	-7.2	-49.3%	YES	21.1	68.5	-5.8	-224.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F16	12.4	20.5	-8.1	-65.3%	YES	16.4	64.5	-5.9	-293.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F16	10.6	19.2	-8.6	-81.1%	YES	12.8	60.2	-5.8	-371.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F16	10.1	18.1	-8	-79.2%	YES	17.7	51.7	-5.7	-192.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F16	9.3	16.7	-7.4	-79.6%	YES	20.8	75.4	-9.2	-262.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F16	8.1	13.5	-5.4	-66.7%	YES	47	79.6	-7.1	-69.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F16	9	11.2	-2.2	-24.4%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F16	8.8	8.6	0.2	2.3%	YES	18.9	23.2	-0.4	-22.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F16	10	6.4	3.6	36.0%	NO	35.5	6.5	2.6	81.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F16	12.5	5.4	7.1	56.8%	NO	33.7	7.7	4.5	77.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F16	15	4.5	10.5	70.0%	NO	39.3	8	5.5	79.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F16	18.1	4.1	14	77.3%	NO	38.9	8.7	5.3	77.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F17	R1	RESIDENTIAL	BEDROOM	W1/F17	32.7	32.7	0	0.0%	YES	85.5	89.5	-0.5	-4.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F17	17.5	23.9	-6.4	-36.6%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F17	14.9	22.7	-7.8	-52.3%	YES	21.2	75.9	-6.7	-258.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F17	12.8	21.4	-8.6	-67.2%	YES	16.8	73.2	-6.9	-335.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F17	11	20	-9	-81.8%	YES	13.3	68.3	-6.8	-413.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F17	10.5	19	-8.5	-81.0%	YES	17.9	57.5	-6.7	-221.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F17	9.6	17.5	-7.9	-82.3%	YES	21.7	83.9	-10.5	-287.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F17	8.4	14	-5.6	-66.7%	YES	47.4	82.3	-7.6	-73.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F17	9.2	11.6	-2.4	-26.1%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F17	9	8.8	0.2	2.2%	YES	21.3	22.7	-0.1	-7.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F17	10.3	6.6	3.7	35.9%	NO	37.8	5.7	2.9	84.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F17	12.8	5.5	7.3	57.0%	NO	33.9	7.6	4.6	77.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F17	15.3	4.5	10.8	70.6%	NO	39.5	8.1	5.5	79.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
RIVER STREET TOWER (CONTINUED)																					
F18	R12	RESIDENTIAL	STUDIO-APT	W14/F17	18.4	4.2	14.2	77.2%	NO	39.3	8.8	5.3	77.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	RESIDENTIAL	BEDROOM	W1/F18	32.9	32.9	0	0.0%	YES	85.2	92	-0.8	-7.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F18	17.8	24.8	-7	-39.3%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F18	15.3	23.5	-8.2	-53.6%	YES	21.4	79.5	-7.1	-272.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F18	13.1	22.2	-9.1	-69.5%	YES	17	77.5	-7.4	-355.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F18	11.3	20.8	-9.5	-84.1%	YES	13.2	72	-7.2	-446.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F18	10.8	19.7	-8.9	-82.4%	YES	17.9	62	-7.5	-246.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F18	10	18.2	-8.2	-82.0%	YES	21.5	88.5	-11.3	-311.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F18	8.7	14.5	-5.8	-66.7%	YES	47.4	83.7	-7.9	-76.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				STUDIO-APT	W9/F18	9.6	12	-2.4	-25.0%	YES											
F19	R8	RESIDENTIAL	BEDROOM	W10/F18	9.4	8.9	0.5	5.3%	YES	21.8	23.1	-0.1	-5.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F18	10.6	6.6	4	37.7%	NO	37.9	6.1	2.9	83.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F18	13.1	5.6	7.5	57.3%	NO	34	7.8	4.6	77.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F18	15.5	4.6	10.9	70.3%	NO	39.6	8.2	5.5	79.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F18	18.6	4.2	14.4	77.4%	NO	39.3	8.6	5.4	78.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	RESIDENTIAL	BEDROOM	W1/F19	33.1	33.1	0	0.0%	YES	85.3	92.2	-0.8	-8.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F19	18.2	25.6	-7.4	-40.7%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F19	15.6	24.3	-8.7	-55.8%	YES	21.5	79.5	-7.1	-269.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F19	13.5	23	-9.5	-70.4%	YES	17.2	77.9	-7.5	-352.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F19	11.7	21.5	-9.8	-83.8%	YES	13.6	72.3	-7.2	-431.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F20	R5	RESIDENTIAL	STUDIO-APT	W6/F19	11.2	20.4	-9.2	-82.1%	YES	18.3	62.6	-7.5	-242.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F19	10.3	18.8	-8.5	-82.5%	YES	21.6	88.6	-11.3	-309.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F19	9.2	14.9	-5.7	-62.0%	YES	47.8	84	-7.9	-75.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F19	9.9	12.3	-2.4	-24.2%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F19	9.7	9.1	0.6	6.2%	YES	21.8	22.8	-0.1	-4.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F19	10.9	6.7	4.2	38.5%	NO	37.9	5.7	2.9	85.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F19	13.4	5.7	7.7	57.5%	NO	34.4	7.8	4.7	77.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F19	15.9	4.7	11.2	70.4%	NO	39.8	7.8	5.6	80.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F19	18.9	4.3	14.6	77.2%	NO	40	8.6	5.5	78.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	RESIDENTIAL	BEDROOM	W1/F20	33.2	33.2	0	0.0%	YES	85.3	92.1	-0.8	-7.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F20	18.6	26.4	-7.8	-41.9%	YES												

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY	ROOM	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
		TYPE	USE		%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
RIVER STREET TOWER (CONTINUED)																					
	R2	RESIDENTIAL	BEDROOM	W3/F20	16.1	25.1	-9	-55.9%	YES	22.1	79.7	-7.1	-260.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F20	14	23.7	-9.7	-69.3%	YES	17.6	78	-7.4	-343.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F20	12.2	22.2	-10	-82.0%	YES	13.9	72.1	-7.2	-419.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F20	11.7	21.1	-9.4	-80.3%	YES	18.6	62.8	-7.5	-238.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F20	10.8	19.4	-8.6	-79.6%	YES	22	88.6	-11.2	-302.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F20	9.7	15.3	-5.6	-57.7%	YES	48.5	84.1	-7.8	-73.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F20	10.4	12.6	-2.2	-21.2%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F20	10.2	9.2	1	9.8%	YES	22.4	22.5	0.0	-0.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F20	11.4	6.8	4.6	40.4%	NO	38.7	6	3.0	84.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F20	13.8	5.8	8	58.0%	NO	34.5	7.4	4.7	78.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F20	16.2	4.8	11.4	70.4%	NO	40.4	8	5.7	80.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F20	19.3	4.4	14.9	77.2%	NO	39.9	8.6	5.5	78.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F21	R1	RESIDENTIAL	BEDROOM	W1/F21	33.4	33.4	0	0.0%	YES	85.9	92.1	-0.8	-7.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F21	19.1	27	-7.9	-41.4%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F21	16.6	25.7	-9.1	-54.8%	YES	23	79.7	-7.0	-246.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F21	14.5	24.3	-9.8	-67.6%	YES	18.5	78	-7.3	-322.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F21	12.8	22.8	-10	-78.1%	YES	14.9	72.4	-7.1	-386.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F21	12.2	21.7	-9.5	-77.9%	YES	19	62.9	-7.4	-231.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F21	11.4	20	-8.6	-75.4%	YES	22.5	88.6	-11.2	-293.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F21	10.3	15.7	-5.4	-52.4%	YES	49.5	84.1	-7.6	-70.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F21	11	12.9	-1.9	-17.3%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F21	10.8	9.4	1.4	13.0%	YES	23.3	22.7	0.0	2.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F21	12	6.8	5.2	43.3%	NO	39	6	3.0	84.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F21	14.3	5.8	8.5	59.4%	NO	35	7.6	4.8	78.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F21	16.7	4.9	11.8	70.7%	NO	40.6	7.9	5.7	80.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F21	19.7	4.5	15.2	77.2%	NO	40.6	8.9	5.6	78.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F22	R1	RESIDENTIAL	BEDROOM	W1/F22	33.5	33.5	0	0.0%	YES	86.2	92.2	-0.7	-6.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F22	19.6	27.5	-7.9	-40.3%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F22	17.2	26.2	-9	-52.3%	YES	23.6	79.7	-6.9	-237.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F22	15.1	24.7	-9.6	-63.6%	YES	19.1	78.1	-7.3	-309.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F22	13.4	23.2	-9.8	-73.1%	YES	15.7	72.3	-7.0	-361.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	
RIVER STREET TOWER (CONTINUED)																					
	R5	RESIDENTIAL	STUDIO-APT	W6/F22	12.9	22.1	-9.2	-71.3%	YES	19.6	62.8	-7.3	-221.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F22	12.1	20.4	-8.3	-68.6%	YES	22.8	88.6	-11.1	-288.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F22	11	15.9	-4.9	-44.5%	YES	49.9	84	-7.5	-68.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F22	11.7	13.1	-1.4	-12.0%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F22	11.5	9.4	2.1	18.3%	YES	24.3	23.1	0.1	4.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F22	12.6	6.8	5.8	46.0%	NO	39.8	6	3.1	84.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F22	14.9	5.9	9	60.4%	NO	35.6	7.4	4.9	79.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F22	17.3	4.9	12.4	71.7%	NO	41.2	8.3	5.7	79.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F22	20.2	4.5	15.7	77.7%	NO	41.3	8.9	5.7	78.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F23	R1	RESIDENTIAL	BEDROOM	W1/F23	33.6	33.6	0	0.0%	YES	86.3	92	-0.7	-6.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F23	20.3	27.6	-7.3	-36.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F23	17.9	26.3	-8.4	-46.9%	YES	24.7	79.6	-6.8	-222.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F23	15.9	24.8	-8.9	-56.0%	YES	20.4	78.1	-7.1	-282.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F23	14.3	23.3	-9	-62.9%	YES	17	72.2	-6.8	-325.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F23	13.7	22.2	-8.5	-62.0%	YES	20.5	62.9	-7.2	-206.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F23	12.9	20.5	-7.6	-58.9%	YES	23.9	88.6	-10.9	-270.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F23	11.9	15.9	-4	-33.6%	YES	50.7	84.2	-7.3	-66.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F23	12.5	13.2	-0.7	-5.6%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F23	12.4	9.5	2.9	23.4%	NO	26.7	23.1	0.3	13.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F23	13.5	6.8	6.7	49.6%	NO	41.2	5.6	3.3	86.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F23	15.7	6	9.7	61.8%	NO	36.4	7.7	5.0	78.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F23	18	5	13	72.2%	NO	42	8.2	5.9	80.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F23	20.8	4.6	16.2	77.9%	NO	42.1	8.9	5.8	78.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F24	R1	RESIDENTIAL	BEDROOM	W1/F24	33.7	33.7	0	0.0%	YES	87.5	92.2	-0.6	-5.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F24	21.1	27.7	-6.6	-31.3%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F24	18.8	26.4	-7.6	-40.4%	YES	26.3	79.9	-6.6	-204.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F24	16.9	25	-8.1	-47.9%	YES	22	78.3	-6.9	-256.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F24	15.3	23.4	-8.1	-52.9%	YES	18.6	72.3	-6.6	-289.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F24	14.8	22.3	-7.5	-50.7%	YES	21.6	63	-7.0	-192.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F24	14	20.6	-6.6	-47.1%	YES	24.7	88.6	-10.8	-258.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F24	13.1	16	-2.9	-22.1%	YES	51.9	84.2	-7.1	-62.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS						MI.		PR.		LOSS %		MEETS CRITERIA
					%	%		%	CRITERIA						%	%	SQM	%	CRITERIA	ANNUAL	
RIVER STREET TOWER (CONTINUED)																					
			STUDIO-APT	W9/F24	13.6	13.3	0.3	2.2%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F24	13.5	9.5	4	29.6%	NO	29.3	22.5	0.6	231%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F24	14.6	6.9	7.7	52.7%	NO	42.8	6	3.4	85.9%	NO		N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F24	16.7	6.1	10.6	63.5%	NO	37.3	7.5	5.2	79.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F24	18.8	5.1	13.7	72.9%	NO	42.8	8.1	6.1	81.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F24	21.6	4.7	16.9	78.2%	NO	43.3	8.7	6.1	79.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F25	R1	RESIDENTIAL	BEDROOM	W1/F25	33.8	33.8	0	0.0%	YES	87.8	92	-0.5	-4.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F25	22.1	27.9	-5.8	-26.2%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F25	19.9	26.5	-6.6	-33.2%	YES	29.5	80	-6.2	-171.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F25	18.1	25.1	-7	-38.7%	YES	25.1	78.2	-6.5	-211.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F25	16.7	23.5	-6.8	-40.7%	YES	22.1	72.5	-6.2	-228.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F25	16.1	22.4	-6.3	-39.1%	YES	23.9	63	-6.6	-163.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F25	15.4	20.7	-5.3	-34.4%	YES	26.9	88.7	-10.4	-229.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F25	14.5	16.1	-1.6	-11.0%	YES	51.9	84.3	-7.1	-62.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F25	15	13.3	1.7	11.3%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F25	15	9.6	5.4	36.0%	NO	32.5	23.2	0.9	28.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F25	15.9	7	8.9	56.0%	NO	44.8	5.9	3.6	86.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F25	17.9	6.2	11.7	65.4%	NO	39	7.6	5.5	80.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F25	19.9	5.2	14.7	73.9%	NO	44.5	7.9	6.4	82.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F25	22.6	4.8	17.8	78.8%	NO	45.1	9	6.3	80.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F26	R1	RESIDENTIAL	BEDROOM	W1/F26	33.9	33.9	0	0.0%	YES	88.5	92.1	-0.4	-4.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F26	23.4	28	-4.6	-19.7%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F26	21.4	26.7	-5.3	-24.8%	YES	32.6	80.1	-5.8	-145.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F26	19.7	25.3	-5.6	-28.4%	YES	28.8	78.6	-6.1	-172.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F26	18.3	23.6	-5.3	-29.0%	YES	26.3	72.6	-5.7	-176.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F26	17.7	22.6	-4.9	-27.7%	YES	27	63.1	-6.1	-133.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F26	17.1	20.8	-3.7	-21.6%	YES	29.7	88.6	-9.9	-198.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F26	16.4	16.2	0.2	1.2%	YES	52.1	84.3	-7.0	-61.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F26	16.8	13.5	3.3	19.6%	YES												
	R8	RESIDENTIAL	BEDROOM	W10/F26	16.8	9.8	7	41.7%	NO	37.6	23.2	1.3	38.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F26	17.7	7.2	10.5	59.3%	NO	47.8	6.3	3.8	86.7%	NO		N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
Floor	Room	Property Type	Room Use	Window	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
					%	%		%	Criteria	%	%	SQM	%	Criteria	Annual	Winter	Annual	Winter	Annual	Winter	Criteria
River Street Tower (Continued)																					
F27	R10 (3)	Residential	Studio-Apt	W12/F26	19.4	6.3	13.1	67.5%	NO	41.2	7.9	5.8	80.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	Residential	Studio-Apt	W13/F26	21.3	5.3	16	75.1%	NO	46.4	8.2	6.7	82.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	Residential	Studio-Apt	W14/F26	23.8	4.9	18.9	79.4%	NO	47.5	9.2	6.7	80.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	Residential	Bedroom	W1/F27	34	34	0	0.0%	YES	89.1	91.9	-0.3	-3.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Bedroom	W2/F27	24.9	28.2	-3.3	-13.3%	YES												
	R2	Residential	Bedroom	W3/F27	23.1	26.9	-3.8	-16.5%	YES	37.5	80.5	-5.3	-114.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	Residential	Bedroom	W4/F27	21.6	25.4	-3.8	-17.6%	YES	33.9	78.7	-5.5	-132.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	Residential	Bedroom	W5/F27	20.4	23.8	-3.4	-16.7%	YES	32.2	72.5	-5.0	-125.1%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	Residential	Studio-Apt	W6/F27	19.8	22.7	-2.9	-14.6%	YES	31.8	63.1	-5.3	-98.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F28	R6	Residential	Studio-Apt	W7/F27	19.3	20.9	-1.6	-8.3%	YES	33.5	88.6	-9.3	-164.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	Residential	Studio-Apt	W8/F27	18.7	16.4	2.3	12.3%	YES	52.2	84.3	-7.0	-61.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Studio-Apt	W9/F27	19	13.6	5.4	28.4%	NO												
	R8	Residential	Bedroom	W10/F27	19.1	9.9	9.2	48.2%	NO	45.5	23	2.1	49.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	Residential	Bedroom	W11/F27	19.8	7.3	12.5	63.1%	NO	52.8	5.8	4.3	89.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	Residential	Studio-Apt	W12/F27	21.3	6.5	14.8	69.5%	NO	44	8	6.3	81.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	Residential	Studio-Apt	W13/F27	23.1	5.5	17.6	76.2%	NO	49	8.5	7.1	82.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	Residential	Studio-Apt	W14/F27	25.3	5.1	20.2	79.8%	NO	50.4	9.1	7.2	82.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R1	Residential	Bedroom	W1/F28	34.1	34.1	0	0.0%	YES	90	92.1	-0.3	-2.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Bedroom	W2/F28	26.8	28.5	-1.7	-6.3%	YES												
	R2	Residential	Bedroom	W3/F28	25.3	27.1	-1.8	-7.1%	YES	45.2	80.8	-4.4	-78.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	Residential	Bedroom	W4/F28	24	25.7	-1.7	-7.1%	YES	42.6	78.8	-4.4	-84.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	Residential	Bedroom	W5/F28	23	24	-1	-4.3%	YES	42.1	72.5	-3.7	-72.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	Residential	Studio-Apt	W6/F28	22.4	22.9	-0.5	-2.2%	YES	40	63.2	-3.9	-57.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	Residential	Studio-Apt	W7/F28	21.9	21.1	0.8	3.7%	YES	40.2	88.7	-8.2	-120.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	Residential	Studio-Apt	W8/F28	21.5	16.5	5	23.3%	NO	54.5	84.1	-6.5	-54.2%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Studio-Apt	W9/F28	21.7	13.8	7.9	36.4%	NO												
	R8	Residential	Bedroom	W10/F28	21.9	10.1	11.8	53.9%	NO	59.3	22.6	3.3	61.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	Residential	Bedroom	W11/F28	22.5	7.5	15	66.7%	NO	62	5.5	5.2	91.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	Residential	Studio-Apt	W12/F28	23.7	6.7	17	71.7%	NO	49	8.6	7.1	82.5%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	Residential	Studio-Apt	W13/F28	25.2	5.7	19.5	77.4%	NO	53.5	9	7.8	83.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	Residential	Studio-Apt	W14/F28	27.1	5.3	21.8	80.4%	NO	55.4	9.4	8.0	83.0%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)						
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	WINDOW	MI.	PR.	LOSS	LOSS	MEETS	MI.	PR.	LOSS	LOSS	MEETS	MI.		PR.		LOSS %		MEETS
					%	%		%	CRITERIA	%	%	SQM	%	CRITERIA	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA
RIVER STREET TOWER (CONTINUED)																					
F29	R1	RESIDENTIAL	BEDROOM	W1/F29	34.2	34.2	0	0.0%	YES	90	92	-0.2	-2.2%	YES							
			BEDROOM	W2/F29	29	28.7	0.3	1.0%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F29	27.8	27.4	0.4	1.4%	YES	59.1	81.3	-2.7	-37.6%	YES							
	R3	RESIDENTIAL	BEDROOM	W4/F29	26.8	25.9	0.9	3.4%	YES	58.3	79.5	-2.6	-36.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F29	26	24.3	1.7	6.5%	YES	58.1	73.4	-1.9	-26.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F29	25.5	23.1	2.4	9.4%	YES	55	63.6	-1.5	-15.8%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F29	25.1	21.3	3.8	15.1%	YES	54.3	89.4	-5.9	-64.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F29	24.9	16.8	8.1	32.5%	NO	62.9	85.3	-4.9	-35.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F29	24.9	14	10.9	43.8%	NO												
	R8	RESIDENTIAL	BEDROOM	W10/F29	25.1	10.4	14.7	58.6%	NO	80.8	22.6	5.3	72.1%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F29	25.6	7.8	17.8	69.5%	NO	79.8	6.6	6.7	91.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F29	26.5	6.9	19.6	74.0%	NO	58.6	8.3	8.8	85.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F29	27.7	5.9	21.8	78.7%	NO	61.5	8.8	9.2	85.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	STUDIO-APT	W14/F29	29.2	5.5	23.7	81.2%	NO	63.3	9.4	9.4	85.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F30	R1	RESIDENTIAL	BEDROOM	W1/F30	34.3	34.3	0	0.0%	YES	91.3	92.2	-0.1	-1.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F30	31.4	29.1	2.3	7.3%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F30	30.6	27.7	2.9	9.5%	YES	82.8	81.9	0.1	1.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM	W4/F30	29.9	26.3	3.6	12.0%	YES	82.7	80.3	0.3	2.9%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM	W5/F30	29.3	24.6	4.7	16.0%	YES	83	74.5	1.1	10.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	STUDIO-APT	W6/F30	28.9	23.4	5.5	19.0%	YES	79.6	64	2.6	19.6%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	STUDIO-APT	W7/F30	28.7	21.6	7.1	24.7%	NO	78.8	89.4	-1.8	-13.4%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	STUDIO-APT	W8/F30	28.6	17	11.6	40.6%	NO	81.9	86.2	-0.9	-5.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			STUDIO-APT	W9/F30	28.5	14.3	14.2	49.8%	NO												
	R8	RESIDENTIAL	BEDROOM	W10/F30	28.7	10.7	18	62.7%	NO	97.5	25.1	6.6	74.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM	W11/F30	29.1	8.1	21	72.2%	NO	96	8	8.0	91.7%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F30	29.7	7.2	22.5	75.8%	NO	79.7	8.9	12.4	88.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F30	30.5	6.3	24.2	79.3%	NO	80.1	9.2	12.4	88.6%	NO							
	R12	RESIDENTIAL	STUDIO-APT	W14/F30	31.6	5.9	25.7	81.3%	NO	80.1	9.9	12.3	87.6%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F31	R1	RESIDENTIAL	BEDROOM	W1/F31	34.4	34.4	0	0.0%	YES	97.9	92.2	0.7	5.7%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM	W2/F31	33.9	29.4	4.5	13.3%	YES												
	R2	RESIDENTIAL	BEDROOM	W3/F31	33.4	28.1	5.3	15.9%	YES	96.9	82.9	1.7	14.5%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A

					VSC (WINDOW)					NSL					APSH (ROOM)							
FLOOR	ROOM	PROPERTY	ROOM	WINDOW	M.I.	PR.	LOSS	LOSS	MEETS	M.I.	PR.	LOSS	LOSS	MEETS	M.I.		PR.		LOSS %		MEETS	
		TYPE	USE	%	%		%	CRITERIA	ANNUAL						WINTER	ANNUAL	WINTER	ANNUAL	WINTER	CRITERIA		
RIVER STREET TOWER (CONTINUED)																						
	R3	RESIDENTIAL	BEDROOM	W4/F31	33.1	26.6	6.5	19.6%	YES	96.4	81	1.9	16.0%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R4	RESIDENTIAL	BEDROOM	W5/F31	32.8	25	7.8	23.8%	NO	97	74.8	2.7	22.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R5	RESIDENTIAL	STUDIO-APT	W6/F31	32.6	23.8	8.8	27.0%	NO	97.5	64.6	5.6	33.8%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R6	RESIDENTIAL	STUDIO-APT	W7/F31	32.4	21.9	10.5	32.4%	NO	96.6	89.6	1.2	7.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R7	RESIDENTIAL	STUDIO-APT	W8/F31	32.3	17.4	14.9	46.1%	NO	98.3	86.3	2.6	12.3%	YES	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			STUDIO-APT	W9/F31	32.3	14.6	17.7	54.8%	NO													
	R8	RESIDENTIAL	BEDROOM	W10/F31	32.4	11	21.4	66.0%	NO	97.4	27	6.4	72.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R9	RESIDENTIAL	BEDROOM	W11/F31	32.6	8.5	24.1	73.9%	NO	96	10.4	7.8	89.2%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R10 (3)	RESIDENTIAL	STUDIO-APT	W12/F31	33	7.6	25.4	77.0%	NO	96.9	9.4	15.3	90.3%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R11 (3)	RESIDENTIAL	STUDIO-APT	W13/F31	33.5	6.7	26.8	80.0%	NO	97.4	9.8	15.3	89.9%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	R12	RESIDENTIAL	STUDIO-APT	W14/F31	34.1	6.3	27.8	81.5%	NO	97.4	10.4	15.2	89.4%	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	