

Attenuation:

based on:

Site boundary area =

D, allow = 2.0 l/s

Proposed catchments area = 204 m^2

MS-60 = 18,00 mm

R = 0,35

lin 100 + 40% CC area

Attenuation required:

lin 30 = 2 m^3 1,5 m^3

lin 100 = 2,5 m^3

lin 100 + 40% CC = 4,4 m^3