

SCHEDULE NO. 11 – HYBRID VENTILATION UNITS

Ref	Location	Type
Level 0		
HVU/0/01	Lo.42 Workshop	HTMF-H
<u>HVU/0/02</u>	<u>Omitted</u>	
HVU/0/03	Lo.43 Multi Mat Prep Room	HTMF-H
HVU/0/04	Lo.38 Food Science	HTMF
HVU/0/05	Lo.38 Food Science	HTMF-H
HVU/0/06	Lo.46 Design Studio	HTMF
HVU/0/07	Lo.46 Design Studio	HTMF-H
<u>HVU/0/08</u>	<u>Lo.37 General Art</u>	<u>HTMF (1No Ducted Ø250mm Spigot)</u>
HVU/0/09	Lo.37 General Art	HTMF-H
HVU/0/10	Lo.47 General Art	HTMF
HVU/0/11	Lo.47 General Art	HTMF-H
HVU/0/12	Lo.30 Extensive Music	HTMF-H
<u>HVU/0/13</u>	<u>Lo.06 Library Community Hub</u>	<u>HTMF-H (2No Ducted Ø250mm Spigots)</u>
<u>HVU/0/14</u>	<u>Omitted</u>	
<u>HVU/0/15</u>	<u>Lo.55 Student Support</u>	<u>HTMF-H</u>
<u>HVU/0/16</u>	<u>Lo.29 ICT Rich Classroom</u>	<u>HTMF</u>
Level 1		
HVU/1/01	L1.50 Classroom Eng 01	HTMF-H
HVU/1/02	L1.52 Classroom Eng 02	HTMF-H
HVU/1/03	L1.53 Classroom Eng 03	HTMF-H
HVU/1/04	L1.54 Classroom Eng 04	HTMF-H
HVU/1/05	L1.42 Classroom Eng 05	HTMF-H
HVU/1/06	L1.55 Classroom Eng 06	HTMF-H
HVU/1/07	L1.41 Classroom Eng 07	HTMF-H
HVU/1/08	L1.56 Classroom Eng 08	HTMF-H
HVU/1/09	L1.57 Classroom Eng 09	HTMF-H
HVU/1/10	L1.40 Classroom Eng 10	HTMF-H
HVU/1/11	L1.59 Class Seminar Hum 04	HTMF-H
HVU/1/12	L1.60 Classroom Hum 05	HTMF-H
HVU/1/13	L1.61 Seminar Isolation	HTMF-H
HVU/1/14	L1.34 Classroom Hum 03	HTMF-H
HVU/1/15	L1.33 Classroom Hum 02	HTMF-H
HVU/1/16	L1.32 Classroom Hum 01	HTMF-H
HVU/1/17	L1.28 Classroom MFL 01	HTMF-H
HVU/1/18	L1.27 Classroom MFL 02	HTMF-H

HVU/1/19	L1.26 Classroom MFL 03	HTMF-H
HVU/1/20	L1.25 Classroom MFL 04	HTMF-H
HVU/1/21	L1.24 Classroom MFL 05	HTMF-H
Level 2		
HVU/2/01	L2.34 Classroom Maths 01	HTMF-H
HVU/2/02	L2.36 Classroom Maths 02	HTMF-H
HVU/2/03	L2.37 Classroom Maths 03	HTMF-H
HVU/2/04	L2.38 Classroom Maths 04	HTMF-H
HVU/2/05	L2.26 Classroom Maths 05	HTMF-H
HVU/2/06	L2.39 Classroom Maths 07	HTMF-H
HVU/2/07	L2.25 Classroom Maths 06	HTMF-H
HVU/2/08	L2.40 Classroom Maths 09	HTMF-H
HVU/2/09	L2.24 Classroom Maths 08	HTMF-H
HVU/2/10	L2.41 Classroom Maths 10	HTMF-H
HVU/2/11	L2.43 Classroom Float 02	HTMF-H
HVU/2/12	L2.46 Classroom Hum 06	HTMF-H
HVU/2/13	L2.47 Classroom Hum 07	HTMF-H
HVU/2/14	L2.48 Classroom Hum 08	HTMF-H
HVU/2/15	L2.02 Classroom Hum 09	HTMF-H
HVU/2/16	L2.03 Classroom Hum 10	HTMF-H
HVU/2/17	L2.04 Science Studio 4	HTMF-H
HVU/2/18	L2.05 Science Lab 5	HTMF
HVU/2/19	L2.05 Science Lab 5	HTMF-H
HVU/2/20	L2.06 Science Studio 3	HTMF-H
HVU/2/21	L2.07 Science Lab 4	HTMF-H
HVU/2/22	L2.09 Science Class 1	HTMF-H
HVU/2/23	L2.10 Science Lab 3	HTMF
HVU/2/24	L2.10 Science Lab 3	HTMF-H
HVU/2/25	L2.13 Science Studio 2	HTMF-H
HVU/2/26	L2.07 Science Lab 4	HTMF
HVU/2/27	L2.14 Science Lab 2	HTMF-H
HVU/2/28	L2.14 Science Lab 2	HTMF
HVU/2/29	L2.15 Science Lab 1	HTMF-H
HVU/2/30	L2.15 Science Lab 1	HTMF
HVU/2/31	L2.16 Science Studio 1	HTMF-H

Notes:

- Each unit is to be supplied complete with a fully automatic intelligent control system with seasonal control, external and internal temperature, SD card Data logger and a wall mounted controller, which includes inbuilt CO₂ sensors for indoor air quality monitoring, user override buttons and traffic light indicator for guidance on window operation. Units to be linked to the BMS via modbus.
- Louvre manufacturer / provider to provide insect mesh.