

Notes

- This drawing to be read in conjunction with all mechanical, electrical & public health drawings for this contract.
- All services work to be carried out in accordance with the relevant Engineering Specification for this contract.

Legend

- Main fire alarm control panel
- Fire alarm repeater panel
- Fire alarm battery cubicle (if required)
- Aspirated fire alarm control panel
- Manual call point (flush)
- Manual call point (surface)
- Optical smoke detector
- Fixed temperature heat detector
- Multi-criteria detector (optical, heat & CO₂)
- Optical smoke detector with sounder base
- Fixed temperature heat detector with sounder base
- Multi-criteria with sounder base
- Optical smoke detector with sounder & visual alarm base
- Fixed temperature heat detector with sounder & visual alarm base
- Multi-criteria detector with sounder & visual alarm base
- Sounder & visual alarm device only
- Electronic sounder
- Flashing alarm indicator
- Automatic detector remote indicator lamp
- Magnetic door holder
- Interface unit
- Beam transmitter & receiver unit
- Reflector
- Emergency voice communication system central control unit (Disabled Refuse Intercom)
- EVCS (Disabled Refuge) Type B Outstation

04	09/09/22	CAT A / B Contractor Issue	MW	RMF
03	12/08/22	CAT B Issue For Planning.	RMF	RMF
02	29/04/22	Stage 4 Tender Issue	RMF	RMF
01	31/03/22	Stage 3 Issue	RMF	RMF
Revision	Date	Description	Drawn	Checked



hilsonmoran.com info@hilsonmoran.com

Client
Bruntwood

Project
38-42 Mosley Street
Grade 2* Listed Building Refurbishment

Drawing Title Electrical Services Third Floor Cat B Fire Alarm & Security Services layout			
Scale 1:100	Sheet Size A1	Checked RMF	Approved SR
Status FOR INFORMATION	HM Project No. 27618		
Drawing No. 27618-HM-ZZ-03-DR-ES-6204	Rev 04		

